

MVG

POD Data

08S 22E 28 SWNWSW

Legal Description	GPS Site ID	Diversion Name	Meas Option	POD
08S 22E 28 SWNWSW	A0004032			100712
Latitude 042:41:46.091	Longitude -113:53:31.048	GPS File R051501A	PCC (2)	

Flowmeter Data

Year	Date	Calibration Factor	Max CFS	Adj Max CFS	Acre-Ft	Adj Acre-Ft	Acre-Ft Qualif	Valid	Prefrd
1999	7/2/1998						ND	☐	☐
	Comments								
1998	7/2/1998	0.91					ND	☐	☐
	Comments								

Flowmeter Calibration

Calibration Date: 7/2/1998 Calibration Factor: 0.91

100712

Installed Meter	Standard Meter	Other well(s):
Meter Type: PROPELLER	Pipe Material:	
Manufacturer: McCROMETER	Outside Diameter:	Other meter(s): N
Model:	Wall Thickness:	Comments:
Serial Number: 98261512	Upstream Straight:	4 BARS, STANDARD
Rate Units: GPM	Downstream Straight:	
Rate Multiplier: 1	Meter Type:	
Volume Units: AF	Measured Flow Units:	
Volume Multiplier: 0.001	Measured Flow:	
Location: GOOD	Confidence:	
Indicated Flow:		Changed:

PCC Data

Year	Total KWH	PCC Acre-Ft	Qualifier	PCC	PCC Date	Utility	Account Number	Service Number
2002	325840.00	273.4	1	1191.7	07/10/2002	IP	693480908	868191907
Comments:						Tracking: ☐	Preferred: ☐	Validated: ☐
							Change Date: 5/12/2003	
1998	203840.00	186.3	1	1094	07/02/1998	IP	18560004231	
Comments:						Tracking: ☐	Preferred: ☐	Validated: ☐
							Change Date:	
1999	286560.00	261.9	1	1094	07/02/1998	IP	18560004231	
Comments:						Tracking: ☐	Preferred: ☐	Validated: ☐
							Change Date:	
2000	361280.00	330.24	1	1094	07/02/1998	IP	18560004232	
Comments:						Tracking: ☐	Preferred: ☐	Validated: ☐
							Change Date: 8/25/2001	

Legal Description	GPS Site ID	Diversion Name	Meas Option	POD
2001	267680.00	244.7	5	1094
07/02/1998	IP	18560004232	868191907	

Comments: **MVGWD reported no use but IPCO power data showed kWh use above. Ownership change between Rustic Ag**

Tracking: ☐ Preferred: ☐ Validated: ☐ Change Date:

PCC Calibration

Date	PCC	Change Date
07/10/2002	1191.7	1/8/2003

Kilowatt-Hour Meter	Condition #1	Condition #2	Condition #3
Utility ☐ IP	KW 174 GPM 793 PCC 1191.67 PSI Percent 100	KW 0 GPM 0 PCC PSI 0 Percent 0	KW 0 GPM 0 PCC PSI 0 Percent 0
Pole No 559	Descrip	Descrip	Descrip
Meter Mfr A			
Meter S/N 03874086			
Disk Const 1.2			
Multiplier 80			

Date	PCC	Change Date
07/02/1998	1094	

Kilowatt-Hour Meter	Condition #1	Condition #2	Condition #3
Utility ☐ IP	KW 169 GPM 839 PCC 1094 PSI 69 Percent 100	KW 0 GPM 0 PCC PSI 0 Percent 0	KW 0 GPM 0 PCC PSI 0 Percent 0
Pole No	Descrip	Descrip	Descrip
Meter Mfr A			
Meter S/N 01377771			
Disk Const			
Multiplier			

Site Visits

Site Visit Date	Site Examiner	Reason	Change Date
7/10/2002	BHIGGS	PCC Calibration	1/8/2003

Notes: Operates 1 pivot. End gum mot on @ 1st, then on. Use 793 gpm. Very good meas section. Corners dry grain. Beets. Bars 4, power 4.

Site Visit Date	Site Examiner	Reason
7/2/1998	BHIGGS	Flowmeter Calibration

Notes: System runs pivot. Very smooth. New installation.