

TRANSMITTAL COVER SHEET

TO: Pam SkaggsTOTAL PAGES SENT: 2
(including cover sheet)
DOCUMENT DESCRIPTION: Bailey 70925

FROM:

IDAHO DEPARTMENT OF WATER RESOURCES
1341 FILLMORE ST, STE 200
TWIN FALLS ID 83301-3380PHONE: 736-3033
FAX: 736-3037CHARGES: One (1) free copy
per request, cover sheet not
counted. Two (2) or more
copies per request will cost
\$0.25 per page. (\$0.50
minimum)

Please consider this document as a billing statement.

The charge for your fax copies is: _____ Please remit to the above address.

SENDER: Cindy Genter

COMMENTS: _____

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Application No: Transfer 70925
Water Right No: 36-13645, et al
Applicant Name: Bailey, Chad and Susan

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:

(R05) Watermaster jurisdiction, Water District 130
(115) Measuring device required
No new wells to be constructed*

- c) ☐ I oppose approval of this application for the following reasons:
- d) ☒ Additional comment:

* I am concerned there is only a single pod associated with this facility, noted as one existing well on the application. Most facilities want or need a backup well; often the backup is the house well. A second well is not mentioned anywhere and possibly does not exist. Notes in the 36-13645 record indicate that the diversion works "are not capable of diverting the recommended div. rate" of 0.08 cfs, although the transfer proposes a new diversion rate of 0.19 from this same well. Is the water user expecting to drill a new well?

I found an error in draft condition comments for 43-13346 and 13348 (#4), where the total combined rate of flow is shown as 19.0 rather than 0.19.

Dated: April 15, 2004

Water District 130



Cindy J Yenter, Watermaster