


11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile.


BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

MICROFILMED

FEB 26 1990

Benjamin M. Apple, VICE PRES.
(Applicant)

3. **Delivery System Diagram:** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe i.d. as applicable.



Scale: 1" = _____

☒ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

☐ Aerial Photo Attached (required for irrigation of 10+ acres)

☒ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
	Franklin	100	Sulom.	CROWN	10'
			(8M700STD)	700 (Layne)	

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date
Sparking meter				6-03474	10	3/16/90

2. Measurements: 550 gpm, time of visit (Rated 750 @ 325 TDH)
From daily 1992 records: 645 gpm = 1.44 cfs on 8/18/92
(copy attached)

OCT

SERVICE LEVEL: BARBER

63-10862

PAGE 12

POOR QUALITY

AUG 20, 1992 8:14

WELLS	PUMP SETTING (ET)	PUMP CAPACITY (GPM)	TOTAL OPR HRS	TOTAL PUMPED (MG)	MEASURED PARAMETERS	AVE	HIGH TIME	LOW TIME	LAST	FAIL PWR	HOURS CON
BERGESON W20PUMP	260	750	24.00	1.824	W50 FLOW W50DPRES W50 GPM W50 S.HD RUN W50 S.HD	572.0 62.5 572.0 0.0 0.0	600.0 76.9 345.0 39.8 0.0	400 1532 5 5 1440 0 0	507.0 40.5 517.0 29.4 *****	15 0 5 4 1533 459 0 0	0.0 0.0 BERGESON
CENTENNL W21PUMP	277	1500	22.75	1.169	W21FLOW W21DPRES W21 S.HD RUN W21 S.HD	856.0 58.8 5.8 64.1	974.0 73.0 51.9 70.1	645 1532 10 7 10 6	574.0 38.6 1.9 5.9	1015 5 5 740 851	0.0 0.0 CENTENNL
LOGGER W10PUMP	310	1200	24.00	0.835	W10FLOW W10DPRES W10 S.HD RUN W10 S.HD	522.0 68.1 522.0 0.0	595.0 82.7 79.9 0.0	1315 1357 1531 0 0	506.0 45.1 50.0 *****	1415 5 5 5 5 0 0	0.0 0.0 LOGGER
SEWER RM W55PUMP	133	500	24.00	0.000	W55FLOW W55DPRES W55 FLOW W55 S.HD RUN W55 S.HD	0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	0.0 0.0 SEWER RM

EXCURSION

TOTAL OPR HRS	TOTAL PUMPED (MG)	MEASURED PARAMETERS	AVE	HIGH TIME	LOW TIME	LAST	FAIL PWR	HOURS CON
---------------------	-------------------------	------------------------	-----	-----------	----------	------	-------------	--------------

BARBER


FIRST PUNCH

2000-0000 BARBER

TOTAL OPR HRS	TOTAL PUMPED (MG)	MEASURED PARAMETERS	AVE	HIGH TIME	LOW TIME	LAST	FAIL PWR	HOURS CON
0.000	0.000	REV FLOW PUMPING PUMPING	0.0 0.0 0.0	0.0 0.0 0.0	0.0 0.0 0.0	0.0 0.0 0.0	0.0 0.0 0.0	0.0 0.0 0.0

RECEIVED
OCT 26 1994

POOR QUALITY



63-10862



Shown: wellhead &
flowmeter

RECEIVED
OCT 26 1994

State of Idaho
Department of Water Resources

WATER RIGHT LICENSE

WATER RIGHT NO. 63-10862

Priority: July 18, 1989

Maximum Diversion Rate:

1.44 CFS

This is to certify, that BOISE WATER CORP
PO BOX 7488
BOISE ID 83701

has complied with the terms and conditions of the permit, issued pursuant to Application for Permit dated July 18, 1989; and has submitted Proof of Beneficial Use on December 9, 1991. An examination indicates that the works have a diversion capacity of 1.440 cfs of water from a GROUNDWATER source, and a water right has been established as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
MUNICIPAL	01/01 to 12/31	1.44 CFS	

LOCATION OF POINT(S) OF DIVERSION:


NWNESE , Sec. 26, Township 03N, Range 02E
ADA County

PLACE OF USE: See Remarks

CONDITIONS/REMARKS:

1. This water right is appurtenant to the described place of use.
2. This right is subject to all prior water rights and may be forfeited by five years of non-use.
3. Modifications to or variance from this license must be made within the limits of Section 42-212, Idaho Code, or the applicable Idaho law.
4. The issuance of this right in no way grants any right-of-way or easement across the land of another.
5. Place of use is located within the city limits of Boise and the surrounding service area.
6. Point of diversion known as the Sempson well.

This license is issued pursuant to the provisions of Section 42-219, Idaho Code. Witness the seal and signature of the Director, affixed at Boise, this 11TH day of OCTOBER, 1994.


Acting for R. Keith Higginson, Director

APPROVED
OCT 26 1994

APPROVED

State of Idaho
Department of Water Resources

RECEIVED
AUG 30 1994

APPLICATION FOR AMENDMENT
(For Licensing Purposes)
WATER RIGHT NO. 63-10862

State of Idaho Department of Water Resources

Date of Priority: July 18, 1989 Maximum Diversion Rate: 1.44 CFS
Comes now BOISE WATER CORP
PO BOX 7488
BOISE ID 83701 and represents to the Director of the

Idaho Department of Water Resources:

That he is the owner and holder of Permit to appropriate the Public Waters of the State of Idaho No. 63-10862, and requests that the permit be changed as follows:

Source: GROUNDWATER

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
MUNICIPAL	01/01 to 12/31	1.44 CFS	

LOCATION OF POINT(S) OF DIVERSION: NWNESE , Sec. 26, Township 03N, Range 02E
ADA County

PLACE OF USE: See Remarks

RECEIVED

OCT 26 1994

Permit holder asserts that no one will be injured by such change and that such change will be made at permit holder's own risk.

Signed at Boise Water Corp, this 16th day of AUGUST, 1994.

Benjamin M. Kipler
(Signature)

State of Idaho
Department of Water Resources

APPLICATION FOR AMENDMENT
(For Licensing Purposes)
WATER RIGHT NO. 63-10862

FOR DEPARTMENT USE ONLY

Preliminary check by BC Fee = 50.00 Receipted by RT # C031170 Date 8/30/94


ACTION OF THE DEPARTMENT OF WATER RESOURCES

I, R. Keith Higginson, of the Department of Water Resources hereby approve the above Application for Amendment for Permit No. 63-10862 with the following;


CONDITIONS/REMARKS:

1. This water right is appurtenant to the described place of use.
2. This right is subject to all prior water rights and may be forfeited by five years of non-use.
3. Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho law.
4. The issuance of this right in no way grants any right-of-way or easement across the land of another.
5. Place of use is located within the city limits of Boise and the surrounding service area.
6. Point of diversion known as the Bergeson well.

Witness my hand this 11TH day of OCTOBER, 1994.


Acting for R. Keith Higginson, Director

OCT 26 1994



STATE OF IDAHO

For Office Use Only
Amt. of Fee \$ 125.00
Date 12/15/91
Receipt No. 0022574
Received by KCB

DEPARTMENT OF WATER RESOURCES

PROOF OF BENEFICIAL USE

Department of Water Resources

The Idaho Department of Water Resources will consider this form as a statement that the permit holder(s) has/have completed all development that will occur under this permit and that water has been applied according to the provisions of the permit for the beneficial use(s) described below. This form must be accompanied by a license examination fee or a completed field examination report prepared by a certified water right examiner who has been appointed by the department.

1. Permit No. 63-10862 Telephone No. 362-1300

2. Name(s) of Permit Holder(s): Boise Water Corp.

3. Post Office Address: Box 7488

4. Source of Water: Groundwater

a. If ground water, well driller's name: Stevens & Sons Date drilled: 2/11/90

b. Pump horsepower: 100 Pressure (psi): 49 Dynamic pumping level (ft.): 225

5. Extent of Use:

Domestic _____ (No. of households)

Irrigation _____ (No. of acres)

Stockwater _____ (No. and type of stock)

Other Municipal

6. Total rate and/or volume for which proof is submitted 1.67 cfs _____ acre/feet

7. Refer to the approval conditions on your permit and respond accordingly:

Measuring device: Required? ☒ Yes ☐ No Installed? ☒ Yes ☐ No

OR

Flow Measurement Port: Required? ☐ Yes ☐ No Installed? ☐ Yes ☐ No

8. Fee Enclosed: \$ 125.00 (See License Examination Fee Schedule)

9. Person to contact to accompany the Department representative during the field examination:

James L. Mooney
Name


362-1300
Telephone No.

8248 W. Victory Rd. Boise, ID 83707
Address

10. The above information is my true statement of the extent to which the above numbered permit has been developed and I relinquish any undeveloped portion of the permit to the state of Idaho.

12/15/91
Date

Jon Bowling, Staff Engineer
Signature (and title if on behalf of a company or organization)



State of Idaho
Department of Water Resources

Permit To Appropriate Water

NO. 63-10862

Proposed Priority: July 18, 1989

Maximum Diversion Rate:

1.67 CFS

This is to certify, that **BOISE WATER CORP.**
P.O. BOX 7488
BOISE, ID 83701

has applied for a permit to appropriate water from: **GROUNDWATER**
and a permit is **APPROVED** for development of water as follows:

BENEFICIAL USE

PERIOD OF USE

RATE OF DIVERSION

MUNICIPAL

01/01 to 12/31

1.67 CFS

LOCATION OF POINT(S) OF DIVERSION:

NWSE Sec. 26, Township 03N, Range 02E
ADA County

PLACE OF USE: See Remarks

CONDITIONS/REMARKS:

1. Proof of construction of works and application of water to beneficial use shall be submitted on or before **February 1, 1992.**
2. Subject to all prior water rights.
3. The point of diversion identified in this permit is located within the boundaries of the Boise Front Low Temperature Geothermal Resource Groundwater Management Area. The well driller must monitor water temperatures while drilling the well. If water with a temperature greater than 85 degrees Fahrenheit is encountered by the driller, drilling must immediately cease, and the Department must be notified. Drilling shall not resume until the Department has reviewed the drilling conditions, and established standards for construction with the driller.
4. Permit holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code.
5. Permit holder shall commence the excavation or construction of diverting works within one year of the date this permit is issued and shall proceed diligently until the project is complete.
6. The issuance of this permit in no way grants any right-of-way or easement across the land of another.
7. Prior to the diversion of water under this permit a flow measurement port or other device as specified by the Department shall be installed to provide for the installation of measuring equipment and the determination of the rate of diversion by the Department.
8. Place of use is within the city limits of Boise.

MICROFILMED

FEB 26 1990

State of Idaho
Department of Water Resources

Permit To Appropriate Water

NO. 63-10862

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code.
Witness the seal and signature of the Director, affixed at Boise, this

23rd day of January, 1990

for *R. Keith Higginson*
R. Keith Higginson, Director

MICROFILMED

FEB 28 1990

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT

RECEIVED
JUL 18 1989

To appropriate the public waters of the State of Idaho

Department of Water Resources
Western Regional Office

1. Name of applicant Boise Water Corporation Phone (208) 362-1300

Post office address P. O. Box 7488 Boise, Idaho 83701

2. Source of water supply Groundwater which is a tributary of _____

3. Location of point of diversion is NW $\frac{1}{4}$ of SE $\frac{1}{4}$ of Section 26 Township 3 North

Range 2 East B.M. Ada County, additional points of diversion if any: _____

4. Water will be used for the following purposes:

Amount 1.67 for Municipal purposes from Jan. 1 to Dec. 31 (both dates inclusive)
(cfs or acre-feet per annum)

Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)

Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)

Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)

5. Total quantity to be appropriated:

a. 1.67 cubic feet per second and/or b. _____ acre-feet per annum.

6. Proposed diverting works:

a. Description of ditches, flumes, pumps, headgates, etc. An 18" drilled and 10" cased deep well approximately 700' deep. Pumped by a deep well turbine driven by an electric motor. Discharge will be directly to applicant's distribution system.

b. Height of storage dam N/A feet, active reservoir capacity N/A acre-feet; total reservoir capacity N/A acre-feet, materials used in storage dam: N/A

Period of year when water will be diverted to storage N/A to N/A inclusive.
(Month/Day) (Month/Day)

c. Proposed well diameter is 18 inches; proposed depth of well is 700 feet.

7. Time required for the completion of the works and application of the water to the proposed beneficial use is 2 years (minimum 1 year - maximum 5 years).

8. Description of proposed uses:

a. If water is not for irrigation:

(1) Give the place of use of water: _____ $\frac{1}{4}$ of _____ $\frac{1}{4}$ of Section _____ Township _____

Range _____ B.M.

(2) Amount of power to be generated: _____ horsepower under _____ feet of head.

(3) List number of each kind of livestock to be watered N/A

(4) Name of municipality to be served Boise, Idaho, or number of families to be supplied with domestic water _____

(5) If water is to be used for other purposes describe: N/A

MICROFILMED

FEB 26 1990

b. If water is for irrigation, indicate acreage in each subdivision in the tabulation below:

TWP	RANGE	SEC.	NE¼				NW¼				SW¼				SE¼				TOTALS
			NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	

Total number of acres to be irrigated _____

c. Describe any other water rights used for the same purposes as described above. All perimts
for Boise Water Corporation as filed and on record in the Department of Water
Resources.

9. a. Who owns the property at the point of diversion Triangle Development Company
b. Who owns the land to be irrigated or place of use N/A
c. If the property is owned by a person other than the applicant, describe the arrangement enabling the
applicant to make this filing Boise Water Corporation is acquiring a long term lease
from the owner.


10. Remarks Water will be used to augment Boise Water Corporation's existing system
and provide service to an expanding system.

Company name for well: Bergeson St. Well

Drilling Permit 63-89-W-171 approved 9/7/89. 82.

MICROFILMED
FEB 26 1990

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile.

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

MICROFILMED
FEB 26 1990

Benjamin M. Hepler, VICE PRES.
(Applicant)

Received by SL for NS Date 7/18/89 Time 1:00 pm
Preliminary check by SL Fee \$ 65⁰⁰ W003701
Receipted by SL Date 7-18-89
Publication prepared by GG Date 8-9-89
Published in ID Statesman
Publication dates 8/17 & 8/23/89
Publication approved SL Date 9-12-89
Protests filed by: _____

Copies of protests forwarded by _____
Hearing held by _____ Date _____
Recommended for approval denial by DRT

ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. _____, and said application is hereby _____.

1. Approval of said application is subject to the following limitations and conditions:

- a. SUBJECT TO ALL PRIOR WATER RIGHTS.
- b. Proof of construction of works and application of water to beneficial use shall be submitted on or before _____, 19 ____.
- c. The rate of diversion, if water is to be used for irrigation under this permit, when combined with all other water rights for the same land shall not exceed 0.02 cubic feet per second for each acre of land.
- d. Other:

MICROFILMED

FEB 26 1990

63-10862

RECEIVED
OCT 18 1989

Department of Water Resources

RECEIVED
OCT 17 1989

Department of Water Resources
Western Regional Office

Boise Water Corporation
Corporate Officers

President
Secretary
Directors

Wayne L. Booe
Charles A. Martin
George B. Flegal, Jr.
Wayne L. Booe
Lewis R. Masotti

P. O. Box 8066, Boise, Idaho 83707
P. O. Box 8066, Boise, Idaho 83707
950 Haverford Rd., Bryn Mawr, PA 19010
P. O. Box 8066, Boise, Idaho 83707
950 Haverford Rd., Bryn Mawr, PA 19010

MICROFILMED

FEB 26 1990



State of Idaho
DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000
Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

October 12, 1994

BOISE WATER CORP
PO BOX 7488
BOISE ID 83701

RE: WATER RIGHT NO. 63-10862

Dear Water Right Holder(s):

Enclosed is a copy of the Water Right License issued on the above referenced permit along with a copy of your approved Application for Amendment.

Should you have any questions regarding these documents, please contact me.

Sincerely,

A handwritten signature in cursive script, reading 'Shelley W. Keen'.

Shelley W. Keen
Water Rights Supervisor

SK:dc

Enclosure

MAILED
OCT 26 1994



State of Idaho
DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000
Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

August 9, 1994

BOISE WATER CORP
PO BOX 7488
BOISE ID 83701

RE: WATER RIGHT NO. 63-10862

Dear Water Right Holder(s):

I previously forwarded to you an Application for Amendment so that you could amend your permit to correspond with the findings of the Department's field examiner.

As of this date, I have not received the amendment. If I do not receive it within fourteen (14) days, I will assume you no longer have any interest in the permit and cancellation proceedings will begin. Enclosed for your convenience is another amendment form in the event the first one was misplaced.

If you have any questions, please contact me. My telephone number is (208) 327-7947.

Sincerely,

JIM JOHNSON, Manager
Water Right Permits Section

JJ:dc

Enclosure

RECEIVED
OCT 26 1994



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

July 8, 1994

BOISE WATER CORP
PO BOX 7488
BOISE ID 83701

RE: WATER RIGHT NO. 63-10862

Dear Water Right Holder(s):

The above referenced water right is in the process of being licensed. However, before a license can be issued, your permit must be amended to correspond with the findings of the Department's field examiner.

The enclosed Application for Amendment contains information that will be included on the license when it is issued. The amendment reflects a change in the location of the point(s) of diversion. Please review carefully and if you concur, sign the amendment and return with the \$50.00 filing fee within 14 days.

The last page of the Application for Amendment form contains a list of CONDITIONS/REMARKS proposed for the license when it is issued. These conditions/remarks may be modified upon further administrative review.

If you do not concur or have any questions with this information, please contact me as soon as possible. My telephone number is (208) 327-7947.

Sincerely,

JIM JOHNSON, Section Manager
Water Right Permits Section

JJ:dc

Enclosure

OCT 26 1994

WRO749NP
No. L63-10862

IDAHO DEPARTMENT OF WATER RESOURCES
WATER RIGHT PROFILE REPORT

DATE: 07/07/94
PAGE: 1

OWNER CODE	NAME & ADDRESS	PRIORITY DATE	WATER USE	USE PERIOD FROM TO	DIVERSION RATE	DIVERSION VOLUME
C	BOISE WATER CORP PO BOX 7488 BOISE ID 83701 (208) 362-1300	07/18/1989	MUNICIPAL	01-01 12-31	1.44 CFS	
TOTAL DIVERSION:					1.44 CFS	

Water Source: GROUNDWATER

Tributary to:

Stage: LICENSE

Point(s) of Diversion Capacity: 1.44 CFS

Point(s) of Diversion: T03N R02E S26

NWNESE

ADA County

Pou County:

Conditions of Approval:

- 004 - The issuance of this right in no way grants any right-of-way
- or easement across the land of another.

Remarks: Place of use is located within the city limits of Boise and the
surrounding service area.

Dates: App. Received: 07/18/1989 Priority Date: 07/18/1989
Proof Due Date: 02/01/1992 Proof Made Date: 12/09/1991
Exam Made Date: 07/08/1993 Exam Sent to S.O.: 08/18/1993
Licensed Date:

Misc: Water District Number: Field Exam Fee:


Comments: Date: 12/09/1991 User-ID: VAULT Subject: Proof of Beneficial Use Rcvd
Proof of Beneficial Use Rcvd

Date: 12/13/1991 User-ID: VAULT Subject: Proof of Beneficial Use Rcvd
Proof of Beneficial Use Rcvd

Date: 07/07/1994 User-ID: BCHAPMAN Subject: WELL INFORMATION
This well is known as the Bergeson Well.

Audit: 07/07/94 BCHAPMAN

LICENSURE REVIEW CHECKLIST



PERMIT NO. 603-108602 DATE 7-7-94

NAME	Yes ☐ No ☒	Or Address Change?
PRIORITY DATE	☐ ☒	Advance? ☐ Advanced to: _____ Order to reinstate needed? _____ Incorrect fee for rate recommended? <u>NO</u>
SOURCE	☐ ☒	Changes or just clarification of originally intended source? _____ Notice of Intent to Void necessary? _____
POINT OF DIV	☒ ☐	Amendment needed? <u>CHANGE TO NESE</u> Overlaps? <u>NA</u>
PLACE OF USE	☐ ☒	Amendment needed? _____ Overlaps? <u>NA</u>
DIV RATE	☐ ☒	Measurement Q = <u>1.44</u> Theoretical Q = <u>1.55</u> <u>FROM Pumping RECORDS = HIGH @ 645 gpm or 1.44 cfs</u> Capacity: <u>1.44</u> Combined rates exceed capacity _____ <u>Permit/fee limits:</u> <u>1.67</u> Allowable: <u>1.44</u>
ANNUAL VOLUME	<u>NA</u>	Season of use: <u>Year around</u> Calculations: <u>Municipal</u> Flow limit: _____ cfs x _____ x 1.9835 = _____ Combined volumes exceed capacity/allowable _____
USES	☐ ☒	Change in Nature of Use or additional uses? _____ Amendment necessary? _____
REMARKS	☐ ☒	Multiple p/d(s) in 1/4 1/4? _____ Other _____
CONDITIONS	☐ ☒	Measuring/Locking Devices _____ Watermaster control - District _____ Irrigation Overlap _____ Water Quality _____ <u>004</u> Other _____

COMMENTS: KNOWN AS BERGESON WELL ; Reduce rate to capacity
Amend P/D

RECOMMENDED	CFS	VOLUME	LICENSE
<u>Municipal</u>	<u>1.44</u>	<u>NA</u>	
_____	_____	_____	1ST AMENDMENT LETTER <u>P39+P38</u>
_____	_____	_____	FINAL AMENDMENT LETTER <u>P47</u>



STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

RECEIVED

AUG 19 1993

Department of Water Resources

A. GENERAL INFORMATION

Permit No. 63-10862

1. Owner: BOISE WATER CORP

Phone No. 362-1300

Current Address: PO Box 7488 BOISE ID 83701

2. Accompanied by: DON MAYS

EXAM DATE: 7/8/93

Address: _____

Phone No. _____

Relationship to Permit Holder: Chief pump operator

3. Source: groundwater

tributary to _____

B. OVERLAP REVIEW

1. Other water rights with the same place of use: N/A

2. Other water rights with the same point of diversion: 63-10108

C. DIVERSION AND DELIVERY SYSTEM

1. Point(s) of Diversion:

Ident No.	Gov't Lot	1/4	1/4	1/4	Sec.	Twp.	Rge.	County	Method of Determination/Remarks
		NW	NE	SE	26	3N	2E	Ada	Site visit, orthophoto


2. Place(s) of Use: See remarks

Indicate Method of Determination _____

TWP	RGE	SEC	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	

OCT 26 1994

3. **Delivery System Diagram:** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe i.d. as applicable.



Scale: 1" = _____

☒ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

☐ Aerial Photo Attached (required for irrigation of 10+ acres)

☒ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
	Franklin	100	Subm. (8M700STD)	CROWN 700 (Layne)	10'

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date
Spurling meter				G-03474	10	3/16/90

2. Measurements: 550 gpm, time of visit (Rated 750 @ 325 TDH)
From daily 1992 records: 645 gpm = 1.44 cfs on 8/18/92
(copy attached)

E. NARRATIVE/REMARKS/COMMENTS

20" x 663' PL 235 via airline measure
Bowls set 252' pressure 70 psi

P/B Commonly known as Bergeson well.

Overlap does not affect this permit.

Place of use is within the service area of
Boise Water Corp.

System capacity & recommended ~~amount~~ rate
drawn from actual pumping records.

Have conditions of permit approval been met? ☒ yes ☐ no

MINNESOTA
OCT 26 1994

F. FLOW CALCULATIONS

____ Additional Computation Sheets Attached

Measured Method:

HP equation :
$$\frac{100 \times 8.8 \times .7}{235 + (70 \times 2.31)} = 1.55 \text{ cfs}$$

pumping records :

1.44 cfs = system capacity

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = \underline{N/R}$

$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 = \underline{\hspace{2cm}}$

$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = \underline{\hspace{2cm}}$

2. Volume Calculations for Other Uses:

H. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
<u>MUNICIPAL</u>	<u>1/1</u>	<u>12/31</u>	<u>1.44</u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Totals:			<u> </u>	<u> </u>

2. Recommended Amendments

☒ Change P.D. as reflected above ☐ Add P.D. as reflected above ☐ None
☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Gilodges Date 7/9/93

Reviewer _____ Date _____

SEAL

OCT 26 1994

63-10862


POOR QUALITY

Feb 1, 1952 416

WELLS	PUMP 15 MIN NET	PUMP 15 MIN GPM	TOTAL GPM HRS	TOTAL GPM HRS	MEASUREMENT PARAMETERS	AVE	HIGH TIME	LOW TIME	LAST	DATE	WELLS
BERGESDA WELPUMP	280	750	21.75	1.160	W21FLOW W21DPRES W21 G.M. W21 G.M.D W21 G.M.D	872.1 82.8 870.0 87.8 87.8	800.0 70.0 1532 80.0 5 5 80.0 1443 80.0 0 0	507.0 40.5 5 4 507.0 1530 50.4 450 ***** 0 0	800.0 48.0 618.5 37.6 0 0	0.0	0.0 BERGESDA
CENTENNL W21PUMP	277	1500	22.75	1.160	W21FLOW W21DPRES W21 G.M. W21 G.M.D	858.6 58.6 51.0 84.1	874.0 73.0 1532 10.7 7 10.6 6	574.0 38.6 5 5 740 5.9 851	825.0 45.1 2.2 0 0	0.0	0.0 CENTENNL
LOGGEE W21PUMP	210	1200	24.00	0.100	W21FLOW W21DPRES W21 G.M. W21 G.M.D	122.1 80.1 70.0 0.0	800.0 80.0 1537 70.0 1530 0.0 0 0	500.0 45.1 5 5 10.0 5 5 ***** 0 0	840.0 50.0 17.2 0 0	0.0	0.0 LOGGEE
WELLS WELPUMP	110	1000	24.00	0.100	W21FLOW W21DPRES W21 G.M. W21 G.M.D	122.1 80.1 70.0 0.0	800.0 80.0 1537 70.0 1530 0.0 0 0	500.0 45.1 5 5 10.0 5 5 ***** 0 0	840.0 50.0 17.2 0 0	0.0	0.0 WELLS

OCT 26 1994

POOR QUALITY



IDAHO DEPARTMENT OF WATER RESOURCES

WELL INSPECTION FORM

1. DRILLING PERMIT NO: 63-89-W-171 OTHER APPLICABLE NO: 63-10862
2. OWNER: BOISE WATER CORP Phone: _____
Address: _____
3. WELL LOCATION: Twp 3N, Rge. 2E, Sec. 26, NE 1/4 SE 1/4
County Ada (Provide sketch map and photo on reverse.)
4. DRILLER: Stevens & Sons Lic. No. 153
When Drilled? 2/11/90 (completed)
5. WELL CONSTRUCTION TD = 663
Casing Diameter 20 inches Water tight cap? ☒ Yes ☐ No Access Port: ☒ Yes ☐ No
Casing $\geq$ 12 inches above ground? ☒ Yes ☐ No - Describe _____
Depth of Casing 70 ft. Method Drilled Cable
Condition of Well Casing: ☒ Good ☐ Fair ☐ Poor Describe some corrosion
Control Valve? ☐ Yes ☒ No Pressure Gauge: ☐ Yes ☒ No
Condition of Piping and Valving GOOD
Auger to a depth of _____ ft. Evidence of Annular Seal ☐ Yes ☐ No
Are there obvious construction problems that may be a source for contamination or waste of water?
☐ Yes ☒ No (Describe in Remarks and Attach Photo - On Reverse)
6. HYDROLOGIC INFORMATION
Depth to Static Water 121 ft. Water Temperature _____ °F PL = 235
Flowing Artesian ☐ Yes ☒ No Pressure: 75 (psi)
Water Sample Taken? ☐ Yes ☒ No If yes, describe purpose _____
Water Quality Measurements/Observations (Describe) _____
7. WELL USE:
☐ Domestic ☐ Irrigation ☐ Stock
☐ Test ☒ Municipal ☐ Industrial
☐ Abandoned ☐ Waste Disposal/Injection ☐ Not Used
☐ Other: _____

RECEIVED
OCT 26 1994

Port needs plug

C. Hedges
Signature of Dept. Representative & Title

7/8/93
Inspection Date

PHOTOS, DRAWINGS, OTHER ATTACHMENTS:

RECEIVED

OCT 26 1994

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTUSE TYPEWRITER OR
BALLPOINT PENState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER Stevens & Sons, Inc. 3709 Hawthorne Dr. Boise, Idaho 83709 Owner's Permit No. C-39-W-171 (63-10862)		7. WATER LEVEL Static water level 121 feet below land surface. Flowing? ☐ Yes ☒ No G.P.M. flow Artesian closed-in pressure P.S.I. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature 9F, Quality Describe artesian or temperature zones below																																																																																																																																																																																			
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe abandonment procedures such as materials, plug depths etc. in lithologic log)		8. WELL TEST DATA ☒ Pump ☐ Bailor ☐ Air ☐ Other <table border="1"><thead><tr><th>Discharge G.P.M.</th><th>Pumping Level</th><th>Hours Pumped</th></tr></thead><tbody><tr><td>1200</td><td>215</td><td>12</td></tr></tbody></table>		Discharge G.P.M.	Pumping Level	Hours Pumped	1200	215	12																																																																																																																																																																												
Discharge G.P.M.	Pumping Level	Hours Pumped																																																																																																																																																																																			
1200	215	12																																																																																																																																																																																			
3. PROPOSED USE ☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other (specify type)		9. LITHOLOGIC LOG <table border="1"><thead><tr><th rowspan="2">Bore Dum.</th><th colspan="2">Depth</th><th rowspan="2">Material</th><th colspan="2">Water</th></tr><tr><th>From</th><th>To</th><th>Yes</th><th>No</th></tr></thead><tbody><tr><td>0</td><td>3</td><td></td><td>sandy brown clay topsoil</td><td></td><td>X</td></tr><tr><td>3</td><td>60</td><td></td><td>sand, gravel & boulders</td><td></td><td>X</td></tr><tr><td>60</td><td>145</td><td></td><td>streaks of blue, black & brown clay</td><td></td><td>X</td></tr><tr><td>145</td><td>185</td><td></td><td>sand, gravel, streaks of brown clay</td><td></td><td>X</td></tr><tr><td>185</td><td>195</td><td></td><td>brown clay</td><td></td><td>X</td></tr><tr><td>195</td><td>250</td><td></td><td>cemented sand & gravel</td><td></td><td>X</td></tr><tr><td>250</td><td>265</td><td></td><td>light brown clay</td><td></td><td>X</td></tr><tr><td>265</td><td>288</td><td></td><td>fine to medium sand & gravel</td><td></td><td>X</td></tr><tr><td>288</td><td>328</td><td></td><td>cemented sand & gravel</td><td></td><td>X</td></tr><tr><td>328</td><td>360</td><td></td><td>blue clay</td><td></td><td>X</td></tr><tr><td>360</td><td>365</td><td></td><td>cemented blue sand</td><td></td><td>X</td></tr><tr><td>365</td><td>389</td><td></td><td>blue clay</td><td></td><td>X</td></tr><tr><td>389</td><td>396</td><td></td><td>fine to coarse muddy sand</td><td></td><td>X</td></tr><tr><td>396</td><td>418</td><td></td><td>blue clay</td><td></td><td>X</td></tr><tr><td>418</td><td>426</td><td></td><td>streaks fine blue sand & blue clay</td><td></td><td>X</td></tr><tr><td>426</td><td>474</td><td></td><td>sticky blue clay</td><td></td><td>X</td></tr><tr><td>474</td><td>522</td><td></td><td>fine to medium blue sand</td><td></td><td>X</td></tr><tr><td>522</td><td>530</td><td></td><td>blue clay</td><td></td><td>X</td></tr><tr><td>530</td><td>538</td><td></td><td>fine to medium blue sand</td><td></td><td>X</td></tr><tr><td>538</td><td>555</td><td></td><td>blue clay</td><td></td><td>X</td></tr><tr><td>555</td><td>565</td><td></td><td>hard dry brown clay</td><td></td><td>X</td></tr><tr><td>565</td><td>570</td><td></td><td>cemented sand & gravel</td><td></td><td>X</td></tr><tr><td>570</td><td>576</td><td></td><td>fine to coarse sand & gravel</td><td></td><td>X</td></tr><tr><td>576</td><td>582</td><td></td><td>brown clay</td><td></td><td>X</td></tr><tr><td>582</td><td>612</td><td></td><td>cemented sand & gravel</td><td></td><td>X</td></tr><tr><td>612</td><td>650</td><td></td><td>brown clay</td><td></td><td>X</td></tr><tr><td>650</td><td>657</td><td></td><td>cemented sand & gravel</td><td></td><td>X</td></tr><tr><td>657</td><td>663</td><td></td><td>brown clay</td><td></td><td>X</td></tr></tbody></table>		Bore Dum.	Depth		Material	Water		From	To	Yes	No	0	3		sandy brown clay topsoil		X	3	60		sand, gravel & boulders		X	60	145		streaks of blue, black & brown clay		X	145	185		sand, gravel, streaks of brown clay		X	185	195		brown clay		X	195	250		cemented sand & gravel		X	250	265		light brown clay		X	265	288		fine to medium sand & gravel		X	288	328		cemented sand & gravel		X	328	360		blue clay		X	360	365		cemented blue sand		X	365	389		blue clay		X	389	396		fine to coarse muddy sand		X	396	418		blue clay		X	418	426		streaks fine blue sand & blue clay		X	426	474		sticky blue clay		X	474	522		fine to medium blue sand		X	522	530		blue clay		X	530	538		fine to medium blue sand		X	538	555		blue clay		X	555	565		hard dry brown clay		X	565	570		cemented sand & gravel		X	570	576		fine to coarse sand & gravel		X	576	582		brown clay		X	582	612		cemented sand & gravel		X	612	650		brown clay		X	650	657		cemented sand & gravel		X	657	663		brown clay		X
Bore Dum.	Depth		Material		Water																																																																																																																																																																																
	From	To		Yes	No																																																																																																																																																																																
0	3		sandy brown clay topsoil		X																																																																																																																																																																																
3	60		sand, gravel & boulders		X																																																																																																																																																																																
60	145		streaks of blue, black & brown clay		X																																																																																																																																																																																
145	185		sand, gravel, streaks of brown clay		X																																																																																																																																																																																
185	195		brown clay		X																																																																																																																																																																																
195	250		cemented sand & gravel		X																																																																																																																																																																																
250	265		light brown clay		X																																																																																																																																																																																
265	288		fine to medium sand & gravel		X																																																																																																																																																																																
288	328		cemented sand & gravel		X																																																																																																																																																																																
328	360		blue clay		X																																																																																																																																																																																
360	365		cemented blue sand		X																																																																																																																																																																																
365	389		blue clay		X																																																																																																																																																																																
389	396		fine to coarse muddy sand		X																																																																																																																																																																																
396	418		blue clay		X																																																																																																																																																																																
418	426		streaks fine blue sand & blue clay		X																																																																																																																																																																																
426	474		sticky blue clay		X																																																																																																																																																																																
474	522		fine to medium blue sand		X																																																																																																																																																																																
522	530		blue clay		X																																																																																																																																																																																
530	538		fine to medium blue sand		X																																																																																																																																																																																
538	555		blue clay		X																																																																																																																																																																																
555	565		hard dry brown clay		X																																																																																																																																																																																
565	570		cemented sand & gravel		X																																																																																																																																																																																
570	576		fine to coarse sand & gravel		X																																																																																																																																																																																
576	582		brown clay		X																																																																																																																																																																																
582	612		cemented sand & gravel		X																																																																																																																																																																																
612	650		brown clay		X																																																																																																																																																																																
650	657		cemented sand & gravel		X																																																																																																																																																																																
657	663		brown clay		X																																																																																																																																																																																
4. METHOD DRILLED Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary ☒ Cable ☐ Day ☐ Other																																																																																																																																																																																					
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other <table border="1"><thead><tr><th>Thickness</th><th>Diameter</th><th>From</th><th>To</th></tr></thead><tbody><tr><td>.250 inches</td><td>20 inches</td><td>0 feet</td><td>70 1/2 feet</td></tr><tr><td>.375 inches</td><td>18 inches</td><td>70 1/2 feet</td><td>32 1/8 feet</td></tr><tr><td>.250 inches</td><td>10 inches</td><td>32 1/8 feet</td><td></td></tr></tbody></table> Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☒ Yes ☐ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation inches by inches <table border="1"><thead><tr><th>Number</th><th>From</th><th>To</th></tr></thead><tbody><tr><td>perforations</td><td>feet</td><td>feet</td></tr><tr><td>perforations</td><td>feet</td><td>feet</td></tr><tr><td>perforations</td><td>feet</td><td>feet</td></tr></tbody></table> Well screen installed? ☒ Yes ☐ No Manufacturer's name Johnson Type stainless steel Model No. 304 Diameter 10 Slot size 30 Set from feet to feet Diameter 10 Slot size 30 Set from feet to feet Gravel packed? ☒ Yes ☐ No Size of gravel 8-12 sand Placed from 291 feet to 663 feet Surface seal depth 70 Material used in seal: ☐ Cement grout ☒ Bentonite ☐ Pudding clay ☐ Sealing procedure used: ☒ Slurry pit ☐ Temp. surface casing ☐ Overbore to seal depth Method of joining casing Threaded ☒ Welded ☐ Solvent Cemented between Describe access port		Thickness	Diameter	From	To	.250 inches	20 inches	0 feet	70 1/2 feet	.375 inches	18 inches	70 1/2 feet	32 1/8 feet	.250 inches	10 inches	32 1/8 feet		Number	From	To	perforations	feet	feet	perforations	feet	feet	perforations	feet	feet																																																																																																																																																								
Thickness	Diameter	From	To																																																																																																																																																																																		
.250 inches	20 inches	0 feet	70 1/2 feet																																																																																																																																																																																		
.375 inches	18 inches	70 1/2 feet	32 1/8 feet																																																																																																																																																																																		
.250 inches	10 inches	32 1/8 feet																																																																																																																																																																																			
Number	From	To																																																																																																																																																																																			
perforations	feet	feet																																																																																																																																																																																			
perforations	feet	feet																																																																																																																																																																																			
perforations	feet	feet																																																																																																																																																																																			
6. LOCATION OF WELL Sketch map location must agree with written location BERGESON ST Subdivision Name Lot No. Block No. County Ada N/W S/E 26 T. 3 S. R. 2 E/W USE ADDITIONAL SHEETS IF NECESSARY - FORWARD THE WHITE COPY TO THE DEPARTMENT		10. DRILLERS CERTIFICATION I/We certify that all minimum well construction standards were complied with at the time the rig was removed. Firm Name Stevens & Sons Firm No. 153 Address 3709 Hawthorne Dr Date 3/1/90 Signed by (Firm Official) Wayne S. Stevens and (Operator) Donald L. Stevens APR 4 1991 Work started 9/26/89 finished 2/11/90																																																																																																																																																																																			

USE ADDITIONAL SHEETS IF NECESSARY - FORWARD THE WHITE COPY TO THE DEPARTMENT

00726 1994

63-10862



Shown: wellhead &
flowmeter

OCT 26 1994

Form 235-1
3/89

Drilling Permit No. 63-89-W-171
Water Permit No. 63-10862 (Application for Permit)
Injection Permit No.

SEP 14 1989

State of Idaho
Department of Water Resources

DRILLING PERMIT

Department of Water Resources

1. Applicant Boise Water Corp.
2. Address P.O. Box 7488 Boise, Id 83701
Telephone 362-1300 or 362-2618
- ☒ Well Owner () Well Operator () Other, specify
3. Proposed well location NW 1/4 SE 1/4, or Gov't lot No. ,
Sec. 26, Twp. 3N, Rge. 2E, County Ada,
Lot, block and subdivision
4. Proposed use of well: (Check all that apply)
() Domestic () Stockwater () Monitoring
 No. of households No. of livestock
() Irrigation () Industrial (☒) Municipal 1.67 cfs
() Injection () Other, Specify
5. Well construction information:
☒ New well () Deepen () Replace
Proposed surface diameter 18" Maximum depth 700'
Anticipated bottom hole temperature:
☒ 85°F or less (Cold water well)
() 85°F to 212°F (Low temp. geothermal well)
() 212°F or more (Geothermal well)
6. Anticipated construction start date A.S.A.P.
7. Well Driller (if known) W.E. Stevens & Sons # 153
Address 3709 Hawthorne Dr. Boise 83703
8. Applicant's signature Daniel Braun
Title COMPANY ENGINEER DEC 26 1989
Date 9/13/89

ACTIC OF DEPARTMENT OF WATER RESOURCE

This Permit is Approved.

If approved, this permit authorizes the construction of a well subject to the following conditions:

GENERAL CONDITIONS

1. The well must be constructed in compliance with the applicable statutes, specific conditions of approval shown on the water right permit, injection well permit, transfer or amendment and the rules and regulations of the Department for water appropriation, injection wells and well construction standards.
2. This drilling permit is valid for two (2) months from its date of issuance for the start of construction and is valid for one (1) year from the date of issuance for completion of the well unless an extension has been granted.
3. This permit does not constitute the approval of the District Health Department or the Idaho Department of Health and Welfare which may be required before construction of this well.
4. The well shall be constructed by a driller currently licensed in the State of Idaho who must maintain a copy of the drilling permit at the drilling site.
5. Issuance of this drilling permit does not authorize trespass on the land of another party.
6. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.
7. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
8. If a bottom hole temperature of 85°F or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.

SPECIFIC CONDITIONS

Dated this 13th day of September, 1989.

Signed

D. R. Tittel

Title

Mgr, Western Region IDWR

Received by 7.11

Fee

\$100⁰⁰

Date

9-13-89

Receipt No. 0005912

Construction start extension to

Extension approved by

DEC 26 1991

December 12, 1991

BOISE WATER CORP.
P.O. BOX 7488
BOISE ID 83701

PROOF ACKNOWLEDGMENT LETTER

RE: PERMIT NO. 63-10862

Dear Permit Holder:

The department acknowledges receipt of the proof of beneficial use form submitted for the above referenced permit. The next step in the process of developing a water right is for the department to conduct a field examination to determine and confirm the use being made of the water.

If you have questions concerning this matter, please feel free to contact the WESTERN Regional Office in Boise at (208)334-2190.

Sincerely,

Karen L. Gustafson
Secretary/Records Manager

c: IDWR - Region

RECEIVED

DEC 26 1991

Form 204-p
6/82

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
COMMENCEMENT OF WORKS

Permit No. 63-10862

Name(s) of Permit Holder(s): BOISE WATER RECREATION

Post Office Address: P.O. BOX 7489

BOISE, IDAHO 83707 Phone No. 362-1300

☒ I hereby certify that construction of diversion works for the above referenced permit began on SEPT. 25, 1989 (date) FEB 15, 1990


continue to develop the water system with due diligence to maintain a valid permit.


☐ I hereby certify that construction of diverting works on the above referenced project has not yet begun due to the following reason beyond my control*:

*Note: A financing difficulty is not an acceptable reason.

1/26/90
Date

Benjamin M. Hepler
Signature of Permit Holder

BOISE W. R. C. 
P.O. BOX 7488
BOISE, IDAHO 83720



JAN 29 1990
STATEHOUSE
Department of Water Resources
BOISE, IDAHO 83720

MICROFILMED

FEB 26 1991

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

USE TYPEWRITER OR
BALLPOINT PEN

This law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER Stevens & Sons, Inc. 1000 N. 2nd St., Boise, Idaho 83702 Owner's Permit No. <u>64-89-W-171 (63-10862)</u>	7. WATER LEVEL Static water level <u>121</u> feet below land surface Flowing? ☒ Yes ☒ No G.P.M. flow _____ Artesian closed-in pressure _____ P.S.I. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature <u>69</u> F. Quality _____ <i>Describe artesian or temperature zones below</i>																																																																																																																																																																																		
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)	8. WELL TEST DATA ☒ Pump ☐ Bailor ☐ Air ☐ Other _____ <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Discharge G.P.M.</th> <th>Pumping Level</th> <th>Hours Pumped</th> </tr> <tr> <td>1200</td> <td>215</td> <td>12</td> </tr> </table>	Discharge G.P.M.	Pumping Level	Hours Pumped	1200	215	12																																																																																																																																																																												
Discharge G.P.M.	Pumping Level	Hours Pumped																																																																																																																																																																																	
1200	215	12																																																																																																																																																																																	
3. PROPOSED USE ☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type)	9. LITHOLOGIC LOG <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Bore Diam.</th> <th colspan="2">Depth</th> <th rowspan="2">Material</th> <th colspan="2">Water</th> </tr> <tr> <th>From</th> <th>To</th> <th>Yes</th> <th>No</th> </tr> </thead> <tbody> <tr><td></td><td>0</td><td>3</td><td>sandy brown clay topsoil</td><td></td><td>X</td></tr> <tr><td></td><td>3</td><td>60</td><td>sand, gravel & boulders</td><td></td><td>X</td></tr> <tr><td></td><td>60</td><td>145</td><td>streaks of blue, black & brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>145</td><td>185</td><td>sand, gravel, streaks of brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>185</td><td>195</td><td>brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>195</td><td>250</td><td>cemented sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>250</td><td>265</td><td>light brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>265</td><td>288</td><td>fine to medium sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>288</td><td>328</td><td>cemented sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>328</td><td>360</td><td>blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>360</td><td>365</td><td>cemented blue sand</td><td></td><td>X</td></tr> <tr><td></td><td>365</td><td>389</td><td>blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>389</td><td>396</td><td>fine to coarse muddy sand</td><td></td><td>X</td></tr> <tr><td></td><td>396</td><td>418</td><td>blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>418</td><td>426</td><td>streaks fine blue sand & blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>426</td><td>474</td><td>sticky blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>474</td><td>522</td><td>fine to medium blue sand</td><td></td><td>X</td></tr> <tr><td></td><td>522</td><td>530</td><td>blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>530</td><td>538</td><td>fine to medium blue sand</td><td></td><td>X</td></tr> <tr><td></td><td>538</td><td>555</td><td>blue clay</td><td></td><td>X</td></tr> <tr><td></td><td>555</td><td>565</td><td>hard dry brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>565</td><td>570</td><td>cemented sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>570</td><td>576</td><td>fine to coarse sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>576</td><td>582</td><td>brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>582</td><td>612</td><td>cemented sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>612</td><td>650</td><td>brown clay</td><td></td><td>X</td></tr> <tr><td></td><td>650</td><td>657</td><td>cemented sand & gravel</td><td></td><td>X</td></tr> <tr><td></td><td>657</td><td>663</td><td>brown clay</td><td></td><td>X</td></tr> </tbody> </table>	Bore Diam.	Depth		Material	Water		From	To	Yes	No		0	3	sandy brown clay topsoil		X		3	60	sand, gravel & boulders		X		60	145	streaks of blue, black & brown clay		X		145	185	sand, gravel, streaks of brown clay		X		185	195	brown clay		X		195	250	cemented sand & gravel		X		250	265	light brown clay		X		265	288	fine to medium sand & gravel		X		288	328	cemented sand & gravel		X		328	360	blue clay		X		360	365	cemented blue sand		X		365	389	blue clay		X		389	396	fine to coarse muddy sand		X		396	418	blue clay		X		418	426	streaks fine blue sand & blue clay		X		426	474	sticky blue clay		X		474	522	fine to medium blue sand		X		522	530	blue clay		X		530	538	fine to medium blue sand		X		538	555	blue clay		X		555	565	hard dry brown clay		X		565	570	cemented sand & gravel		X		570	576	fine to coarse sand & gravel		X		576	582	brown clay		X		582	612	cemented sand & gravel		X		612	650	brown clay		X		650	657	cemented sand & gravel		X		657	663	brown clay		X
Bore Diam.	Depth		Material	Water																																																																																																																																																																															
	From	To		Yes	No																																																																																																																																																																														
	0	3	sandy brown clay topsoil		X																																																																																																																																																																														
	3	60	sand, gravel & boulders		X																																																																																																																																																																														
	60	145	streaks of blue, black & brown clay		X																																																																																																																																																																														
	145	185	sand, gravel, streaks of brown clay		X																																																																																																																																																																														
	185	195	brown clay		X																																																																																																																																																																														
	195	250	cemented sand & gravel		X																																																																																																																																																																														
	250	265	light brown clay		X																																																																																																																																																																														
	265	288	fine to medium sand & gravel		X																																																																																																																																																																														
	288	328	cemented sand & gravel		X																																																																																																																																																																														
	328	360	blue clay		X																																																																																																																																																																														
	360	365	cemented blue sand		X																																																																																																																																																																														
	365	389	blue clay		X																																																																																																																																																																														
	389	396	fine to coarse muddy sand		X																																																																																																																																																																														
	396	418	blue clay		X																																																																																																																																																																														
	418	426	streaks fine blue sand & blue clay		X																																																																																																																																																																														
	426	474	sticky blue clay		X																																																																																																																																																																														
	474	522	fine to medium blue sand		X																																																																																																																																																																														
	522	530	blue clay		X																																																																																																																																																																														
	530	538	fine to medium blue sand		X																																																																																																																																																																														
	538	555	blue clay		X																																																																																																																																																																														
	555	565	hard dry brown clay		X																																																																																																																																																																														
	565	570	cemented sand & gravel		X																																																																																																																																																																														
	570	576	fine to coarse sand & gravel		X																																																																																																																																																																														
	576	582	brown clay		X																																																																																																																																																																														
	582	612	cemented sand & gravel		X																																																																																																																																																																														
	612	650	brown clay		X																																																																																																																																																																														
	650	657	cemented sand & gravel		X																																																																																																																																																																														
	657	663	brown clay		X																																																																																																																																																																														
4. METHOD DRILLED ☐ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary ☒ Cable ☐ Dug ☐ Other _____																																																																																																																																																																																			
5. WELL CONSTRUCTION Casing schedule ☒ Steel ☐ Concrete ☐ Other _____ <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Thickness</th> <th>Diameter</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>.250 inches</td> <td>20 inches</td> <td>0 feet</td> <td>70 1/2 feet</td> </tr> <tr> <td>.375 inches</td> <td>18 inches</td> <td>70 1/2 feet</td> <td>327 1/8 feet</td> </tr> <tr> <td>.250 inches</td> <td>10 inches</td> <td>327 1/8 feet</td> <td>_____ feet</td> </tr> </tbody> </table> Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☒ Yes ☐ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation _____ inches by _____ inches <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Number</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr> <tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr> <tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr> </tbody> </table> Well screen installed? ☒ Yes ☐ No Manufacturer's name <u>Johnson</u> Type <u>stainless steel</u> Model No. <u>304</u> Diameter <u>10</u> Slot size <u>30</u> Set from _____ feet to _____ feet Diameter <u>10</u> Slot size <u>30</u> Set from _____ feet to _____ feet Gravel packed? ☒ Yes ☐ No Size of gravel <u>8-12</u> sand Placed from <u>291</u> feet to <u>663</u> feet Surface seal depth <u>70</u> Material used in seal: ☐ Cement grout ☒ Bentonite ☐ Pudding clay ☐ _____ Sealing procedure used: ☒ Slurry pit ☐ Temp. surface casing ☐ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Describe access port _____	Thickness	Diameter	From	To	.250 inches	20 inches	0 feet	70 1/2 feet	.375 inches	18 inches	70 1/2 feet	327 1/8 feet	.250 inches	10 inches	327 1/8 feet	_____ feet	Number	From	To	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet																																																																																																																																																							
Thickness	Diameter	From	To																																																																																																																																																																																
.250 inches	20 inches	0 feet	70 1/2 feet																																																																																																																																																																																
.375 inches	18 inches	70 1/2 feet	327 1/8 feet																																																																																																																																																																																
.250 inches	10 inches	327 1/8 feet	_____ feet																																																																																																																																																																																
Number	From	To																																																																																																																																																																																	
_____ perforations	_____ feet	_____ feet																																																																																																																																																																																	
_____ perforations	_____ feet	_____ feet																																																																																																																																																																																	
_____ perforations	_____ feet	_____ feet																																																																																																																																																																																	
6. LOCATION OF WELL Sketch map location must agree with written location <u>BERGESON ST</u> Subdivision Name _____ Lot No. _____ Block No. _____ County <u>Ada</u> N/W S/E 26 3 (N/S, R. 2) E/W % Sec. _____ T. _____ R. _____	10. DRILLERS CERTIFICATION I/we certify that all minimum well construction standards were complied with at the time the rig was removed. Firm Name <u>Stevens & Sons</u> Firm No. <u>153</u> Address <u>3709 Hawthorne Dr</u> Date <u>3/1/90</u> Signed by (Firm Official) <u>Wayne E. Stevens</u> and (Operator) <u>Donald L. Stevens</u>																																																																																																																																																																																		

USE ADDITIONAL SHEETS IF NECESSARY - FORWARD THE WHITE COPY TO THE DEPARTMENT

DEC 26 1991

MEMORANDUM

TO: FILES 63-10862/11003 & 11034

FROM: PAM SKAGGS

RE: MISFILED LETTERS

DATE: 26-NOV-1991

=====

When these files were called up for proof due notices, it was found that the permit approval letters within the files were incorrectly filed and microfilmed. The permits were processed at the same period of time and the letters were placed in the wrong files. We assume a correct permit approval letter was sent with a copy of the approved permit to the applicant since there is no evidence that they were returned in error. Staff, however, should be aware of the error.

DEC 1 1991

138283

November 30, 1991

BOISE WATER CORP.
P.O. BOX 7488
BOISE ID 83701

PROOF DUE NOTICE

RE: PERMIT NO. 63-10862

Dear Permit Holder:

One of the conditions of approval of the above referenced water permit was that proof of the extent of your beneficial use must be submitted to this office on or before February 1, 1992. (See last page of your approved permit or your last approved extension request.) Enclosed is a form which when accompanied by the license examination fee or a complete field examination report prepared by a certified water right examiner may be used to submit the required proof.

If you have not fully completed your project, and you or a previous owner of this permit have not received a prior extension of time, you may request an extension of time if the delay is for reasonable cause as provided in Section 42-204, Idaho Code. If you have been prevented from proceeding by a governmental agency or by litigation which might bring title to the water in question, more than one extension of time can be granted. An extension of time request form is enclosed for your convenience.

Either an acceptable proof of beneficial use submittal or an acceptable request for an extension of time must be received by this department on or before the above described proof due date. If neither is received, the department will send you a lapse notice. Within sixty (60) days of the mailing of the lapse notice, the permit will no longer be of any force nor effect.

SINCERELY,

Karen L. Gustafson
Secretary/Records Manager

Enclosures

DEC 26 1991

S T A T E O F I D A H O
D E P A R T M E N T O F W A T E R R E S O U R C E S

Statehouse
Boise, Idaho 83720
(208) 327-7900
January 24, 1990

CLEMENTS CONCRETE CO.
P.O. BOX 8124
BOISE, ID 83707

P E R M I T A P P R O V A L N O T I C E

RE: PERMIT NO. P63-11003

Dear Permit Holder:

Enclosed is a copy of your approved application for permit. We direct your attention to the conditions of approval on the final page.

You should be aware that the groundwater you propose to divert is located within a drainage basin where surface waters are regulated during the months of low flow. It is possible that diversion of groundwater may have an adverse impact on these surface water flows. Information available to us at this time does not warrant refusing to issue permits in your area, but we do caution that diversions of groundwater are not allowed to deplete flows available for surface water users with earlier priority dates. Siting your well as far from surface sources as possible and casing out upper water producing zones may reduce the potential of interference.

Section 42-235, Idaho Code, requires that a "drilling permit" must be obtained from the department for all wells constructed after July 1, 1987. A drilling permit is a separate permit that must be issued in addition to your permit to appropriate water. Commencement of well construction or diversion of water under your permit to appropriate water is prohibited unless a drilling permit is obtained.

Please note the requirement that as a permit holder you must commence the excavation or construction of diverting works within one year of the date the permit was issued, and you must proceed diligently until the project is completed. The enclosed blue card must be completed and returned to this office as soon as you commence construction, no later than one year from the date the permit was approved.

MICROFILMED

FEB 26 1990

We have enclosed a form entitled "Instructions for Proof of Beneficial Use". Please read the instructions carefully since you must take further action to develop this permit into a license.

Sincerely,

GARY SPACKMAN, Supervisor
Water Right Permits Section

GS: SC
Enclosures

MICROFILMED

FEB 26 1990



STATE OF IDAHO

DEPARTMENT OF HEALTH
AND WELFARE

DIVISION OF ENVIRONMENTAL QUALITY

BOISE FIELD OFFICE
801 Reserve Street
Boise, Idaho 83712
(208) 334-3823

August 21, 1989

RECEIVED
AUG 23 1989

Department of Water Resources
Western Regional Office

Mr. David R. Tuthill
Western Region Supervisor
Department of Water Resources
Statehouse Mail
Boise, Idaho 83720

Re: 63-10862 (Boise Water Corporation)

Dear Mr. Tuthill:

This office has reviewed the above referenced application
and has no objections to this appropriation.

Sincerely,

A handwritten signature in black ink, appearing to read "Jon Wroten".

Jon Wroten
Water Quality Compliance Officer

JW:ae

cc: Craig Shepard, DEQ-BFO
Susan Martin, DEQ-BFO

MICROFILMED

FEB 26 1990



State of Idaho
DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705 - (208) 334-2190

CECIL D. ANDRUS

GOVERNOR

R. KEITH HIGGINSON

DIRECTOR

August 15, 1989

Idaho Dept. of Health & Welfare
Division of Environment
Statehouse
Boise, ID 83720

Re: Application for Permit No. 63-10862 in the name of Boise Water Corp.

Dear Sir:

Enclosed is a copy(s) of the above-referenced application(s) for permit which may be of interest to your agency. Please review the application(s) and submit any comments you may have.

This office normally completes the processing of an application within a six-week period and is required to take final action shortly thereafter, however, if your agency desires to file a formal protest against the approval of this application(s), your written protest must be received in this office by September 5, 1989.

If you have any questions regarding the application, please contact this office.

Sincerely,

for DAVID R. TUTHILL, JR., P. E.
Manager, Western Regional Office

DRT:st

Enclosure(s):

MICROFILMED

FEB 26 1990

CONVERSATION MEMORANDUM

DATE 7/21/89

FILE _____

NAME OF PARTY Boise Water Corp.EMPLOYEE Stan Laster

RE: I called Dan Brown (362-2618), Engineer for
Corp. Anticipate to drill a production well $\approx$ 700' deep for
cold water. Discussed issue of hitting hot water when drilling
actually occurs. Told him that S.O. will probably handle
the monitoring of drilling conditions to be associated with
well construction.

at this time, we can process's advertise the
application for cold water > 300' within Boise Front
gwna.

Officer names/titles (addresses c/o B.W. Corp.)
from Permit 63-10688 file:

<u>Pres-</u>	<u>Wayne L. Booe</u>
<u>V.P. & manager</u>	<u>Benjamin M. Hepler</u>

MICROFILMED

FEB 26 1990

AUG 28 1989

P.O. BOX 40, BOISE, IDAHO 83707

AL ADVERTISING INVO.

Department of Water Resources
Western Regional Office

Amount Due

201.72

Account Name		Account Number	
State of Idaho - Department of Water Resources		#4	
Address		City/State	
2735 Airport Way		Boise, ID	
Ordered By	P.O. Number	Rate	Run Dates
Gail Garrett		n t	August
Identification		Estimated Inc	
Notice of Applications for Water Rights			

Number of Affidavits Requested

NOTICE OF APPLICATION FOR WATER RIGHT

The following application(s) have been filed to appropriate the public waters of the State of Idaho:

63-10817
REYNOLDS, ARLIE
7685 VALLEY JO
BOISE, ID 83709
Source: Groundwater
Diversion Pt: NWSE Sec 12 T
02N R 01E
Use: Irrigation (.140 CFS)
Use: Domestic (.020 CFS)
Date Filed: 6/19/1989
In: T02N R01E S12 NWSE
7.0 ACRES TOTAL

63-10823
KAYLOR, RICHARD L.
KAYLOR, GLORIA J.
3877 GEMINI CIR.
BOISE, ID 83709
Source: Groundwater
Diversion Pt: NWSE Sec 26 T
03N R 01E
Use: Irrigation (.020 CFS)
Use: Domestic (.020 CFS)
Date Filed: 6/21/1989
In: T03N R01E S26 NWSE
1.0 ACRES TOTAL

63-10838
WALTERS, JIM E.
WALTERS, MARY L.
11401 COLUMBIA RD.
BOISE, ID 83709
Source: Groundwater
Diversion Pt: NWNE Sec 10 T
02N R 01E
Use: Irrigation (.040 CFS)
Date Filed: 6/30/1989
In: T02N R01E S10 NWNE
2.0 ACRES TOTAL

63-10856
THOMPSON, RALPH A.
P.O. BOX 5243
BOISE, ID 83705
Source: Groundwater
Diversion Pt: SWNE Sec 12 T
02N R 01E
Use: Irrigation (.100 CFS)
Use: Commercial (.020 CFS)
Date Filed: 7/18/1989
In: T02N R01E S12 SWNE
5.0 ACRES TOTAL

63-10857
TUCKER, MYRON
6600 HILL RD.
BOISE, ID 83703
Source: Groundwater
Diversion Pt: Lot 4 (SWSW)
Sec 19 T 04N R 02E
Use: Commercial (.050 CFS)
Use: Irrigation (.020 CFS)
Date Filed: 7/19/1989
In: T04N R02E S19 Lot 4 (SWSW)
0.5 ACRES TOTAL

63-10858
HUFF, PHIL T.
HUFF, NANCY
3502 BROOKSIDE
BOISE, ID 83703
Source: Groundwater
Diversion Pt: SESE Sec 34 T
05N R 01E
Use: Irrigation (.090 CFS)
Date Filed: 7/19/1989
In: T05N R01E S34 SESE
3.0 ACRES TOTAL

63-10860
FIREBIRD RACEWAY, INC.

BOX 7235
BOISE, ID 83707
Source: Groundwater
Diversion Pt: NWSW Sec 16
05N R 01W
Use: Irrigation (.060 CFS)
Use: Commercial (.300 CFS)
Use: Domestic (.040 CFS)
Date Filed: 7/25/1989
In: T05N R01W S16 NESW
NWSW SWSW SESE
2.0 ACRES TOTAL

Debbie Richards

sworn, deposes and says: That she is the P
Idaho Statesman, a daily newspaper printed
Ada County, State of Idaho, and having a ge
and which said newspaper has been continu
published in said County during a period of
months prior to the first publication of the
attached hereto; that said notice was publis
Statesman in conformity with Section 60-10
amended, for 2

☒ consecutive weekly ☐ consecutive daily

insertion(s) beginning with the issue of

and ending with the issue of

STATE OF IDAHO)

COUNTY OF ADA)

On this 24th day of August
1989, before me, a Notary P

Debbie Richards
to me to be the person whose name su
strument, and being by me first duly
statements therein are true, and ackno
executed the same.

Notary Public for Idaho
Residing at Boise, I
My commission expires:

MICROFILMED

FEB 26 1990

63-10861
LYNN, MARK
LYNN, M. JOY
4831 SKYLINE
EAGLE, ID 83616
Source: Groundwater
Diversion Pt: SESW Sec 30 T
05N R 01E
Use: Irrigation (.150 CFS)
Use: Fire Protection (.150 CFS)
Date Filed: 7/26/1989
In: T05N R01E S30 NESW
SESW NWSE SWSE
5.0 ACRES TOTAL

63-10862
BOISE WATER CORP.
P.O. BOX 7488
BOISE, ID 83701
Source: Groundwater
Diversion Pt: NWSE Sec 26 T
03N R 02E
Use: Municipal (1.670 CFS)
Date Filed: 7/18/1989

63-10866
EVERETT, KENNETH
EVERETT, PAULA
7920 STACK ROCK RD.
BOISE, ID 83703
Source: Groundwater
Diversion Pt: NWNE Sec 25 T
05N R 01E
Use: Irrigation (.150 CFS)
Date Filed: 7/27/1989
In: T05N R01E S24 SWSE
In: T05N R01E S25 NWNE
5.0 ACRES TOTAL

63-10870
DORAMUS, DAN A.
DORAMUS, DEANA R.
2126 BRYSON SUB.
BOISE, ID 83704
Source: Groundwater
Diversion Pt: NESW Sec 3 T
03N R 01E
Use: Irrigation (.020 CFS)
Date Filed: 7/28/1989
In: T03N R01E S03 NESW
0.5 ACRES TOTAL

63-10872
JAMES FAMILY LTD.
PART -NERSHIP
4675 N. TEN MILE RD.
MERIDIAN, ID 83642
Source: Groundwater
Diversion Pt: NESE Sec 27 T
04N R 01W
Diversion Pt: NENE Sec 34 T
04N R 01W
Use: Irrigation (2.400 CFS)
Date Filed: 8/01/1989
In: T04N R01W S28 SESE
In: T04N R01W S34 NENW
NWNW
120.0 ACRES TOTAL

63-10876
BARRETT, JOHN W.
BARRETT, MARILYN J.
10918 CRUSER DR.
BOISE, ID 83709
Source: Groundwater
Diversion Pt: NENE Sec 15 T
03N R 01E
Use: Irrigation (.040 CFS)
Use: Stockwater (.020 CFS)
Date Filed: 8/07/1989
In: T03N R01E S15 NENE
1.5 ACRES TOTAL

63-10885
TOMKINSON, STEVEN D.
TOMKINSON, DIANNE
1739 CHAROLAIS DR.
MERIDIAN, ID 83642
Source: Groundwater
Diversion Pt: NWSWNW Sec
20 T 03N R 01E
Use: Irrigation (.030 CFS)
Date Filed: 7/07/1989
In: T03N R01E S20 SWNW
1.0 ACRES TOTAL

63-10887
BUDELL, JUANITA L.
2490 W. FRANKLIN RD.
MERIDIAN, ID 83642
Source: Groundwater
Diversion Pt: SESW Sec 11 T
03N R 01W
Use: Irrigation (.060 CFS)
Use: Stockwater (.020 CFS)
Use: Domestic (.040 CFS)
Date Filed: 7/18/1989
In: T03N R01W S11 SESE
2.0 ACRES TOTAL

The permit(s) will be subject to
all prior water rights. Protests
must be filed with the Director,
Dept. of Water Resources, West-
ern Region, 2735 Airport Way,
Boise, Idaho 83705 on or before
SEPTEMBER 5, 1989.

R. KEITH HIGGINSON
Director
Pub. Aug. 17, 24, 1989

3379

63-10862

BOISE WATER CORP.
P.O. BOX 7488
BOISE, ID 83701

Source: GROUNDWATER

Diversion Pt: NWSE Sec 26 T 03N R 02E

Use: MUNICIPAL (1.670 CFS)

Date Filed: 7/18/1989

RECORDED

FEB 26 1990