

Printed 07/07/2003
Drilling Permit No. 804401
Well Tag No. D0023806
Well ID # 375284
Water Right No.
Receipt #
Approved Date

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
DRILLING PERMIT**

Relationship: Owner/Operator
Name: GLANBIA FOOD INC
Address: 1373 FILLMORE ST
TWIN FALLS ID 83301

Phone: (208)733-7555

Proposed Well Location: Township 04S, Range 20E, Section 18, NE, NW, NE
COUNTY LINCOLN

Street Address of Well Site: 3 M NE OF RICHFIELD
RICHFIELD ID

Proposed Use of Well: Test

Well Construction Information:

- A. New Well
- B. Proposed Surface Diameter: 16 Inches. Proposed Depth 800 Feet.
- C. Anticipated Bottom Hole Temperature: 85F and less

Construction Start Date: Jul 07 2003

Anticipated Well Drilling Company: EATON DRILLING & PUMP SERVICE INC (No. 26)

Applicant's Signature: _____ Date _____

Title: _____


Well ID # 375284


Well Tag No. D0023806

ACTION OF THE DEPARTMENT OF WATER RESOURCES

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. **READ CAREFULLY!**

1. This drilling permit is valid for two (2) months from the approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the local Health District or the Idaho Department of Environmental Quality which may be required prior to construction of this well. The local Health District should be contacted for septic tank/drainfield locations. Domestic wells must not be drilled closer than 100 ft. from any drainfield and 50 ft. from any septic tank. Public Water Supply wells must not be drilled closer than 100 ft. from any drainfield or septic tank.
3. The well shall be constructed by a driller currently licensed in the state of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals that may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
7. If a bottom hole temperature of 85 Degrees F (29.44 oC) or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department of Water Resources immediately.
8. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or its contractors to contact "Dig-line" (Dig-Line is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "Dig-Line " Number for this location is 1-800-342-1585
9. Please be advised that this drilling permit should be considered and treated as a preliminary permit. If you are in disagreement with this preliminary permit you have fourteen (14) days of the service date of this permit to petition the Idaho Department of Water Resources for reconsideration, pursuant to Section 67-5243, Idaho Code.
10. The well tag for the drilling permit/start card shall be securely and permanently attached to the well casing through welding or by the use of four closed end domed stainless steel pop rivets. The tag attachment will be done at the time of completion of the well, and prior to removing the drill rig from the drill site.
11. This Drilling Permit is issued for a test well only. Diversion of water from this well is not authorized except for a well test not to exceed 24 hrs. No permanent casing shall be installed. Upon aquisition of necessary data, all casing shall be removed and the hole abandoned by an approved method and seal material. This approval shall be done through the use of an application for abandonment. Water obtained from the test shall be disposed of in a manner which does not adversely effect other individuals, this or another resource.


Signature of Authorized Dept. Representative


Title