


Complete the following map by showing land and point of diversion as proposed by this amendment. Show 40 acre subdivisions, sections, townships, ranges, and ditches.

T. 2 T. 3 N. R. 38 E.B.M.



Scale: 2 inches equal 1 mile

That no one will be injured by such change, and that such change will be made at permit holder's own risk.

Signed at Ucon, Idaho, this 22 nd day of October, 1971.

By:

CITY OF UCON

MAYOR

(signature)

ACTION OF STATE RECLAMATION ENGINEER


I, R. KEITH HIGGINSON, Director of the Dept. of Water Administration, State Reclamation Engineer of the State of Idaho, hereby APPROVE application for amendment for Permit No. 25-7007

Witness my hand this 12th day of November, 19 71

State Reclamation Engineer

T3N R38E

11. Map of proposed project:



Scale: 2 inches equal 1 mile

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

Bud S. Shupp
(Applicant) Mayor

at to sign
D

25 7007

RECEIVED
APR 17 1970
Department of Reclamation

Proof of Publication The Post-Register

State of Idaho, }
County of Bonneville } ss.

I, E. F. McDermott, first being duly sworn, depose and say: That I am the Principal Clerk of The Post Company, a corporation of Idaho Falls, Bonneville County, Idaho, publishers of The Post-Register, a newspaper of general circulation, published daily, except Saturday, at Idaho Falls, Idaho; said Post-Register being a consolidation of the Idaho Falls Times, established in the year 1890, The Idaho Register, established in the year 1880 and the Idaho Falls Post, established in 1903, such consolidation being made on the 1st day of November, 1931, and each of said newspapers having been published continuously and uninterruptedly, prior to consolidation, for more than seventy-eighty (78) weeks and said Post-Register having been published continuously and uninterruptedly from the date of such consolidation, up to and including the last publication of notice hereinafter referred to.

That the notice, of which a copy is hereto attached and made a part of this affidavit, was published in said Post-Register for two consecutive weeks, first publication having been made on the 2nd day of April, 1970, last publication having been made on the 9th day of April, 1970, and that the said notice was published in the regular and entire issue of said paper on the respective dates of publication, and that such notice was published in the newspaper and not in a supplement.

Subscribed and sworn to before me, this 10th day of April, 1970

Karl Schuler
Notary Public

My commission expires April 5, 1971

B10, 1M

NOTICE OF APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF IDAHO
Notice is hereby given that the City of Ucon, P.O. Box 12, Ucon, Idaho, has on March 13, 1970 submitted Application No. 25-7007 to appropriate the public waters of a groundwater source.
The application proposes a maximum diversion and appropriation of 3.0 cubic feet per second of water to be diverted by well and pump within the SE $\frac{1}{4}$ NE $\frac{1}{4}$ of Sec. 14, T. 3N, R. 48E, B.M., Bonneville County, and is to be used within the City of Ucon for municipal purposes from Jan. 1 to Dec. 31.
Any permit issued pursuant to this application will be subject to ALL PRIOR WATER RIGHTS and subject to the CONTROL OF A STATE WATERMASTER. Any protest against this application must be filed with the Idaho Department of Reclamation on or before April 20, 1970.
R. KEITH HIGGINSON
State Reclamation Engineer
Pub: Apr 2, 9, 1970

25 7007

TWP. 3N RANGE 38E COUNTY Bonneville SCALE: 1" = 1 MILE

LEGEND


● - APPLICANT'S WELLS

● - IRRIGATION

● - DOMESTIC

DEPTH
DTW
GPM
O.D.

● - Municipal



Rye 38E






Diagram of System



1000 gals PRESSURE TANK.
(38-58 psi).



WATER RIGHT LICENSE

THIS IS TO CERTIFY, that CITY OF UCON

Beneficial Use	Period of Use	Rate of Diversion	Annual Volume
Municipal	from Jan 1 to Dec 31	at .48 cfs and	
	from to at	cfs and	
	from to at	cfs and	

(both dates inclusive)

Subject, however, to the condition that no more than .48CFS of water be diverted at any one time, and that the amount of water so diverted and to which such right is entitled and confirmed is for the purpose aforementioned and is limited to the amount which can actually be beneficially used and shall not exceed _____ acre feet per-year, said waters to be diverted within the SENE Sec. 14, Twp. 3N,
Rge 38E, B.M. _____ in the County of Bonneville

Description and location of place of use:

[illegible]

Total number of acres irrigated _____

NOTE: Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho Law. This right may be forfeited by five years of non-use.

The right to the use of the water hereby confirmed is restricted and appurtenant to the lands or place of use herein described, as provided by the laws of Idaho.

Witness the seal and signature of the Director, affixed at Boise, Idaho, this 27 day of February 19 81

Director

MICROFILMED

DET new

BEFORE THE DEPARTMENT OF WATER RESOURCES
OF THE
STATE OF IDAHO

IN THE MATTER OF PERMIT NO. 25-7007

IN THE NAME OF THE CITY OF UCON

ORDER OF REINSTATEMENT

WHEREAS, on March 13, 1970, the City of Ucon filed with the Department of Water Resources (formerly the Department of Water Administration) an application for permit to appropriate 3.00 cubic feet per second of groundwater to be diverted within the SE $\frac{1}{4}$ NE $\frac{1}{4}$, Sec. 14, Twp. 3N, Rge. 38E, B.M., Bonneville County, to be used for municipal purposes; and,

WHEREAS, on September, 1971, the Department approved said application and issued Permit No. 25-7007 with the condition that proof of construction of works and application of water to beneficial use be submitted to the Department on or before September 1, 1976; and,

WHEREAS, on June 30, 1976, the Department notified the permit holder by certified mail that proof of beneficial use was due and instructed the permit holder as to the steps to be taken to make said proof; and,

WHEREAS, on September 10, 1976, the Department notified the permit holder that Permit No. 25-7007 had lapsed for failure to submit proof of beneficial use of water; and,


WHEREAS, on November 9, 1976, the Department received the required proof of beneficial use of water; and,

WHEREAS, Section 42-218a of the Idaho Code provides that a permit may be reinstated upon a showing of reasonable cause within 60 days from the date of the notice of lapsing; and,

WHEREAS, the permit holder has provided a reasonable showing as to why said permit should be reinstated;

IT IS, THEREFORE, HEREBY ORDERED that Permit No. 25-7007 be REINSTATED and the priority advanced to May 21, 1970.

Dated this 17 day of November, 1976.


A. KENNETH DUNN
Administrator, Operations Division

RECEIVED

RECEIVED

Feb. 21/80
Received 10-27-71
OCT 26 1971 Receipt # 2235

REG

Department of Water Administration
Eastern District Office

STATE OF IDAHO
DEPARTMENT OF WATER ADMINISTRATION

Department of Water Administration

APPLICATION FOR AMENDMENT

APPROVED

Permit No. 25-7007

Comes now Bud L. Strupp, Mayor, for the CITY OF UCON of (address)

P. O. BOX 12 UCON, IDAHO 83454, and represents to the State Reclamation
Engineer of the State of Idaho:

THE CITY OF UCON

That ~~he~~ is the owner and holder of Permit to Appropriate the Public Waters of the State of Idaho
No. 25-7007, and requests that the permit and permit map be changed as follows:

1. Point of diversion: SE 1/4 NE 1/4, Sec. 14, T. 3 North
R. 38 E, B.M. Other points of diversion

2. Period and nature of use: (irrigation, domestic, stockwatering, industrial, etc.)

Jan. 1 mo. - day Dec. 31 mo. - day

For MUNICIPAL purposes from Jan. 1 to Dec. 31 (both dates incl.)

For purposes from to (both dates incl.)

For purposes from to (both dates incl.)

For purposes from to (both dates incl.)

3. Place of use or land to be irrigated:


TWP.	RANGE	SEC.	NE 1/4				NW 1/4				SW 1/4				SE 1/4				TOTALS
			NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	
3 N	38 E	10																X	
3 N	38 E	11											X					X	
3 N	38 E	12											X						
3 N	38 E	13						X	X			X							
3 N	38 E	14	X	X	X	X	X	X	X	X	X	X			X	X			
3 N	38 E	15	X			X									X				

Total number of acres to be irrigated

25 7007

25 7007

Complete the following map by showing land and point of diversion as proposed by this amendment. Show 40 acre subdivisions, sections, townships, ranges, and ditches.
T. 2 T. 3 N. R. 38 E.B.M.



Scale: 2 inches equal 1 mile

That no one will be injured by such change, and that such change will be made at permit holder's own risk.

Signed at Ucon, Idaho, this 22 nd day of October, 1971.

By: CITY OF UCON
[Signature]
MAYOR (signature)

ACTION OF STATE RECLAMATION ENGINEER

I, R. KEITH HIGGINSON, Director of the Dept. of Water Administration, State Reclamation Engineer of the State of Idaho, hereby APPROVE application for amendment for Permit No. 25-7007

Witness my hand this 12th day of November, 19 71

[Signature]
State Reclamation Engineer

Identification No. 25-7007
Application No. _____

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
APPLICATION FOR PERMIT

APPROVED

To Appropriate the Public Waters of the State of Idaho
(TYPE OR PRINT IN INK)

Bud L. Strupp.
523-4464

1. Name of applicant CITY OF UCON
post office address P. O. BOX 12 UCON, BONNEVILLE COUNTY, IDAHO
2. Source of water supply DEEP WELL which is a tributary of _____
3. a. Location of point of diversion is SE $\frac{1}{4}$ of NE $\frac{1}{4}$ of Section 14 Township 3 North
Range 38 E B.M. BONNEVILLE County; additional points of diversion if any: _____

- b. If water is not consumed, it will be discharged into _____ at a point in _____ $\frac{1}{4}$
of _____ $\frac{1}{4}$ of Section _____ Township _____ Range _____ B.M. _____
4. Water will be used for the following purposes:
Amount 3 for Municipal supply purpose from Jan 1 to Dec. 31 (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purpose from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purpose from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
5. Total quantity to be appropriated:
a. Three (3) cubic feet per second and/or
b. _____ acre feet per annum.
6. Proposed diverting works:
a. Description of ditches, flumes, pumps, headgates, etc. Pump

b. Height of storage dam _____ feet, active reservoir capacity _____ acre feet; total reservoir
capacity _____ acre feet, materials used in storage dam: _____
Period of year during which storage will occur _____ to _____ inclusive.
(Mo. Day) (Mo. Day)
c. Proposed well diameter is 16" inches; proposed depth of well is 210 feet.
7. a. Time required for the completion of the works and application of the water to the proposed beneficial use
is 5 years.
b. Estimated construction cost is \$ 10,000.00.
8. Description of proposed uses:
a. If water is **not** for irrigation: Serve the City of Ucon, Idaho Municipal use.
(1) Give the place of use of water: SE $\frac{1}{4}$ of NE $\frac{1}{4}$ of Section 14 Township 3 North
Range 38 B.M.
(2) Amount of power to be generated: _____ hp under _____ feet of head.
(3) List number of each kind of livestock to be watered _____

(4) Name of municipality to be served Ucon, Idaho, or number of families to be
supplied with domestic water _____
(5) If water is to be used for other purposes describe: _____

25 7007

25 7007

b. If water is for irrigation, indicate acreage in each subdivision in the tabulation below:

[illegible]

Total number of acres to be irrigated_____


c. Describe any other water rights used for the same purposes_____

9. a. Who owns the property at the point of diversion City
b. Who owns the land to be irrigated or place of use City
c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing _____

10. Remarks This well will be drilled by Jack Cushman Drilling- Blackfoot, Idaho
Drilling to commence some time in April 1970

T3N R38E

11. Map of proposed project:



Scale: 2 inches equal 1 mile

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

Bud P. Shupp
(Applicant) Mayor *ck to sign*
D

25 7007

Received by jh Date 3-13-70 Time 8:00 am
Preliminary check by Duffy Fee \$ 30⁰⁰
Receipted by 21 Date 3-16-70
Publication prepared by de Date 3-25-70
Published in Post Register
Publication dates 4-2+9-70
Publication approved de Date 4-21-70
Priority reduced to _____ Reason _____

25 7007

Protests filed by: _____
Copies of protests forwarded by _____
Hearing held by _____ Date _____
Recommended for approval denial by DE DEF OK

ACTION OF STATE RECLAMATION ENGINEER

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. 25-7007, and said application is hereby APPROVED.

1. Approval of said application is subject to the following limitations and conditions:

- a. SUBJECT TO ALL PRIOR WATER RIGHTS.
- b. Proof of construction of works and application of water to beneficial use shall be submitted on or before September 1, 19 76.
- c. Other: The permit holder shall permanently install and maintain as part of the diverting works a measuring device at the point of diversion of a type approved by this Department.

2. Denial of said application is for the following reasons: _____

Witness my hand this 23 day of September 19 71.

R. Kind
Director State Reclamation Engineer

DEPARTMENT OF RECLAMATION

STAFF ANALYSIS

Application No. 25-7007 Name City of Ucon

Source groundwater

Point of Diversion SE 1/4 NE 1/4, Sec. 14, T. 3N, R. 38E, B.M., Bonneville County

Quantity 3.0 Use municipal Period Jan. 1 - Dec. 31

Quantity Use Period

Quantity Use Period

Well Size Diameter Proposed Depth Feet

Use serve the City of Ucon

Date Forwarded 3-16-70 Date Returned 3-17-70 Received by D.H.

RECOMMENDATIONS: Measuring device

Qty. Use Period AF AFA

Qty. Use Period AF AFA

Qty. Use Period AF AFA

ACTION: Approved ☒ Denied ☐

Conditions of approval or reason for denial:

ENGINEERING By A.H. Quinn Title 3-17-70

Date A.H. Quinn

STATE OF IDAHO

Department of Reclamation

Nº 4316

Boise, Idaho, Mar 16, 19 70

RECEIVED
FROM

City of Umond
Thirty & no 100

\$ 30⁰⁰

DOLLARS

FOR

App for
per

\$ 30 00

\$

\$

\$

TOTAL - - -

\$ 30 00

25 7007

E. J. Woods
STATE RECLAMATION DEPARTMENT

DEPARTMENT OF RECLAMATION

STAFF ANALYSIS

Application No. 25-7007 Name City of Ucon

Source groundwater

Point of Diversion SE 1/4, Sec. 14, T. 3N, R. 38E, B.M., Bonneville County

Quantity 3.0 Use municipal Period Jan. 1 - Dec. 31

Quantity _____ Use _____ Period _____

Quantity _____ Use _____ Period _____

Well Size _____ Diameter _____ Proposed Depth _____ Feet

Use serve the City of Ucon

Date Forwarded 3-23-70 Date Returned 4-3-70 Received by Shur

RECOMMENDATIONS: WATER TABLE IS STABLE IN
NEAREST OBSERVATION WELL (10 miles East)
(Bulletin # 11). Within the Upper Snake River
IRRIGATION project, Assoc. of Idaho Cities lists
population as 520. Assuming 4 persons/family,
130 families inhabit Ucon. At 0.02 cfs/family the
MAXIMUM diversion would be 2.6 cfs. Existing well listed
@ 5 cfs in drillers logs. City should justify additional diversion.

Qty. _____ Use _____ Period _____ AF _____ AFA _____

Qty. _____ Use _____ Period _____ AF _____ AFA _____

Qty. _____ Use _____ Period _____ AF _____ AFA _____

ACTION: Approved ☒ Denied _____

Conditions of approval or reason for denial: Approval should be
allowed only after satisfactory justification
FOR ADDITIONAL DIVERSION. Require MEASURING
DEVICES AND MINIMUM well SPACING OF 500 ft.

INVESTIGATION By Norman C. Young Title WRI II
Date April 3, 1970

25 7007


RECEIVED
APR 19 1970
Department of Reclamation


Proof of Publication
The Post-Register

State of Idaho, }
County of Bonneville } ss.

I, E. F. McDermott, first being duly sworn, depose and say: That I am the Principal Clerk of The Post Company, a corporation of Idaho Falls, Bonneville County, Idaho, publishers of The Post-Register, a newspaper of general circulation, published daily, except Saturday, at Idaho Falls, Idaho; said Post-Register being a consolidation of the Idaho Falls Times, established in the year 1890; The Idaho Register, established in the year 1880 and the Idaho Falls Post, established in 1903, such consolidation being made on the 1st day of November, 1931, and each of said newspapers having been published continuously and uninterruptedly, prior to consolidation, for more than seventy-eighty (78) weeks and said Post-Register having been published continuously and uninterruptedly from the date of such consolidation, up to and including the last publication of notice hereinafter referred to.

That the notice, of which a copy is hereto attached and made a part of this affidavit, was published in said Post-Register for two consecutive weeks, first publication having been made on the 2nd day of April, 1970, last publication having been made on the 9th day of April, 1970, and that the said notice was published in the regular and entire issue of said paper on the respective dates of publication, and that such notice was published in the newspaper and not in a supplement.


Subscribed and sworn to before me, this 10th day of April, 1970


Notary Public

My commission expires April 5, 1971

B10, 1M

NOTICE OF APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF IDAHO
Notice is hereby given that the City of Ucon, P.O. Box 12, Ucon, Idaho, has on March 13, 1970 submitted Application No. 25-7007 to appropriate the public waters of a groundwater source.
The application proposes a maximum diversion and appropriation of 3.0 cubic feet per second of water to be diverted by well and pump within the SE 1/4 NE 1/4 of Section 14, T. 24 N., R. 38 E., B.M., Bonneville County, Idaho, and is to be used within the City of Ucon for municipal purposes from Jan. 1 to Dec. 31.
Any permit issued pursuant to this application will be subject to ALL PRIOR WATER RIGHTS and subject to the CONTROL OF THE STATE WATERMASTER. Any proposed permit application must be filed with the Department of Reclamation on or before April 20, 1970.
R. H. HILGEMAN
State Reclamation Engineer
Pub: Apr 2, 9, 1970

25 7007

TWP. 3N RANGE 38E COUNTY Bonneville SCALE: 1" = 1 MILE

LEGEND


● - APPLICANTS WRECK

○ - IRRIGATION

● - DOMESTIC

DEPTH
OTW
GPM
O.D.

○ - MURDER



02 WATER RIGHT NUMBER 25-7007

OWNER LAST NAME - CITY OF UCON

ADDRESS LINE 1 - P.O. BOX 98

ADDRESS LINE 2 -

SOURCE - GROUNDWATER

SIAGE - LICENSE

TOTAL DIV. VOLUME -

DIVERSTON POINT - SEWE 14 03N 38E LOT

FROM - 01-01 TO - 12-31 USE - MUNICIPAL

USE -

DECREE NAME -

REMARKS - P/U WITHIN CITY LIMITS OF UCON.

NON IRRIG USE -

OTHER RIGHTS FOR SAME USE -

PROOF DUE - 09-01-1976 PERMIT/DENIED - 09-23-1971 PROTESTED -

PROOF MADE - P FLD EXAM - F COND. OF APPROVAL -

DIVERSION MEANS - PUMP.

FIRST NAME -

ADDRESS LINE 2 -

CITY - UCON

TRIBUTARY OF -

PRIORITY - 05-21-1970 COUNTY - BONNEVILLE TOTAL DIV. RATE - .4800 -CFS

WATER DIST. - DLE/CAREY ACT - RIGHT BASIS -

REDIV - 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0

USE DIV. RATE - .4800 CFS USE DIV. VOLUME - .00 AFA

PLACE OF USE - TWN RNG SEC

DATE -

TOTAL ACRES 0

HEARING -

OLD NO. -

[illegible]



State of Idaho

DEPARTMENT OF WATER RESOURCES

STATE OFFICE, 450 W. State Street, Boise, Idaho

JOHN V. EVANS
Governor

C. STEPHEN ALLRED
Director

Mailing address:
Statehouse
Boise, Idaho 83720
(208) 334-4440

March 6, 1981

City of Ucon
Box 98
Ucon, Id 83454

Dear Sirs,

RE: License No. 25-7007

Enclosed is a copy of the Water Right License issued on the above referenced Permit.

Please be advised that one of the conditions of your permit was that a measuring device be installed as part of your diversion works. That requirement has been waived with issuance of the enclosed license. However, in the event that water supply shortages become a problem installation of measuring devices may be required.

Sincerely,

JIM JOHNSON
Water Distribution Supervisor

JJ:mr
Enclosure

MICROFILMED



State of Idaho
DEPARTMENT OF WATER RESOURCES
STATE OFFICE, 450 W. State Street, Boise, Idaho

JOHN V. EVANS
Governor

C. STEPHEN ALLRED
Director

Mailing address:
Statehouse
Boise, Idaho 83720
(208) 334-4440

February 11, 1981

City of Ucon
Box 98
Ucon, ID 83454

Dear Sirs,

A representative of this Department has made an examination of the works covered by your Permit No. 25-7007, and has found the following:

Amount of water that can be recognized as beneficially used under Idaho law: .48 cfs Source: groundwater

The maximum quantity diverted shall not exceed N/A acre feet per year.

Point(s) of diversion: SE 1/4, Sec. 14, Twp. 3N, Rge. 38E, B.M.

Beneficial use: Within the city limits of Ucon.

Priority date established: May 21, 1970

Conditions (if any):

If you do not concur with these findings please contact us within 10 days, otherwise a water license will be issued as set forth above.

Sincerely,

JIM JOHNSON
Water Distribution Supervisor

MICROFILMED

DEPARTMENT OF WATER ADMINISTRATION

FIELD REPORT

RECEIVED

NOV 24 1976

1. Name of permit holder City of Ucon
 Post office address Box 98, Ucon, Idaho 83454
 Person to contact CLARENCE ROCK - GENERAL MAINTENANCE Phone _____

Department of Water Resources
 Eastern District Office

2. Source of water supply: Groundwater ☒ Surface water ☐
 (name spring, stream, etc.)
 Tributary to _____

3. Water will be used for the following purposes:

Amount 3.00 c.f.s. for Municipal
 AF/Annum (nature of use)

Period of Use: from Jan. 1 to Dec. 31
 (mo.-day) inclusive (mo.-day)

Amount _____ c.f.s. for _____
 AF/Annum (nature of use)

Period of Use: from _____ to _____
 (mo.-day) inclusive (mo.-day)

Amount _____ c.f.s. for _____
 AF/Annum (nature of use)

Period of Use: from _____ to _____
 (mo.-day) inclusive (mo.-day)

Other uses: _____

Permit No. 25-7007
 Examination for b/u

4. Total amount to be appropriated:

Max Rate of Diversion 3.00 cubic feet per second and annual volume _____ AF/Annum.

5. Location of Point(s) of Diversion:

Township 3N N/S, Range 38E E/W, B.M., Section 14, Subdivision SE $\frac{1}{4}$ NE $\frac{1}{4}$, Bonneville
 County

Township _____ N/S, Range _____ E/W, B.M., Section _____, Subdivision _____ $\frac{1}{4}$ _____ $\frac{1}{4}$, _____
 County

Township _____ N/S, Range _____ E/W, B.M., Section _____, Subdivision _____ $\frac{1}{4}$ _____ $\frac{1}{4}$, _____
 County

Other Points of Diversions: _____

Description of diverting works: 25 hp pump, 10" pitless adapter, 5" column discharge, 20" casing to 10" casing at 330 T.D.H., well depth 177 feet, static water level 142'

Measuring device required: yes ☒ no ☐

6. Lands to be irrigated or place of use.

TWP.	RANGE	SEC.	NE $\frac{1}{4}$				NW $\frac{1}{4}$				SW $\frac{1}{4}$				SE $\frac{1}{4}$				TOTALS
			NE $\frac{1}{4}$	NW $\frac{1}{4}$	SW $\frac{1}{4}$	SE $\frac{1}{4}$	NE $\frac{1}{4}$	NW $\frac{1}{4}$	SW $\frac{1}{4}$	SE $\frac{1}{4}$	NE $\frac{1}{4}$	NW $\frac{1}{4}$	SW $\frac{1}{4}$	SE $\frac{1}{4}$	NE $\frac{1}{4}$	NW $\frac{1}{4}$	SW $\frac{1}{4}$	SE $\frac{1}{4}$	
3N	38E	10																X	
		11											X					X	
		12											X						
		13						X	X			X							
		14	X	X	X	X	X	X	X	X	X	X			X	X			
		15	X			X									X				

MICROFILME

TOTAL ACREAGE _____

Rge 38E





Diagram of System



DATE OF EXAM 7/14/77

ACREAGE
Found n/a
Recommended n/a

Irrigation Requirement n/a Ac Ft/Ac

USE
Irrigation Q = c.f.s. V = AF/Ann. from to
Domestic Q = c.f.s. V = AF/Ann. from to
Livestock Q = c.f.s. V = AF/Ann. from to
Municipal 48 cfs V = 324 AF/Ann. from Jan 1 to Dec 31

Is water co-mingled? yes no X

Name source: n/a
twp. N/S, Rge E/W, B.M., Sec. , Sub. 1/4 1/4 County

Exchange? yes no X

Name source exchanged with: n/a
twp. N/S, Rge E/W, B.M., Sec. , Sub. 1/4 1/4 County

Point of injection: n/a
twp. N/S, Rge E/W, B.M., Sec. , Sub. 1/4 1/4 County

Point of exchange: n/a
twp. N/S, Rge E/W, B.M., Sec. , Sub. 1/4 1/4 County

Total Q measured 48 cfs Method of measurement IN LINE METER
Total Q recommended 48 cfs Meter No. 87531 Type Master Flow Condition good
Total V recommended 324 AF/Ann

Recommended Amendments:

P.D.
Place of Use
Other
None

MEASUREMENT CALCULATION:

Measured 214 gpm, 1 cfs = 448.8, $\therefore 214 \div 448.8 = .48$ cfs
V = by assignment - 1.20 AF/yr/unit X 290 units = 324 AF/yr
No volume on Municipal

SYSTEM DESCRIPTION:


25 H.P. RED JACKET SUBMERSIBLE PUMP, 3 PHASE, 440 VOLT (NO OTHER IDENTIFICATION AVAILABLE). STATIC WATER LEVEL 142', A 100 FT, 10" MAIN CONVEYS WATER FROM WELL TO 10,000 GAL PRESSURE TANK (38 TO 58 PSI) WATER IS DISCHARGED FROM PRESSURE TANK INTO MUNICIPAL SYSTEM.

REMARKS:

SYSTEM DESCRIBED & SIGNED BY CLARENCE ROCK.
290 WATER METERS w/ ONE FAMILY UNIT PER METER. POPULATION CENSUS FOR 1976 = 825 people.
water from this source during the summer months. Potable houses use
No conflicting rights

Examiner's Signature Anthony R. Kozlowski Date 7/14/77
Checked by Robert A. Parker Date 8/29/78
Approved by Date 2/10/81

10.000 psi
(38-58 psi).





STATE OF IDAHO

DEPARTMENT OF WATER RESOURCES

Cecil D. Andrus
Governor

R. Keith Higginson
Director

Statehouse
Boise, Idaho 83720
(208) 384-2215

November 22, 1976

Re: Permit No. 25-7007

City of Ucon
Box 98
Ucon, Idaho 83454

Gentlemen:

We acknowledge receipt of the affidavit submitted as proof of beneficial use for the above referenced permit. Enclosed is an Order of Reinstatement; please note that the priority has been advanced to May 21, 1970.

Before a license can be issued, a field examination must be made by a representative of this Department. We cannot tell just when this exam will be made, but our examiner will try to contact you at the time he makes the exam so that you may show him the system.

If you have any questions regarding the field exam, please contact our Regional Office in Idaho Falls.

Sincerely,

JANICE RENK
Water Rights

Enc.

RECEIVED

RECEIVED

NOV 9 1976

Department of Water Resources
Eastern District Office

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

Identification No. _____

Permit No. 25-7007

RECEIVED

PROOF OF APPLICATION OF WATER TO BENEFICIAL USE

NOV 12 1976

1. a) Name of Permit Holder City of Ucon Department of Water Resources
b) Post Office Address P.O. Box 98, Ucon, Idaho 83454
2. Permit Number 25-7007
3. Date of Priority that you are prepared to establish 3-13-70
4. a) Source from which water was appropriated ground water
b) Location of the point of diversion: SE $\frac{1}{4}$ NE $\frac{1}{4}$, Section 14
Township 3N, Range 38E Boise Meridian, Other points of diversion: _____
5. a) The amount of water and use to which the water has been applied:
Amount 0.51 for Municipal purposes from Jan. 1 to Dec. 31 incl.
(cfs and/or acre-feet per annum) (Month-Day) (Month-Day)
Amount _____ for _____ purposes from _____ to _____ incl.
(cfs and/or acre-feet per annum) (Month-Day) (Month-Day)
Amount _____ for _____ purposes from _____ to _____ incl.
(cfs and/or acre-feet per annum) (Month-Day) (Month-Day)
b) Total amount appropriated 0.51 cfs and/or acre-feet per annum
c) Describe how and by whom measurement of rate of flow or amount of storage was made and the qualifications of the person making the measurement: Rate of flow was made with a mainline meter by David E. Benton, P.E.
6. If the means of diversion and conveyance are owned by someone other than the Permit Holder:
a) Give the name or description of the canal, ditch or other works by which the water is conducted to the place of use: Municipal Distribution System
b) Describe the agreement or understanding by which you take water from the works: _____
7. a) Briefly describe the works for diverting and conveying the water to the place of use, (if from a subterranean source, give the pump size, motor size, size of well casing, depth of well; if from surface water, give brief description of diversion structure and/or canal or ditch) 25 Hp. Layne & Bowler 4 stage pump, 10" Pitless adapter, 5" column discharge, 20" casing to 10' casing @ 330 T.D.H.; Well depth - 177 feet; Static water level - 142 feet.
b) Describe the type and size of measuring device which you have installed at your point of diversion: 4" Hersey Sparling Master Flo Mainline Meter with direct reading on meter
c) Give well driller's name and address and the date the well was completed: Cushman & Denning - Blackfoot, Idaho
Completed July, 1971
8. If for other than irrigation, describe the beneficial use to which you have applied the water and the place of use: Municipal use for the City of Ucon, Idaho

RECEIVED

NOV 12 1976

9. Irrigation uses: describe the lands irrigated by giving the acreages irrigated within each 40 acre subdivision: _____

T	R	SEC.	NE¼				NW¼				SW¼				SE¼				TOTAL
			NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	
3N	38E	10																X	
		11											X					X	
		12											X						
		13						X	X			X							
		14	X	X	X	X	X	X	X	X	X	X			X	X			
		15	X			X									X				

Total number of acres irrigated _____

10. Remarks: Potato houses use water during winter months, which keeps the
yearly average fairly even

The above information is a true statement of the extent to which the above numbered permit has been developed.

11-10-76
(Date)

Lloyd J. Morris councilman
(Signature)

State of Idaho)
) ss.
County of Bonneville)

On this 11th day of Nov., 1976, personally appeared before me
the signer(s) of the above instrument, who duly acknowledged to me that he (she) (they) executed the same.

Lorna Kinghorn
Notary Public residing at: 245 E 10th
Ucon, Idaho 83446

My commission expires Sept 23 1980



STATE OF IDAHO

DEPARTMENT OF WATER RESOURCES

Cecil D. Andrus
Governor

R. Keith Higginson
Director

Statehouse
Boise, Idaho 83720
(208) 384-2215


September 10, 1976

City of Ucon
Box 12
Ucon, Idaho 83454

Gentlemen:

You are hereby notified that under the provisions of Section 42-218a of the Idaho Code, Permit No. 25-7007 has lapsed.

You are further advised that the Department cannot reinstate the permit except upon a showing of reasonable cause within 60 days from the date of this notice of lapsing.


R. KEITH HIGGINSON
Director

RKH:jg

RECEIVED
SEP 14 1976
DEPT. OF WATER RESOURCES

WATER RESOURCE BOARD:

John F. Streiff
Chairman

Franklin Jones
Member

George L. Yost
Vice-Chairman

M. Roed Hansen
Member

Donald R. Kramer
Secretary

Scott W. Reed
Member

Edwin C. Schlender
Member

Joseph H. Nettleton
Member

June 30, 1976

CERTIFIED MAIL 138721

Re: Permit No. 25-7007

City of Ucon
Box 12
Ucon, Idaho 83454

Gentlemen:

One of the conditions of approval of your water Permit No. 25-7007 (see last page of your approved permit) was that evidence of the extent of development be submitted as proof of application of water to beneficial use to this office on or before September 1, 1976. Enclosed is an affidavit form which must be used to submit the required proof of beneficial use.

If you have not fully completed your project, and you have not previously received an extension of time, you may request an extension of time provided the delay is for reasonable cause as indicated in Section 42-204, Idaho Code, amended. If you have been prevented from proceeding by a governmental agency or by litigation, more than one extension of time can be granted.

Either the beneficial use affidavit or a request for an extension of time must be received by this Department on or before the above mentioned date, otherwise the permit will lapse and be of no further force or effect.


R. KEITH HIGGINSON
Director

RKH:jg
Enc: Proof affidavit

RECEIVED
JUL 1 1976

STATE OF IDAHO

DEPARTMENT OF WATER ADMINISTRATION

Statehouse - Annex 2
Boise, Idaho 83707
(208) 384-2215



R. Keith Higginson
Director

Water Rights Administration
Water Resource Investigations
Dam and Reservoir Safety
Water Well Drilling
Flood Plain Management
Irrigation and
Flood Control Districts

November 12, 1971

Re: Permit No. 25-7000 & 25-7007 - City of Ucon

City of Ucon
P. O. Box 12
Ucon, Idaho 83454

ATTENTION: Bud L. Strupp

Dear Mr. Strupp:

Enclosed please find copies of the approved applications for amendment for the above referenced permits.

If we may be of further assistance, do not hesitate to contact us.

Very truly yours,

Donald W. McEldowney
Appropriation Supervisor

DWM/BB

Enclosures

25 7007

STATE OF IDAHO

DEPARTMENT OF WATER ADMINISTRATION

Statehouse - Annex 2

Boise, Idaho 83707

(208) 384-2215



R. Keith Higginson
Director

Water Rights Administration
Water Resource Investigations
Dam and Reservoir Safety
Water Well Drilling
Flood Plain Management
Irrigation and
Flood Control Districts

September 23, 1971

Re: Permit No. 13-7025	31-7052
17-7014	35-7181
25-7007	35-7182
27-7019	74-7014
29-7067	75-7016

Norman C. Young
STATE OF IDAHO
DEPT. OF WATER ADMINISTRATION
240 South Holmes
Idaho Falls, Idaho 83401

Dear Norm:

Please find enclosed copies of the above referenced permits which have been approved by this office.

If you have any questions, please contact us.

Very truly yours,

Bobby D. Fleenor

BOBBY D. FLEENOR
Assistant Director

BDF:cr

Enc: copies

25 7007

STATE OF IDAHO

DEPARTMENT OF WATER ADMINISTRATION

Statehouse - Annex 2
Boise, Idaho 83707
(208) 384-2215



R. Keith Higginson
Director

Water Rights Administration
Water Resource Investigations
Dam and Reservoir Safety
Water Well Drilling
Flood Plain Management
Irrigation and
Flood Control Districts

September 23, 1971

Re: Permit No. 25-7007 - City of Ucon

City of Ucon
P.O. Box 12
Ucon, Idaho 83454

Gentlemen:

Enclosed is a copy of your approved Application for Permit No. 25-7007. We direct your attention to the conditions of approval as listed on the fourth page.

Be sure to note that a special condition requiring you to install and maintain a measuring device at your point of diversion has been placed upon your permit. We are enclosing a letter describing different types of measuring devices accepted by this office.

Very truly yours,

BOBBY D. FLEENOR
Assistant Director

BDF:cr

Enclosures

25 7007

CITY OF UCON
UCON, IDAHO 83454

Aug. 20, 1971

RECEIVED

AUG 23 1971

Department of Water Administration

State of Idaho
Dept. of Water Administration
Statehouse---Annex 2
Boise, Idaho 83707

Attn: Donald W. McEldowney

BDF

8/23/71

Dear Sir;

I would like to give to the State Dept. of Water Administration a brief history of the water system in the City of Ucon.

The main supply of water was taken from a well owned by the Union Pacific Railroad which the City leased. Late in 1964 we found that this water was contaminated. The State Sanitation Dept. condemned the well. A new well was then drilled. The Railroad well was then cut off and sealed from our system. A new well was drilled in 1965, which is filed under water permit 25-7000. The water from this is our main supply now. The information about how much it pumps in on the enclosed letter.

In the summer of 1970 another well was drilled. This is to be used as an auxiliary to our main supply. This well was drilled directly south across the street from an old well that has been in our City for years. This old well was known as the Andrus well. At the last usage it would pump about 18 gallon a minute-with sand. The "Andrus" well has now been cut off from our system and sealed with cement. The well drilled to replace this is not in use as yet. No pump has been installed to determine capacity of the well. However when tested it pumped dry at the rate of 1,000 gallon per minute. It is felt that production will be a lesser amount.

Due to enlarging by annexation, about ten (10) acres for a housing development, and continual new building there is and will be greater demand for water. There are also two potatoe warehouses that draw heavily from the system during the winter until early summer. As well as other industries and business'. The City has a fire engine and volunteer fire department that has relied upon a good water system to protect our industries, business and homes.

If there is more information needed I would be glad to try to help.

Sincerely,

Alene M. Hill
Alene M. Hill
City Clerk

Encls:

25 7007

CITY OF UCON
P. O. Box 98
Ucon, Idaho
83454

RECEIVED

March 31, 1971

Re: Permit Application
No. 25-7007

Department of Reclamation
Statehouse- Annex 2
Boise, Idaho 83707

Attention: Donald W. McEldowney
Appropriation Supervisor

Dear Mr. McEldowney:

The following is information for the City of Ucon and our two wells.

The 1960 population of Ucon was 532 and the 1970 census showed 664. Our Well No. 1 (permit no. 25-7000) has a 490 gpm pump installed and the max. use on this well has been 1.1 c.f.s. even though it was tested at 2242 g.p.m. We are filing our "Proof of Application of Water to Beneficial Use" on Well No. 1 at 1.1 c.f.s.

The population increase during the past 10 years was 24.8%. Due to financing problems on housing during the last few years our growth has been curtailed. At the time of application we expected to get a better well than we did. This well (permit No. 25-7007) only tested at 1100 gp.m. and therefore we only plan to use 2.0 c.f.s. instead of the 3.0 c.f.s. placed on the application. A new housing project is starting in the City and we feel that we will be needing this full 2.0 c.f.s.

If any additional information is needed please write or call our City Engineer, David E. Benton 1400 Benton St. Idaho Falls, Idaho 83401 Phone 522-8033.

Sincerely yours,



Bud L. Strupp
Mayor

25 7007

March 17, 1971

Re: Application No. 25-7007

Mr. Bud L. Strupp
City of Ucon
Box 12
Ucon, Idaho 83454

Dear Mr. Strupp:

We are again writing you in connection with the above referenced application for permit, which your city filed with the Department of Water Administration on March 13, 1970. The application proposes a diversion of 3 cubic feet per second from ground water. We have been attempting to obtain additional information that will help justify the quantity of water you have requested.

We have written on May 13, 1970 and February 5, 1971 and have as yet, failed to receive any response. As you are probably aware, that unless this permit is approved, there is no authority to divert any water from a well drilled in connection with this filing. We would therefore request that you supply answers to the copy of the May 13, 1970 letter we are enclosing.

If you have any questions on the matter, please contact us.

Very truly yours,

Donald W. McEldowney
Appropriation Supervisor

DWM/bb

Enc: copy of letter

25 7007

February 5, 1971

Re: Application No. 25-7007

City of Ucon
P.O. Box 12
Ucon, Idaho 83454

Gentlemen:

Please find enclosed a copy of our letter of May 13, 1970 in regards to the above referenced application for permit. As of this date, we have received no response to our inquiries.

Your prompt attention to this matter is requested so that we may continue the processing of your application.

Very truly yours,

Donald W. McEldowney
Appropriation Supervisor

DWM/DG

Enc: copy of letter

25 7007

May 13, 1970

Re: Permit Application No. 25-7007

City of Ucon
P. O. Box 12
Ucon, Idaho

Gentlemen:

We are in receipt of the above referenced application and before we can take final action, please supply additional information that will assist us in justifying the additional three ^{egs} inches of appropriation from a groundwater source that you are now requesting. Our records indicate from a well drillers log that you already have a well capable of producing 5.0 cubic feet per second. The only figures we can find for population are those from the Association of Idaho Cities that lists the population of Ucon at 520. Your current population, your proposed assumption, for a five year period, as well as information about your present use and demands will assist us in better justifying the quantity of water you have requested.

Very truly yours,

Donald W. McEldowney
Appropriation Supervisor

DWM:tg

25 7007

March 25, 1970

Re: Application for Permit No. 25-7007 - City of Ucon

Post Register
333 Northgate Mile
Idaho Falls, Idaho 83401

Gentlemen:

Enclosed you will find a legal notice which we wish to have published once a week for two consecutive weekly issues of your newspaper. We have inserted the publication dates allowing ample time for you to submit us a galley proof for review before publication.

After sending us a galley proof, proceed with the publication on the dates we have inserted assuming the notice is correct. If we have any corrections, we will notify you before the first publication date. If you cannot publish the notice on the proposed dates, please contact us immediately.

An affidavit of publication must be submitted to the Department of Reclamation along with the publication bill. In order to receive payment, the following certification must appear on the bill:

I hereby certify that the foregoing account is just and correct, that the amount claimed is legally due, after allowing all just credits, and that no part of the same has been paid.

(Signature of the claimant)

Very truly yours,

Donald W. McEldowney
Appropriation Examiner

DWM:DR
Enc: Legal notice

Bill submitted

4-21-70

ds

25 7007

NOTICE OF APPLICATION FOR PERMIT

TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF IDAHO

Notice is hereby given that the City of Ucon, P.O. Box 12, Ucon, Idaho,

has on March 13, 1970

submitted Application No. 25-7007 to appropriate the public waters of
a groundwater source

~~The proposed uses are~~

The application proposes a maximum diversion and appropriation of 3.0
cubic feet per second ~~added added~~ of water to be diverted by well and pump
within the SE $\frac{1}{4}$ NE $\frac{1}{4}$ of Sec. 14,
T. 3N, R. 38E, B.M., Bonneville County,

and is to be used within the City of Ucon for municipal purposes from Jan. 1
to Dec. 31

Any permit issued pursuant to this application will be subject to ALL PRIOR
WATER RIGHTS and subject to the CONTROL OF A STATE WATERMASTER. Any protest
against this application must be filed with the Idaho Department of Reclamation on
or before April 20, 1970.

R. KEITH HIGGINSON

State Reclamation Engineer

Published in the Post Register, Idaho Falls, Idaho,
on April 2 and April 9, 1970

25 7007

BENTON ENGINEERING

Consulting Engineers

DAVID E. BENTON, P.E.
RES. PH. 522-5046

LLOYD J. BENTON
RES. PH. 522-8314

1400 BENTON ST.
IDAHO FALLS, IDAHO
PH. 522-8033

RECEIVED

MAR 13 1970

Department of Reclamation

March 11, 1970

State Department of Reclamation
Boise, Idaho

Gentlemen:

I am enclosing an application to drill a well in the City of
Ucon, Idaho. If any additional information is required please
send it to me at the above address.

Sincerely yours,

David E. Benton

David E. Benton, P.E.