


T5N T4N

T. 4840 / 6

42' 30"

4039



RECEIVED

MAY 11 1993

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

Department of Water Resources

A. GENERAL INFORMATION

Permit No. 63-10965
1. Owner: Ray V. & Lynne Sasso Phone No. 939-2334
Current Address: 900 W. Meader Ct., Eagle, ID 83616
2. Accompanied by: Lynne Sasso EXAM. DATE: 7-22-92
Address: _____ Phone No. _____
Relationship to Permit Holder: _____
3. Source: Groundwater tributary to _____

B. OVERLAP REVIEW


1. Other water rights with same place of use: None

☐ Copies Attached
2. Other water rights with same point of diversion: None

☐ Copies Attached ☐ Copies of Field Exam's Attached

C. SYSTEM DESCRIPTION

1. **Diversion System Diagram:** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe i.d. as applicable. ☐ Alternative diagram attached



Scale: 1" = Not to scale.

JUL 23 1993

2. ☒ Copy of U.S.G.S. Quadrangle Attached
Showing location(s) of point(s) of diversion and
place(s) of use (required). ☐ Aerial Photo Attached
(required for irrigation of 10 acres or more).
☒ Photo of Diversion and System Attached
(required for all but single household domestic groundwater, and stockwater.

UNITED STATES
DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY






PHOTO ONE-

Three inch sprinkler line
with 1/8" head P/U, Facing
west.



PHOTO TWO-

Sprinkler line w/ 1/8"
heads. Facing South-West.

MICROFILMED
JUL 23 1993

State of Idaho
Department of Water Resources

WATER RIGHT LICENSE
WATER RIGHT NO. 63-10965

Priority: September 8, 1989

Maximum Diversion Rate: 0.12 CFS
Maximum Diversion Volume: 17.8 AF

This is to certify, that RAY V SASSO
LYNNE SASSO

900 W MEANDER COURT
EAGLE ID 83616

has complied with the terms and conditions of the permit, issued pursuant to Application for Permit dated September 8, 1989; and has submitted Proof of Beneficial Use on April 30, 1990. An examination indicates that the works have a diversion capacity of .170 cfs of water from a **GROUNDWATER** source, and a water right has been established as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
IRRIGATION	03/15 to 11/15	0.09 CFS	17.1 AF
STOCKWATER	01/01 to 12/31	0.01 CFS	0.1 AF
DOMESTIC	01/01 to 12/31	0.02 CFS	0.6 AF
Totals		0.12 CFS	17.8 AF

LOCATION OF POINT(S) OF DIVERSION:

NESW , Sec. 32, Township 05N, Range 01E
ADA County

PLACE OF USE: IRRIGATION

<u>TWN</u>	<u>RGE</u>	<u>SEC</u>	<u>ACRES</u>	<u>ACRES</u>	<u>ACRES</u>	<u>TOTAL</u>
05N	01E	32	NESW	3.8		3.8

Total number of acres irrigated: 3.8

PLACE OF USE: STOCKWATER, same as IRRIGATION use

PLACE OF USE: DOMESTIC, same as IRRIGATION use

CONDITIONS/REMARKS:

1. The maximum diversion volume is defined as the maximum allowable volume of water that may be diverted annually from the source under this right. The use of water confirmed by this right is limited to the amount which can actually be beneficially used. The maximum diversion volume may be adjusted to more accurately describe the beneficial use or to implement accepted standards of diversion and use efficiency.
2. This water right is appurtenant to the described place of use.
3. This right is subject to all prior water rights and may be forfeited by five years of non-use.
4. Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho law.

MICROFILMED

JUL 23 1993

State of Idaho
Department of Water Resources

WATER RIGHT LICENSE
WATER RIGHT NO. 63-10965

CONDITIONS/REMARKS:

5. This right when combined with all other rights shall provide no more than 4.5 afa per acre for the lands above.
6. The right holder shall fully use all surface water rights appurtenant to the lands identified above prior to using water under this right.
7. Place of use is located within Lot 1, Block 2, Eagle North Estates.
8. Stockwater use is for 1 horse and 5 range cattle.
9. Domestic use is for 1 home.

This license is issued pursuant to the provisions of Section 42-219, Idaho Code, Witness the seal and signature of the Director, affixed at Boise, this 13TH day of July, 1993.

Acting for R. Keith Higginson, Director

RECEIVED

JUL 23 1993

RECEIVED
APR 30 1990

For Office Use Only
Amt. of Fee \$ 50.00
Date 4-30-90
Receipt No. C016605
Received by Amie

STATE OF IDAHO

DEPARTMENT OF WATER RESOURCES

Department of Water Resources

PROOF OF BENEFICIAL USE

The Idaho Department of Water Resources will consider this form as a statement that the permit holder(s) has/have completed all development that will occur under this permit and that water has been applied according to the provisions of the permit for the beneficial use(s) described below. This form must be accompanied by a license examination fee or a completed field examination report prepared by a certified water right examiner who has been appointed by the department.

Permit No. 63-10965 Telephone No. 939-2334

Name(s) of Permit Holder(s): Raymond J. Sasso, JR & Lynne Sasso

Post Office Address: 900 W. Meander Ct. Eagle, Id. 83616

Source of Water: Ground water

If ground water, well driller's name: Borse Valley Pump Date drilled: 5/5/88

Extent of Use:
Domestic 1 (No. of households) Irrigation 5 (No. of acres)
Stockwater 1 horse (No. and type of stock) Other _____
5 herefords

Total rate and/or volume for which proof is submitted .19 cfs 5 acre/feet

Show date water was first diverted and beneficially used under this permit: 6/89

One of the following may be a condition of approval of your permit:

Measuring device: Required? Yes No Installed? Yes No

OR

Flow Measurement Port: Required? Yes No Installed? Yes No

Fee Enclosed: \$ _____ (See License Examination Fee Schedule)

Person to contact to accompany the Department representative during the field examination:

Lynne Sasso 939-2334
Name Telephone No.

900 W. Meander Ct Eagle Id. 83616
Address

The above information is my true statement of the extent to which the above numbered permit has been developed and I relinquish any undeveloped portion of the permit to the state of Idaho.

Date

Lynne Sasso
Signature (and title if on behalf of a company or organization)

DEC 26 1991

State of Idaho
Department of Water Resources
Permit To Appropriate Water

NO. 63-10965

Proposed Priority: September 8, 1989 Maximum Diversion Rate: 0.19 CFS

This is to certify, that **RAY V. SASSO**
LYNNE SASSO
900 W. MEANDER CT.
EAGLE, ID 83616

has applied for a permit to appropriate water from: **GROUNDWATER**
and a permit is **APPROVED** for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
IRRIGATION	03/15 to 11/15	0.15 CFS
STOCKWATER	01/01 to 12/31	0.02 CFS
DOMESTIC	01/01 to 12/31	0.02 CFS
Totals		0.19 CFS

LOCATION OF POINT(S) OF DIVERSION: NESW Sec. 32, Township 05N, Range 01E
ADA County

PLACE OF USE: IRRIGATION

<u>TWN</u>	<u>RGE</u>	<u>SEC</u>	<u>ACRES</u>	<u>ACRES</u>	<u>ACRES</u>	<u>TOTAL</u>
05N	01E	32	NESW	5		5
Total number of acres irrigated:						5

PLACE OF USE: STOCKWATER, same as IRRIGATION use

PLACE OF USE: DOMESTIC, same as IRRIGATION use

CONDITIONS/REMARKS:

1. Proof of construction of works and application of water to beneficial use shall be submitted on or before January 1, 1991.
2. Subject to all prior water rights.
3. Permit holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code.
4. The rate of diversion of water for irrigation under this permit and all other water rights on the same land shall not exceed 0.03 cubic feet per second for each acre of land.
5. Place of use also known as Lot 1, Blk. 2, Eagle North Estates.
6. Domestic use is for 1 home.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code.
Witness the seal and signature of the Director, affixed at Boise, this

14th day of December, 1989.

NOTARIZED

DEC 19 1989

[Signature]
for R. Keith Higginson, Director

Ident. No. 63-10965

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

APPLICATION FOR PERMIT

To appropriate the public waters of the State of Idaho

1. Name: RAY V. SASSO 208-939-2334
Address: 900 W. MEANDER CT.
EAGLE, ID 83616

OR

Name: LYNNE SASSO 208-939-2334
Address: 900 W. MEANDER CT.
EAGLE, ID 83616

2. Source: GROUNDWATER

Trib. to:

3. Location of Point of Diversion: NESW Sec. 32, Township 05N, Range 01E
ADA County

4. Water will be used for the following purposes:

Purpose	From	To	CFS	(or)	AF
DOMESTIC	01/01	12/31	0.020		
STOCKWATER	01/01	12/31	0.020		
IRRIGATION	03/15	11/15	0.150		

5. Total quantity appropriated is:
0.190 CFS (and/or) AF

6. Proposed diverting works:

- Description of ditches, flumes, pumps, headgates, etc.
165' DEEP, 10" CASING, 2 SUB. PUMPS, PIPED TO HOME, & SPRINKLER S
- Height of storage dam feet; active reservoir capacity
acre-feet; total reservoir capacity acre-feet; period of
year when water will be diverted to storage: to inclusive.
- Proposed well diameter is 10 inches; proposed depth of well is 165
feet.
- Is groundwater with a temperature greater than 90F being sought? NO

7. Time required for the completion of the works and application of
the water to the proposed beneficial use is 1 years.

8. Description of proposed uses:
DOMESTIC, STOCK, IRRIGATION

RECEIVED

DEC 19 1989

9. Place of Use: IRRIGATION

TWN RGE SEC	ACRES	ACRES	ACRES	TOTAL
05N 01E 32	NESW 5			5

* Place of Use: STOCKWATER

TWN RGE SEC	
05N 01E 32	NESW

* Place of Use: DOMESTIC

TWN RGE SEC	
05N 01E 32	NESW

Total number of acres irrigated: 5

10. Describe any other water rights used for the same purposes.
NONE

11. a. Who owns the property at the point of diversion?

APPLICANT

b. Who owns the land to be irrigated or place of use?

APPLICANT

c. If the property is owned by a person other than the applicant,
describe the arrangement enabling the applicant to make this filing.

* 12. Remarks:

~~THIS SYSTEM EXISTS~~

EAGLE NORTH ESTATES, LOT 1 BLK 2.

13. Map of proposed point of diversion and place of use attached? [✓]

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.


Applicant

* Deleted in data base 7-25-89 SS

MICROFILMED

DEC 19 1989


Ident. No. 63-10965
Page 3

Received by Rch Date 9/8/89 Time 16:58 Preliminary check by [Signature]
Fee \$ 30.00 Receipted by Rch # W005798 Date 9/8/89
Publication prepared by GG Date 9-27-89 Published in ID Statesman
Publication approved [Signature] Date 10/23-89 ^{10/5 & 10/12/89}

MICROFILMED

DEC 19 1989

T5N
T4N





State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

July 14, 1993


RAY V SASSO
LYNNE SASSO
900 W MEANDER COURT
EAGLE ID 83616

RE: WATER RIGHT NO. 63-10965

Dear Water Right Holder(s):

Enclosed herewith is a copy of the Water Right License issued on the above referenced permit.

Sincerely,



JIM JOHNSON
Water Rights Supervisor

JJ:dc

Enclosure

MICROFILMED

JUL 23 1993

WR0749NP
No. L63-10965

IDAHO DEPARTMENT OF WATER RESOURCES
WATER RIGHT PROFILE REPORT
(REGIONAL)

DATE: 07/12/93
PAGE: 1

OWNER CODE	NAME & ADDRESS	PRIORITY DATE	WATER USE	USE PERIOD FROM TO	DIVERSION RATE	DIVERSION VOLUME
C	RAY V SASSO	09/08/1989	IRRIGATION	03-15 11-15	0.09 CFS	17.1 AFA
C	LYNNE SASSO		STOCKWATER	01-01 12-31	0.01 CFS	0.1 AFA
	900 W MEANDER COURT		DOMESTIC	01-01 12-31	0.02 CFS	0.6 AFA
	EAGLE ID 83616					
	(208) 939-2334					
				TOTAL DIVERSION:	0.12 CFS	17.8 AFA

Water Source: GROUNDWATER

Tributary to:

Stage: LICENSE

Point(s) of Diversion Capacity: 0.17 CFS

Point(s) of Diversion: T05N R01E S32 NE SW

Place of use Legal Description for: IRRIGATION

												NE				NW				SW				SE				
			NENE	NWNE	SWNE	SENE	:	NENW	NWNW	SWNW	SENW	:	NESW	NWSW	SWSW	SESW	:	NESE	NWSE	SWSE	SESE	:	SUM					
T	R	S	: Lt	Ac	Lt	Ac	Lt	Ac	Lt	Ac	Lt	Ac	:	Lt	Ac	Lt	Ac	Lt	Ac	Lt	Ac	Lt	Ac	:				
05N	01E	32	:										:	03										:				
																							TOTAL ACRES	3.8				

Place of use location for STOCKWATER is the same location as described for: IRRIGATION

Place of use location for DOMESTIC is the same location as described for: IRRIGATION

Pou County: ADA

Non-Irrigation Uses: STOCKWATER, UP TO 8 BEEF CATTLE, & HORSE

Other Water Rights with Same Point(s) of Diversion and Source:
63-10567 63-10781 63-10965 63-10997

Other Water Rights Listing Overlapping Place(s) of use:
63-03018 63-10567 63-10781 63-10965 63-10997

Conditions of Approval:

- R27 - This right when combined with all other rights shall provide no more than 4.5 afa per acre for the lands above.

Remarks: The right holder shall fully use all surface water rights appurtenant to the lands identified above prior to using water under this right.
Place of use is located within Lot 1, Block 2, Eagle North Estates.
Stockwater use is for 1 horse and 5 range cattle.
Domestic use is for 1 home.

Dates: App. Received: 09/08/1989 Priority Date: 09/08/1989
Proof Due Date: 01/01/1991 Proof Made Date: 04/30/1990
Exam Made Date: 07/22/1992 Exam Sent to S.O.: 04/28/1993
Licensed Date:

LICENSE REVIEW CHECKLIST

Permit # 63-10965 Date 7-12-93 Brenda Chapman

NAME	Yes <u> </u> No <u> </u> ☒	Or Address Change?
PRIORITY DATE	<u> </u> ☒ Advance? <u> </u> Memo to Advance <u> </u>	
	<u> </u> ☒ Order to Reinstate Needed?	
SOURCE	<u> </u> ☒ Changes? Clarification of Originally Intended source	
	<u> </u> ☒ Notice of Intent to Void - Source change.	
P/D	<u> </u> ☒ Amendment Needed?	
	<u> </u> ☒ Is Overlap Analysis a Consideration?	
P/U	<u> </u> ☒ Amendment Needed?	
	<u> </u> ☒ Is Overlap Analysis a Consideration?	
TOTAL CFS	<u> </u> ☒ Incorrect Fee for rate recommended? 13 heads @ 2.96 = .09 CFS	
	<u> </u> ☒ Disagree/Measurement 5HP @ .13 CFS	
	<u> </u> ☒ Pumping Theoretical $(8.8) \times (.70) \times (1.5)$ $(140 + [2.31 \times 40]) = .04 \text{ CFS}$	
	<u> </u> ☒ System Capacity .17	
	Allowable Amount: <u>Dom = .02 STOCK = .01 IRR = .09</u>	
TOTAL VOLUME	Rate/ac <u>4.5</u> AFA Irr. Season <u>D</u>	
	<u>3-15 to 11-15</u> Standard Irr. Season	
	<u>Standard</u> Season Recommended	
	<u> </u> ☒ Disagree with Examiner's Calculations?	
	<u>3.8 acres X 4.5 = 17.1 af Dom = .6 Stock = .1</u>	
	<u> </u> ☒ Flow limit: <u>.09</u> x 246 x 1.9835 = <u>43.9 > 17.1</u>	
USES	<u> </u> ☒ Change(s) in Nature of Use?	
	<u> </u> ☒ Amendment Needed?	
REMARKS	<u> </u> ☒ Multiple P/Ds in 1/4 1/4?	
	<u> </u> ☒ Non-Irr. Uses <u>DOMESTIC + STOCKWATER</u>	
	<u> </u> ☒ Special Overlap Condition	
	<u>WB3</u> <u> </u> ☒ Other <u>(BASIN 63 GW supplemental)</u>	
CONDITIONS	<u> </u> ☒ Measuring Devices	Dates/Misc
	<u> </u> ☒ W/Master Control	Water Dist
	<u>R27</u> <u> </u> ☒ Irrigation Overlap	<u>9-8-89</u> App Rec'd
	<u> </u> ☒ Water Quality	<u>7-22-92</u> Exam Made

COMMENTS: Reduce acres and amount; Six head (horse scows)

RECOMMENDED	CFS	VOL	LICENSE
Irrigation	<u>.09</u>	<u>17.1</u>	☒
Domestic	<u>.02</u>	<u>.6</u>	
Stockwater	<u>.01</u>	<u>.1</u>	
			AMEND <u> </u>

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

RECEIVED
MAY 11 1993
Department of Water Resources

A. GENERAL INFORMATION


1. Owner: Ray V. & Lyane Sasso Permit No. 63-10965
Current Address: 900 W. Mender Ct., Eagle, ID 83616 Phone No. 939-2334
2. Accompanied by: Lyane Sasso EXAM. DATE: 7-22-92
Address: _____ Phone No. _____
Relationship to Permit Holder: _____
3. Source: Groundwater tributary to _____

B. OVERLAP REVIEW

1. Other water rights with same place of use: None ☐ Copies Attached
2. Other water rights with same point of diversion: None ☐ Copies Attached ☐ Copies of Field Exam's Attached

C. SYSTEM DESCRIPTION

1. Diversion System Diagram: Indicate all major components and distances between components. Indicate weir size/ditch size/pipe i.d. as applicable. ☐ Alternative diagram attached



Scale: 1" = Not to scale.

JUL 23 1993

2. ☒ Copy of U.S.G.S. Quadrangle Attached ☐ Aerial Photo Attached
Showing location(s) of point(s) of diversion and (required for irrigation of 10 acres or more).
place(s) of use (required).
☒ Photo of Diversion and System Attached
(required for all but single household domestic groundwater, and stockwater.

System Description (continued)

3. Narrative: Description (As operating at time of measurement. Indicate pressure, number of sprinklers, etc.)

A 10" x 165' well has a 1.5 h.p. pump for domestic use and a 5 h.p. pump for irrigation. Stockwater is also off of a faucet from the domestic pump. The 1 1/2 h.p. pump discharges underground into a pressure tank for use inside the home. The 5 h.p. pump discharges through a 2 1/2" line into a 4" mainline which bisects a pasture to the east. The mainline has 6 risers from which 3" hard lines are attached to water a pasture, lawn, and garden. During the exam, 13 - 1/8" heads were being used. Stock includes 5 cows & 1 horse

☐ See Remarks on page 4 for continuation

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
		5hp			
		1 1/2 hp			

*Code to correspond with No. on map and aerial photo

5. Point(s) of Diversion:

Ident. No.	Gov't. Lot	1/4	1/4	1/4	Sec.	Twp.	Rge.	County	Method of Determination/Remarks
			NE	SW	32	5N	1E	Ada	USGS Photo Quad

6. Place(s) of Use:

Indicate Method of Determination USGS Photo Quad

Twp.	Rge.	Sec.	NE 1/4				NW 1/4				SW 1/4				SE 1/4				Totals
			NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	
5N	1E	32									3.8								3.8 Ac.

Do not use this space

MISSISSIPPI

JUL 28 1993

Do not use this space

D. FLOW MEASUREMENTS

☐ Additional Data Sheets Attached

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurements:

13 - 1/8" heads @ 40 psi = 2.96 GPM each.

1 1/2 h.p. & 5 h.p., 140' dynamic, 40 psi.

Area = $\left[(560' \times 300') - (3000 \text{ sq. ft. house}) \right] \div 143560 = 3.8 \text{ acres}$

E. FLOW CALCULATIONS

☐ Additional Computation Sheets Attached

1. Measured Method:

$$2.96 \text{ GPM} \times 13 \times \frac{1}{448.8} = .09 \text{ cfs} \quad 3.8 \text{ acres} \times \frac{.03 \text{ cfs}}{\text{acre}} = .11 \text{ cfs}$$

2. Alternate Method for Checking Purposes:

$$\frac{1.5 \times .7 \times 8.8}{(2.31 \times 40) + 140} = .04 \text{ cfs For dom. stack} \quad \frac{5 \text{ h.p.} \times .7 \times 8.8}{(2.31 \times 40) + 140} = .13 \text{ cfs For irrig}$$

F. PUMP EFFICIENCY DATA (Optional)

Discharge Pressure: _____ psi x 2.31 = _____ ft (1); Dynamic pumping level: _____ ft (2)

Total Head: (1) + (2) = _____ (3) ; Flow rate: _____ cfs (4)

Water HP: (3) x (4) ÷ 8.8 = _____ (5)

Meter Input KW: 3.6 x _____ KH x _____ CTR or _____ MULT x _____ PTR x _____ N/ _____ T = _____ (6)

Meter Input HP: (6) x 1.34 = _____ (7)

Panel Input KW: _____ Ave PF x _____ Ave Volts x _____ Ave Amps x .001732 = _____ (8)

Panel Input HP: (8) x 1.34 = _____ (7) Efficiency: (5)/(7) x 100 = _____ %

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = 3.8 \times 4.5 = 17.1 \text{ aF}$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 = .09 \text{ cfs} \times 245 \times 1.9835 = 43.7 \text{ aF}$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 17.1 \text{ aF}$$

2. Volume Calculations for Other Uses:

$$\text{Domestic} = .6 \text{ aF}$$

$$\text{Stack} = \frac{12 \text{ GPD}}{\text{head}} \times \left(\frac{\text{head}}{\text{ft}} \times \frac{365 \text{ days}}{\text{year}} \times \frac{1 \text{ aF}}{325,350 \text{ gal}} \right) = .1 \text{ aF}$$

MICROFILMED

JUL 23 1993

H. REMARKS AND OVERLAP REVIEW ANALYSIS

I. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
Irrigation	3/15	11/15	.02 .09 cfs	17.1 afa
Domestic	1/1	12/31	.02 cfs	.6 afa
Stock	1/1	12/31	.02 cfs	.1 afa
Totals:			.13 cfs	17.8 afa

2. Recommended Amendments


- ☐ Change P.D. as reflected above
☐ Change P.U. as reflected above

- ☐ Add P.D. as reflected above
☐ Add P.U. as reflected above

- ☒ None
☐ Other

J. AUTHENTICATION

Field Examiner's Name Mark Sapius
Signature Mark Sapius
Certification Date _____
Field Report Preparation Date 7-23-92



K. Licensing recommendation shall be prepared by an Idaho Department of Water Resources employee on a computer printout attached hereto.

MICROFILMED

JUL 23 1993

UNITED STATES
DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY

2' 30"

551000E


552

553

20'

554

555



Department of Water Resources

WELL INSPECTION FORM

If well is associated with water right, provide WR# 63-10965

Otherwise provide legal description and a sketch map and/or address so that the well can be located easily.

1. Legal Description: TWP 5N, Rge 1E, Sec. 32, NE 1/4 SW 1/4 or Lot _____.

2. Owner: Ray V. & Lynn Sasso

Address 900 W. Meander Court, City Engle, St ID

3. Casing $\geq$ 12 inches above ground: Yes ☒ No ☐

4. Access Port:	Yes ☐ No ☒	Static Water Level:	<u>82'</u>
Pressure Gauge:	Yes ☐ No ☒	Casing Diameter:	<u>10"</u>
Flowing:	Yes ☒ No ☐	Temperature:	_____

5. Are there any obvious construction problems that may be a source for contamination or waste of water: Yes ☐ No ☒

If answer to Item 5 is Yes, describe in remarks and attach photo.


Remarks: _____

MICROFILMED

JUL 23 1993

JUL 23 1993

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER Name <u>Ray Jasso</u> Address _____ Owner's Permit No. <u>63-88-2-32</u>	7. WATER LEVEL Static water level <u>82</u> feet below land surface. Flowing? ☐ Yes ☒ No G.P.M. flow _____ Artesian closed-in pressure _____ p.s.i. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature _____ °F. Quality _____ Describe artesian or temperature zones below.																																																																
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)	8. WELL TEST DATA ☒ Pump ☐ Bailor ☒ Air ☐ Other _____																																																																
3. PROPOSED USE ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type)	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33%;">Discharge G.P.M.</th> <th style="width: 33%;">Pumping Level</th> <th style="width: 33%;">Hours Pumped</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;"><u>80 GPM</u></td> <td style="text-align: center;"><u>190</u></td> <td style="text-align: center;"><u>28 hrs</u></td> </tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>	Discharge G.P.M.	Pumping Level	Hours Pumped	<u>80 GPM</u>	<u>190</u>	<u>28 hrs</u>																																																										
Discharge G.P.M.	Pumping Level	Hours Pumped																																																															
<u>80 GPM</u>	<u>190</u>	<u>28 hrs</u>																																																															
4. METHOD DRILLED ☐ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary ☒ Cable ☐ Dug ☐ Other _____	9. LITHOLOGIC LOG <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Bore Diam.</th> <th colspan="2">Depth</th> <th rowspan="2">Material</th> <th colspan="2">Water</th> </tr> <tr> <th>From</th> <th>To</th> <th>Yes</th> <th>No</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0</td> <td>3</td> <td>Top soil</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>3</td> <td>18</td> <td>Sandy soil</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>18</td> <td>67</td> <td>Dark Brown Sandy Clay</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>67</td> <td>93</td> <td>Dark Brown Sandy Clay</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>93</td> <td>106</td> <td>Dark Brown Clay</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>106</td> <td>116</td> <td>Dark</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>116</td> <td>120</td> <td>Sandy Brown Clay</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>120</td> <td>144</td> <td>Brown sand</td> <td> </td> <td> </td> </tr> <tr> <td>10</td> <td>144</td> <td>165</td> <td>Coarse sand & pea gravel</td> <td> </td> <td> </td> </tr> </tbody> </table>	Bore Diam.	Depth		Material	Water		From	To	Yes	No	10	0	3	Top soil			10	3	18	Sandy soil			10	18	67	Dark Brown Sandy Clay			10	67	93	Dark Brown Sandy Clay			10	93	106	Dark Brown Clay			10	106	116	Dark			10	116	120	Sandy Brown Clay			10	120	144	Brown sand			10	144	165	Coarse sand & pea gravel		
Bore Diam.	Depth		Material	Water																																																													
	From	To		Yes	No																																																												
10	0	3	Top soil																																																														
10	3	18	Sandy soil																																																														
10	18	67	Dark Brown Sandy Clay																																																														
10	67	93	Dark Brown Sandy Clay																																																														
10	93	106	Dark Brown Clay																																																														
10	106	116	Dark																																																														
10	116	120	Sandy Brown Clay																																																														
10	120	144	Brown sand																																																														
10	144	165	Coarse sand & pea gravel																																																														
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____ <table style="width: 100%;"> <thead> <tr> <th>Thickness</th> <th>Diameter</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td><u>250</u> inches</td> <td><u>10</u> inches</td> <td><u>1</u> feet</td> <td><u>153</u> feet</td> </tr> <tr> <td><u>250</u> inches</td> <td><u>8</u> inches</td> <td><u>143</u> feet</td> <td><u>155</u> feet</td> </tr> <tr> <td><u>250</u> inches</td> <td><u>8</u> inches</td> <td><u>163</u> feet</td> <td><u>165</u> feet</td> </tr> </tbody> </table> Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☒ Yes ☐ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation _____ inches by _____ inches Number _____ From _____ To _____ _____ perforations _____ feet _____ feet _____ perforations _____ feet _____ feet _____ perforations _____ feet _____ feet Well screen installed? ☒ Yes ☐ No Manufacturer's name <u>Cook</u> <u>Stainless Steel</u> Type _____ Model No. _____ Diameter <u>8</u> Slot size <u>35</u> Set from <u>155</u> feet to <u>163</u> feet Diameter _____ Slot size _____ Set from _____ feet to _____ feet Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____ Placed from _____ feet to _____ feet Surface seal depth <u>20</u> Material used in seal: ☐ Cement grout ☐ Bentonite ☒ Puddling clay ☐ _____ Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☒ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld ☐ Cemented between strata Describe access port _____	Thickness	Diameter	From	To	<u>250</u> inches	<u>10</u> inches	<u>1</u> feet	<u>153</u> feet	<u>250</u> inches	<u>8</u> inches	<u>143</u> feet	<u>155</u> feet	<u>250</u> inches	<u>8</u> inches	<u>163</u> feet	<u>165</u> feet	10. Work started <u>4/12/88</u> finished <u>5/3/88</u>																																																
Thickness	Diameter	From	To																																																														
<u>250</u> inches	<u>10</u> inches	<u>1</u> feet	<u>153</u> feet																																																														
<u>250</u> inches	<u>8</u> inches	<u>143</u> feet	<u>155</u> feet																																																														
<u>250</u> inches	<u>8</u> inches	<u>163</u> feet	<u>165</u> feet																																																														
6. LOCATION OF WELL Sketch map location <u>must</u> agree with written location.  Subdivision Name <u>Middletown</u> Lot No. _____ Block No. <u>23</u> County <u>Ada</u>	11. DRILLERS CERTIFICATION I/We certify that all minimum well construction standards were complied with at the time the rig was removed. Firm Name <u>Boise Valley Pump & Drilling</u> Firm No. <u>207</u> Address <u>2950 S. Garden</u> Date <u>5/11/88</u> Signed by (Firm Official) <u>Ron S. Nicks</u> and (Operator) <u>Mary R. Fulton</u>																																																																




PHOTO ONE-

Three inch sprinkler line
with 1/8" head P/U, Facing
west.




PHOTO TWO-

Sprinkler line w/ 1/8"
heads. Facing South-west.

RECEIVED

JUL 28 1993

December 20, 1991

RAY V. SASSO
LYNNE SASSO
900 W. MEANDER CT.
EAGLE ID 83616

PROOF ACKNOWLEDGMENT LETTER

RE: PERMIT NO. 63-10965

Dear Permit Holder:

The department acknowledges receipt of the proof of beneficial use form submitted for the above referenced permit. The next step in the process of developing a water right is for the department to conduct a field examination to determine and confirm the use being made of the water.

If you have questions concerning this matter, please feel free to contact the WESTERN Regional Office in Boise at (208)334-2190.

Sincerely,

Karen L. Gustafson
Secretary/Records Manager

c: IDWR - Region

DEC 26 1991

1/88

PROOF OF BENEFICIAL USE

ANALYSIS SHEET

Permit No. 63-10965

Date: 7-16-90

General Considerations:

- ☒ Name same as permit
☒ Signature the same as permit holder
☒ Address change NO If yes, prepare a data entry
☒ Proof received timely
☐ Reinstated

Source of Water:

- ☐ Surface water
☒ Groundwater
☒ 1. well log in file
☒ 2. drilling permit 63-88-2-32
10 A. amount of drilling fee paid for proposed uses

Extent of Use and Rate of Diversion:

- ☒ Rate of diversion appropriate for uses
☒ Is rate or volume and fee appropriate?
☒ Has permit holder indicated when water was first put to a beneficial use?

Measuring Device:

- ☒ Is a measuring device or access port required?
☒ Has one been installed?
☒ Waiver or modification of measuring device requested

Remarks:

drill permit fee should have been
needs app. \$90.00 - received 12/19/91
proof acceptable

Priority Calculation:

Date proof received	<u>NA</u>	
Date proof due		-
No. of days late		=
Priority date		+
NEW PRIORITY DATE		=

SEND FILES TO DATA ENTRY AND THEN TO MICROFILM

proof made 4/30/90
12/20/91 - KRG



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

December 18, 1991

Ray V. or Lynne Sasso
900 West Meander Court
Eagle, ID 83616

Re: Permit No. 63-10965

Dear Permit Holder:

On November 18, 1991, I notified you that an error had been made when you applied for and received your drilling permit. The fee you paid was \$10 and it should have been \$100. I asked that you return the \$90 fee within 30 days of the date of mailing.

As of this date, I have not received the additional drilling fee. I cannot process your proof of beneficial use until I have received that fee. Therefore, I would ask once again that you respond within 15 days of the date of this mailing.

Once again, I apologize for the error made at the time you applied. If you have any questions or if I can be of any further assistance, please feel free to contact me.

Sincerely,

Karen L. Gustafson
Secretary/Records Manager

UNRECORDED

DEC 26 1991



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

November 18, 1991

Ray V. or Lynne Sasso
900 West Meander Court
Eagle, ID 83616333

Re: Permit No. 63-10965

Dear Permit Holder:

Returned is a copy of the Proof of Beneficial Use and Drilling Report you submitted to this office on April 30, 1990. During my examination of your proof, an error has been detected that needs to be corrected before the final processing of the proof.

You indicate the total rate of diversion to be .19 cfs. If that is indeed the case, the drilling permit fee that should have been paid was \$100. The permit indicates you paid \$10 which leaves a balance due of \$90.

We apologize for the error made at that time. I will hold your proof due notice for 30 days without action. Please submit the additional \$90 before that time. As soon as I receive the additional fee, I will complete my examination and begin the licensing process.

If you have any questions or if I can be of further assistance, please feel free to contact me.

Sincerely,

Karen Gustafson
Karen L. Gustafson
Secretary, Records Manager

Enclosures

DEC 26 1991

Drilling Permit No. 123-88-2-32
Water Permit No. N/A
Injection Permit No. N/A

State of Idaho
Department of Water Resources

DRILLING PERMIT

(Authorizing Construction of a Well)*

1. Applicant Ray Sano
2. Address 10436 Lady Brook Dr.
Boise Id. 83702

(☒ Well Owner () Well Operator () Other, specify _____)

3. Water right permit no. N/A; Injection well permit no. N/A
4. Proposed well location 1/4 NE 1/4 SW 1/4, or Gov't lot No. _____,
Sec. 32, Twp. 5N, Rge. 1E, County Ada,
Lot, block and subdivision _____

5. Proposed use of well: (Check all that apply)
(☒ Domestic () Stockwater () Monitoring
() Irrigation () Industrial () Municipal
() Injection () Other, Specify _____)

6. Well construction information:
(☒ New well () Deepen () Replace
Proposed surface diameter 10" Proposed depth 170'

Anticipated bottom hole temperature:

- (☒ 85°F or less (Cold water well)
() 85°F to 212°F (Low temp. geothermal well)
() 212°F or more (Geothermal well)

7. Anticipated construction start date 4/4/88
8. Well Driller (if known) Boise Valley Pump Murphy #207
Address Boise Id.
Date 7/7/88 Applicant's signature Ray Sano
Title owner

UNRECORDED

ACTION OF IDWR

(☒) Approved () Denied

The approval of this permit authorizes the construction of a well as described on this application subject to the conditions on this permit.

GENERAL CONDITIONS:

1. The well must be constructed in compliance with the applicable statutes, specific conditions of approval shown on the water right permit, injection well permit, transfer or amendment and the rules and regulations of the Department for water appropriation, injection wells and well construction standards.
2. This drilling permit is valid for two (2) months from its date of issuance for the start of construction and is valid for one (1) year from the date of issuance for completion of the well unless an extension has been granted.
3. The permit holder or his representative shall notify the Department ten (10) days prior to the start of construction unless good cause for later notification can be shown.
4. The well shall be constructed by a driller currently licensed in the State of Idaho who must maintain a copy of the drilling permit at the drilling site.
5. Issuance of this drilling permit does not authorize trespass on the land of another party.
6. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.

SPECIFIC CONDITIONS:

7. *Neat data. State shall be followed.*
8. *If warm water (85°F BWT) is encountered or depth shall be notified immediately.*

Dated this 4th day of April, 1988.

Signed

Title

John E. Beal
SECTION MANAGER
GROUNDWATER PROTECTION

Received by ng Fee \$10⁰⁰ Date 4-4-88

Receipt No. C000273 Construction start date March 1988

Construction start extension to DEC 26 1991

Extension approved by _____

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTUSE TYPEWRITER OR
BALLPOINT PENState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER Name <u>Ray Jasso</u> Address _____ Owner's Permit No. <u>63-H-2-32</u>		7. WATER LEVEL Static water level <u>82</u> feet below land surface Flowing? ☐ Yes ☒ No G.P.M. flow _____ Artesian closed-in pressure _____ p.s.i. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature <u>OF</u> Quality _____ Describe artesian or temperature zones below																																																					
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)		8. WELL TEST DATA ☒ Pump ☐ Baller ☐ Air ☐ Other _____ <table border="1"><thead><tr><th>Discharge G.P.M.</th><th>Pumping Level</th><th>Hours Pumped</th></tr></thead><tbody><tr><td><u>80 GPM</u></td><td><u>190</u></td><td><u>3 P.M.</u></td></tr><tr><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td></tr></tbody></table>		Discharge G.P.M.	Pumping Level	Hours Pumped	<u>80 GPM</u>	<u>190</u>	<u>3 P.M.</u>																																														
Discharge G.P.M.	Pumping Level	Hours Pumped																																																					
<u>80 GPM</u>	<u>190</u>	<u>3 P.M.</u>																																																					
3. PROPOSED USE ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type)		9. LITHOLOGIC LOG <table border="1"><thead><tr><th rowspan="2">Bore Diam.</th><th colspan="2">Depth</th><th rowspan="2">Material</th><th rowspan="2">Water Yes No</th></tr><tr><th>From</th><th>To</th></tr></thead><tbody><tr><td><u>10</u></td><td><u>0</u></td><td><u>3</u></td><td><u>Top soil</u></td><td>☒</td></tr><tr><td><u>3</u></td><td><u>3</u></td><td><u>18</u></td><td><u>Sandy silt</u></td><td>☒</td></tr><tr><td><u>18</u></td><td><u>18</u></td><td><u>67</u></td><td><u>Sandy Brown Sandy Clay</u></td><td>☒</td></tr><tr><td><u>67</u></td><td><u>67</u></td><td><u>93</u></td><td><u>Sandy Brown Sandy Clay</u></td><td>☒</td></tr><tr><td><u>93</u></td><td><u>93</u></td><td><u>106</u></td><td><u>Sandy Brown Clay</u></td><td>☒</td></tr><tr><td><u>106</u></td><td><u>106</u></td><td><u>116</u></td><td><u>Sandy</u></td><td>☒</td></tr><tr><td><u>116</u></td><td><u>116</u></td><td><u>120</u></td><td><u>Sandy Brown Clay</u></td><td>☒</td></tr><tr><td><u>120</u></td><td><u>120</u></td><td><u>144</u></td><td><u>Broken sand</u></td><td>☒</td></tr><tr><td><u>144</u></td><td><u>144</u></td><td><u>165</u></td><td><u>Coarse sand & pea gravel</u></td><td>☒</td></tr></tbody></table>		Bore Diam.	Depth		Material	Water Yes No	From	To	<u>10</u>	<u>0</u>	<u>3</u>	<u>Top soil</u>	☒	<u>3</u>	<u>3</u>	<u>18</u>	<u>Sandy silt</u>	☒	<u>18</u>	<u>18</u>	<u>67</u>	<u>Sandy Brown Sandy Clay</u>	☒	<u>67</u>	<u>67</u>	<u>93</u>	<u>Sandy Brown Sandy Clay</u>	☒	<u>93</u>	<u>93</u>	<u>106</u>	<u>Sandy Brown Clay</u>	☒	<u>106</u>	<u>106</u>	<u>116</u>	<u>Sandy</u>	☒	<u>116</u>	<u>116</u>	<u>120</u>	<u>Sandy Brown Clay</u>	☒	<u>120</u>	<u>120</u>	<u>144</u>	<u>Broken sand</u>	☒	<u>144</u>	<u>144</u>	<u>165</u>	<u>Coarse sand & pea gravel</u>	☒
Bore Diam.	Depth		Material		Water Yes No																																																		
	From	To																																																					
<u>10</u>	<u>0</u>	<u>3</u>	<u>Top soil</u>	☒																																																			
<u>3</u>	<u>3</u>	<u>18</u>	<u>Sandy silt</u>	☒																																																			
<u>18</u>	<u>18</u>	<u>67</u>	<u>Sandy Brown Sandy Clay</u>	☒																																																			
<u>67</u>	<u>67</u>	<u>93</u>	<u>Sandy Brown Sandy Clay</u>	☒																																																			
<u>93</u>	<u>93</u>	<u>106</u>	<u>Sandy Brown Clay</u>	☒																																																			
<u>106</u>	<u>106</u>	<u>116</u>	<u>Sandy</u>	☒																																																			
<u>116</u>	<u>116</u>	<u>120</u>	<u>Sandy Brown Clay</u>	☒																																																			
<u>120</u>	<u>120</u>	<u>144</u>	<u>Broken sand</u>	☒																																																			
<u>144</u>	<u>144</u>	<u>165</u>	<u>Coarse sand & pea gravel</u>	☒																																																			
4. METHOD DRILLED ☐ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary ☒ Cable ☐ Dug ☐ Other _____		RECEIVED OCT 07 1988 Department of Water Resources																																																					
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____ <table border="1"><thead><tr><th>Thickness</th><th>Diameter</th><th>From</th><th>To</th></tr></thead><tbody><tr><td><u>250</u> inches</td><td><u>10</u> inches</td><td><u>1</u> feet</td><td><u>153</u> feet</td></tr><tr><td><u>250</u> inches</td><td><u>8</u> inches</td><td><u>143</u> feet</td><td><u>155</u> feet</td></tr><tr><td><u>250</u> inches</td><td><u>8</u> inches</td><td><u>143</u> feet</td><td><u>165</u> feet</td></tr></tbody></table> Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☒ Yes ☐ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation _____ inches by _____ inches <table border="1"><thead><tr><th>Number</th><th>From</th><th>To</th></tr></thead><tbody><tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr><tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr><tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr></tbody></table> Well screen installed? ☒ Yes ☐ No Manufacturer's name <u>Cook</u> <u>Standard Steel</u> Type _____ Model No. _____ Diameter <u>8</u> Slot size <u>35</u> Set from <u>155</u> feet to <u>163</u> feet Diameter _____ Slot size _____ Set from _____ feet to _____ feet Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____ Placed from _____ feet to _____ feet Surface seal depth <u>20</u> Material used in seal: ☐ Cement grout ☐ Bentonite ☒ Pudding clay ☐ _____ Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☐ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld _____ ☐ Cemented between strata Describe access port _____				Thickness	Diameter	From	To	<u>250</u> inches	<u>10</u> inches	<u>1</u> feet	<u>153</u> feet	<u>250</u> inches	<u>8</u> inches	<u>143</u> feet	<u>155</u> feet	<u>250</u> inches	<u>8</u> inches	<u>143</u> feet	<u>165</u> feet	Number	From	To	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet																								
Thickness	Diameter			From	To																																																		
<u>250</u> inches	<u>10</u> inches			<u>1</u> feet	<u>153</u> feet																																																		
<u>250</u> inches	<u>8</u> inches	<u>143</u> feet	<u>155</u> feet																																																				
<u>250</u> inches	<u>8</u> inches	<u>143</u> feet	<u>165</u> feet																																																				
Number	From	To																																																					
_____ perforations	_____ feet	_____ feet																																																					
_____ perforations	_____ feet	_____ feet																																																					
_____ perforations	_____ feet	_____ feet																																																					
6. LOCATION OF WELL Sketch map location must agree with written location. <table border="1"><tr><td>N</td><td></td><td></td></tr><tr><td>W</td><td></td><td>E</td></tr><tr><td></td><td></td><td></td></tr><tr><td>S</td><td></td><td></td></tr></table> Subdivision Name _____ Lot No. _____ Block No. _____ County <u>Ada</u> <u>NE</u> & <u>SW</u> & Sec. <u>32</u> , T. <u>5</u> N. & R. <u>1</u> E. & W.		N			W		E				S			11. DRILLERS CERTIFICATION I/We certify that all minimum well construction standards were complied with at the time the rig was removed. Firm Name <u>Boise Valley Pump & Drilling</u> Firm No. <u>207</u> Address <u>2950 S. Garden</u> Date <u>5/11/88</u> Signed by (Firm Official) <u>Don J. M. [Signature]</u> and (Operator) <u>Harry R. Fulton</u>																																									
N																																																							
W		E																																																					
S																																																							
10. Work started <u>4/12/88</u> finished <u>5/3/88</u>																																																							

USE ADDITIONAL SHEETS IF NECESSARY - FORWARD THE WHITE COPY TO THE DEPARTMENT

S T A T E O F I D A H O
D E P A R T M E N T O F W A T E R R E S O U R C E S

Statehouse
Boise, Idaho 83720
(208) 327-7900
December 15, 1989

RAY V. SASSO
LYNNE SASSO
900 W. MEANDER CT.
EAGLE, ID 83616

P E R M I T A P P R O V A L N O T I C E

RE: PERMIT NO. P63-10965

Dear Permit Holder:

Enclosed is a copy of your approved application for permit. We direct your attention to the conditions of approval on the final page.

You should be aware that the groundwater you propose to divert is located within a drainage basin where surface waters are regulated during the months of low flow. It is possible that diversion of groundwater may have an adverse impact on these surface water flows. Information available to us at this time does not warrant refusing to issue permits in your area, but we do caution that diversions of groundwater are not allowed to deplete flows available for surface water users with earlier priority dates. Siting your well as far from surface sources as possible and casing out upper water producing zones may reduce the potential of interference.

Section 42-235, Idaho Code, requires that a "drilling permit" must be obtained from the department for all wells constructed after July 1, 1987. A drilling permit is a separate permit that must be issued in addition to your permit to appropriate water. Commencement of well construction or diversion of water under your permit to appropriate water is prohibited unless a drilling permit is obtained.

We have enclosed a form entitled "Instructions for Proof of Beneficial Use". Please read the instructions carefully since you must take further action to develop this permit. Also enclosed for your convenience is a form entitled "Proof of

Beneficial Use" that must be submitted to the Department when your project is completed. If development is complete, you may submit proof of beneficial use immediately.

Sincerely,

GARY SPACKMAN, Supervisor
Water Right Permits Section

GS: SC
Enclosures

RECEIVED
OCT 16 1989

The Idaho Statesman

P.O. BOX 40, BOISE, IDAHO 83707

Department of Water Resources
Western Regional Office

LEGAL ADVERTISING INVOICE

Amount Due

265.44

Account Name		Account Number	
Department of Water Resources - Western		47628	
Address		City/State	Zip
2735 Airport Way		Boise, Idaho	83705
Ordered By	P.O. Number	Rate	Run Dates
Gail Garrett		63-10965	1989
Identification		October 5, 12	Estimated Inches
Notice of Application for			Real Inches
			Legal Number
			3800

Number of Affidavits
Requested

1

NOTICE OF APPLICATION FOR WATER RIGHT

The following applications have
been filed to appropriate the public
waters of the State of Idaho:

63-10891

Serra, John R.
Serra, Nola R.
3905 Sandbar Ln.
Eagle, ID 83616
Source: Groundwater
Diversion Pt: SENE Sec 32 T 05N
R 01E
Use: Irrigation (.150 CFS)
Use: Domestic (.040 CFS)
Date Filed: 8/07/1989
In: T05N R01E S32 SENE
5.0 ACRES TOTAL

63-10905

Junnilla, William E.
Junnilla, Renae M.
4615 1/2 N. Eagle Rd.
Meridian, ID 83642
Source: Groundwater
Diversion Pt: NENE Sec 32 T 04N
R 01E
Use: Irrigation (.030 CFS)
Use: Stockwater (.020 CFS)
Use: Domestic (.040 CFS)
Date Filed: 8/18/1989
In: T04N R01E S32 NENE
1.0 ACRES TOTAL

63-10934

Kaplan, Dean W.
Kaplan, Cynthia A.
10220 Stardust
Boise, ID 83709
Source: Groundwater
Diversion Pt: NWNW Sec 14 T
03N R 01E
Use: Irrigation (.020 CFS)
Date Filed: 8/29/1989
In: T03N R01E S14 NWNW
0.5 ACRES TOTAL

63-10957

Sedlacek, Randy A.
Sedlacek, Joyce D.
4290 Perkins St.
Meridian, ID 83642
Source: Groundwater
Diversion Pt: SESW Sec 22 T 03N
R 01W
Use: Irrigation (.030 CFS)
Date Filed: 9/06/1989
In: T03N R01W S22 SESW
1.0 ACRES TOTAL

63-10959

St. Matthews Catholic Church
P.O. Box 296
Eagle, ID 83616
Source: Groundwater
Diversion Pt: NWSW Sec 9 T 04N
R 01E
Use: Domestic (.100 CFS)
Date Filed: 9/07/1989
In: T04N R01E S09 NWSW

63-10960

Wiscombe, Phillip W.
Wiscombe, LaVonne
4400 Hubbard Rd.
Kuna, ID 83634
Source: Groundwater
Diversion Pt: NESW Sec 10 T 02N
R 01W
Use: Irrigation (.800 CFS)
Use: Stockwater (.050 CFS)
Date Filed: 9/07/1989
In: T02N R01W S10 NESW
40.0 ACRES TOTAL

Sasso, Ray V.
Sasso, Lynne
900 W. Meander Ct.
Eagle, ID 83616
Source: Groundwater
Diversion Pt: NESW Sec 32 T 05N
R 01E
Use: Domestic (.020 CFS)
Use: Stockwater (.020 CFS)
Use: Irrigation (.150 CFS)
Date Filed: 9/08/1989
In: T05N R01E S32 NESW
5.0 ACRES TOTAL

63-10985

Morris, William E.
Morris, Camille J.
4525 Ginger Creek Dr.
Meridian, ID 83642
Source: Groundwater
Diversion Pt: NWNE Sec 33 T
04N R 01E
Use: Irrigation (.015 CFS)
Date Filed: 9/05/1989
In: T04N R01E S33 NESE
0.5 ACRES TOTAL

63-10986

Ellis, Ted
Ellis, Valerie
2820 E. Ustick Rd.
Meridian, ID 83642
Source: Groundwater

LEGAL NOTICES

Diversion Pt: SWSE Sec 32 T
04N R 01E
Use: Irrigation (.030 CFS)
Date Filed: 9/01/1989
In: T04N R01E S32 SESE
1.0 ACRES TOTAL

63-10987

Schmillen, Kenneth
Schmillen, Diane
427 Linder Ave.
Kuna, ID 83634
Source: Groundwater
Diversion Pt: NENE Sec 34 T 03N
R 01W
Use: Irrigation (.100 CFS)
Use: Stockwater (.020 CFS)
Use: Domestic (.040 CFS)
Date Filed: 8/31/1989
In: T03N R01W S34 NENE
5.0 ACRES TOTAL

63-10988

Watson, Wayne H.
Watson, Barbara A.
5730 N. Five Mile Rd.
Boise, ID 83704
Source: Groundwater
Diversion Pt: SWNW Sec 26 T 04N
R 01E
Use: Irrigation (.030 CFS)
Date Filed: 8/29/1989
In: T04N R01E S26 SWNW
1.0 ACRES TOTAL

63-10990

George, Judy J.
George, Robert C.
3192 Heritage Ave.
Boise, ID 83709
Source: Groundwater
Diversion Pt: NWNW Sec 27 T
03N R 01E
Use: Irrigation (.020 CFS)
Use: Stockwater (.020 CFS)
Use: Domestic (.040 CFS)
Date Filed: 8/28/1989
In: T03N R01E S27 NWNW
1.0 ACRES TOTAL

63-10991

Miller, Anthony
10597 W. Kuna Mora Rd.
Kuna, ID 83634
Source: Groundwater
Diversion Pt: Lot 1 (NENE) Sec T
01N R 01E
Diversion Pt: Lot 1 NESE Sec 3 T
01N R 01E
Diversion Pt: Lot 1 NWSE Sec 3 T
01N R 01E
Use: Irrigation (.990 CFS)
Date Filed: 8/28/1989
In: T01N R01E S03 NESW
SWSE SESE
73.0 ACRES TOTAL

63-10992
Camie, Daniel
5669 Fieldcrest Dr.
Boise, ID 83704
Source: Groundwater
Diversion Pt: SWNW Sec 26 T 04N
R 01E
Use: Irrigation (.030 CFS)
Date Filed: 8/29/1989
In: T04N R01E S26 SWNW
1.0 ACRES TOTAL

63-10993
McKeon, Deborah C.
McKeon, Michael G.
2106 Almaden Dr.
Meridian, ID 83642
Source: Groundwater
Diversion Pt: SENWSE Sec 23 T
04 N R 01W
Use: Irrigation (.060 CFS)
Use: Domestic (.040 CFS)
Date Filed: 9/06/1989
In: T04N R01W S23 NWSE
2.0 ACRES TOTAL

63-10995
St. Mark's Roman Catholic
Church
7503 Northview
Boise, ID 83704
Source: Groundwater
Diversion Pt: NESE Sec 1 T 03N R
01E
Use: Irrigation (.120 CFS)
Date Filed: 9/13/1989
In: T03N R01E S01 NESE
4.0 ACRES TOTAL

63-10996
Alleman, Fred L.
Alleman, Ruby J.
8465 Golse Dr.
Boise, ID 83704
Source: Groundwater
Diversion Pt: NWSWNE Sec 15 T
03N R 02E
Use: Irrigation (.030 CFS)
Date Filed: 9/14/1989
In: T03N R02E S15 SWNE
1.0 ACRES TOTAL

63-10997
Pope, Lyle H.
Pope, Judy
901 W. Meander Ct.
Eagle, ID 83616
Source: Groundwater
Diversion Pt: SENESW Sec 32 T
05N R 01E
Use: Irrigation (.140 CFS)
Date Filed: 9/08/1989
In: T05N R01E S32 NESW
4.5 ACRES TOTAL

The permits will be subject to all
prior water rights. Protests must be
filed with the Director, Dept. of Wa-
ter Resources, Western Region,
2735 Airport Way, Boise, Idaho
83705 on or before OCTOBER 23,
1989.

R. KEITH HIGGINSON
Director
Pub. Oct. 5, 12, 1989 3800

RECEIVED

DEC 19 1989

63-10965

SASSO, RAY V.
SASSO, LYNNE
900 W. MEANDER CT.
EAGLE, ID 83616

Source: GROUNDWATER

Diversion Pt: NESW Sec 32 T 05N R 01E

Use: DOMESTIC	(.020 CFS)
STOCKWATER	(.020 CFS)
IRRIGATION	(.150 CFS)

Date Filed: 9/08/1989

In: T05N R01E S32 NESW

5.0 ACRES TOTAL

MICROFILMED

DEC 19 1989