

47-2352

G-29655

City Engineer
City Hall
Twin Falls, Idaho

APPLICATION FOR PERMIT

To Appropriate the Subterranean Waters of The State of Idaho

Application No. G- 37660
Permit No. G- 29655
District No.

1. Name of Applicant: City of Twin Falls

Postoffice address: Twin Falls

County: Twin Falls

State: Idaho

2. Quantity of water claimed: $1\frac{1}{2}$ cubic feet per second

(a) Rate of withdrawal in cubic feet per second
Miners' inches

or Idaho

or gallons per minute

(b) Annual withdrawal in acre feet per annum

3. Source of water supply: Subterranean

4. Location of point of diversion or well is in the NE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 8

Twp. 11 S , Rge. 17 E , B.M., County of Twin Falls

5. Water is to be used for: Domestic use, fire fighting, lawn sprinkling at municipal airport

6. If for municipal, industrial or recreational purposes, give:

(a) Point of use of water is in the ~~NE~~ of the E $\frac{1}{2}$ $\frac{1}{4}$ of Section 8 , Twp. 11 S
Rge. 17 E. , B.M.

(b) Waste water or sewage effluent is to be returned to ground and ditches

at a point in the ~~NE~~ of the E $\frac{1}{2}$ $\frac{1}{4}$ of Section 8 , Twp. 11 S , Rge. 17 E. , B.M.

7. Kind of works: Well pumping unit with 10,000 gallon storage



8. Estimated cost of works: \$ 15,000

9. (a) Is reservoir to be used? covered concrete

(b) Capacity of reservoir: 10,000 gallons

10. The time required for the completion of such work and complete application of the water to the proposed use is 5 years.

11. If applicant is a corporation, give:

I. (a) Date and place of incorporation:

(b) Amount of capital stock: \$

(c) Amount paid in: \$

(d) Names and addresses of directors:

II. The financial resources of the applicant are (a) Cash on hand: \$

(b) Treasury stock:

(c) Bonds to be issued:

(d) Other resources:

12. The land to be irrigated is described in the following tabulation:

13. Existing water rights and/or valid permits appurtenant to the lands to be irrigated are:

(a) $1\frac{1}{2}$ (cubic feet per second, ~~inches or gallons per minute~~) of the water herein applied for is to be supplemental to the existing water rights.

(b) 0 (cubic feet per second, inches or gallons per minute) is for new lands.

R 17E

T
11
S

7

8

P.D.

2
2

2
2
4

Subdivisions 2

AREA 4 acrs.

.08 cts. or 4 in. Irrigation
.02 cts. or 1 " Domestic

1.40 cts. 70 min. Fire Protection

1.50 cts. Total.

Affidavit of Publication

Nº 10029

STATE OF IDAHO,
COUNTY OF TWIN FALLS

ss.

SEP 16 1963

Department of Reclamation

I, Maale F. Clark, being first duly sworn upon

oath depose and say that I am Principal Clerk of the TIMES-NEWS, published daily, except Saturday, at Twin Falls, Idaho, and do solemnly swear that a copy of the notice of advertisement, as per clipping attached, was published in the regular and entire issue of said newspaper, and not in any supplement thereof, for four consecutive Thursdays, commencing with the issue dated August 1, 1963, and ending with the issue dated August 22, 1963.

And I do further certify that said newspaper is a consolidation, effective February 16, 1942, of the Idaho Evening Times, published theretofore daily except Sunday, and the Twin Falls News, published theretofore daily except Monday, both of which newspapers prior to consolidation had been published under said names in said city and county continuously and uninterruptedly during a period of more than twelve consecutive months, and said TIMES-NEWS, since such consolidation, has been published as a daily newspaper except Saturday, under said name in said city and county continuously and uninterruptedly.

And I further certify that pursuant to Section 60-108 Idaho Code, Thursday of each week has been designated as the day on which legal notice by law or by order of any court of competent jurisdiction within the state of Idaho, to be published weekly, will be published; and that at the head of the editorial column of said combined newspapers, and in each issue thereof, Thursday is announced as the day on which said legal notices will be published.

Maale F. Clark
Subscribed and sworn to before me this 23rd day of

August, 1963.

A. Wistgen
Notary Public in and for the County of Twin Falls,
State of Idaho, residing at Twin Falls, Idaho.

NOTICE OF PROOF OF COMPLETION OF WORKS AND APPLICATION OF WATER TO BENEFICIAL USE

Notice is hereby given that at 4:00 P.M., on the 12 day of September 1963, at Twin Falls, County of Twin Falls, State of Idaho, before Mrs. Constance J. Leiser, Notary Public, at City Hall City of Twin Falls, proof will be submitted of the completion of works for the diversion of 1.5 cubic feet per second of underground water from a well, and of the application to beneficial use of said water, in accordance with the terms and conditions of Permit No. G29655, heretofore issued by the Department of Reclamation of the State of Idaho.

1. The name and postoffice address of the person or corporation holding said permit is City of Twin Falls, Twin Falls, Idaho.

2. Said works of diversion will be fully completed on the date set for such completion, and the amount of water which said works are capable of conveying to the place of use is 1.5 cubic feet per second.

3. The use to which said water has been applied is domestic purposes, and the amount applied to beneficial use is 1.5 cubic feet per second.


4. The point of diversion of said water is NE $\frac{1}{4}$, NE $\frac{1}{4}$, Sec. 8 Twp. 11 S., Rge 17 E., B. M.

5. The place where said water is used is Municipal Airport.

6. The date of priority which said user is prepared to establish is April 25, 1961.

CARL E. TAPPAN
Acting State Reclamation
Engineer.

Publish: Aug. 1, 8, 15, 22, 1963.



Permit Map No. 29655
As Approved APR 28 1961
GEO. N. CARTER
Reclamation Engineer

State of Idaho
License and Certificate of Water Right

Water License No. G-29655

Amount 1.5 c.f.s.

Water District No.

Priority April 25, 1961

THIS IS TO CERTIFY that CITY OF TWIN FALLS
of Twin Falls, Idaho, made application for a permit to appropriate the
public waters of the State of Idaho, dated April 25, 1961; that Permit No. G-29655
was issued under said application; that Certificate of Completion of works, with a carrying capacity of
1.5 second feet, was issued thereunder on December 13, 1963, showing that said works
were completed on the 12th day of September, 1963; and that on the 12th
day of September, 1963,

CITY OF TWIN FALLS

of Twin Falls, State of Idaho, made proof to the satisfaction of the
State Reclamation Engineer of Idaho, of the right to use the waters of a well
, a tributary of subterranean flow, for the purpose of domestic, fire fighting,
port lawn sprinkling at
municipal airport Use Permit No. G-29655 of the Department of Reclamation
and that said right to the use of said waters has been perfected in accordance with the laws of Idaho,
and is hereby confirmed by the State Reclamation Engineer of Idaho and entered of record in Volume
12 of Licenses at page 7794, on the 13 day of December, 1963;

The right hereby confirmed dates from April 25, 1961;

The Point of Diversion is located

in the NE 1/4 NE 1/4, Sec. 8, Tp. 11 S. R. 17 E., B. M. County Twin Falls

That the amount of water to which such right is entitled and hereby confirmed, for the purposes
aforesaid, is limited to an amount actually needed and beneficially used for said purposes, and shall
not exceed 1.5 cubic feet per second.

Description and location of use:

Twp.	Range	Sec.	Forty-acre Tract	No. Acres Described in Permit	No. Acres Actually Irrigated
11 S.	17 E.	8	NE 1/4 NE 1/4 SE 1/4 NE 1/4		2 2
			Total number of acres to be irrigated:		4

The right to the use of the water aforesaid hereby confirmed is restricted to the lands or place
of use herein described, as provided by the laws of Idaho.

WITNESS the seal and signature of the State Reclamation Engineer, affixed at Boise, Idaho, this

13th day of December, 1963.

/s/ RALPH W. THOMAS
Deputy State Reclamation Engineer.

(SEAL)

17 2352

47-2352

G-29655


City Engineer
City Hall
Twin Falls, Idaho

APPLICATION FOR PERMIT

To Appropriate the Subterranean Waters of The State of Idaho

Application No. G- 37660
Permit No. G- 29655
District No.

1. Name of Applicant: City of Twin Falls
Postoffice address: Twin Falls County: Twin Falls State: Idaho
2. Quantity of water claimed: $1\frac{1}{2}$ cubic feet per second
 - (a) Rate of withdrawal in cubic feet per second or Idaho
Miners' inches or gallons per minute
 - (b) Annual withdrawal in acre feet per annum
3. Source of water supply: Subterranean
4. Location of point of diversion or well is in the NE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 8
Twp. 11 S, Rge. 17 E, B.M., County of Twin Falls
5. Water is to be used for: Domestic use, fire fighting, lawn sprinkling at municipal airport
6. If for municipal, industrial or recreational purposes, give:
 - (a) Point of use of water is in the ~~NE~~ of the E $\frac{1}{2}$ $\frac{1}{4}$ of Section 8, Twp. 11 S
Rge. 17 E., B.M.
 - (b) Waste water or sewage effluent is to be returned to ground and ditches
at a point in the ~~NE~~ of the E $\frac{1}{2}$ ~~NE~~ of Section 8, Twp. 11 S, Rge. 17 E., B.M.
7. Kind of works: Well pumping unit with 10,000 gallon storage
8. Estimated cost of works: \$15,000
9. (a) Is reservoir to be used? covered concrete
(b) Capacity of reservoir: 10,000 gallons
10. The time required for the completion of such work and complete application of the water to the proposed use is 5 years.
11. If applicant is a corporation, give:
 - I. (a) Date and place of incorporation:
(b) Amount of capital stock: \$ (c) Amount paid in: \$
(d) Names and addresses of directors:
 - II. The financial resources of the applicant are (a) Cash on hand: \$
(b) Treasury stock: (c) Bonds to be issued:
(d) Other resources:
12. The land to be irrigated is described in the following tabulation:
13. Existing water rights and/or valid permits appurtenant to the lands to be irrigated are:
 - (a) $1\frac{1}{2}$ (cubic feet per second, ~~inches or gallons per minute~~) of the water herein applied for is to be supplemental to the existing water rights.
 - (b) 0 (cubic feet per second, inches or gallons per minute) is for new lands.



Remarks:

BE IT KNOWN THAT The undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

City of Twin Falls, Idaho Applicant.

By

s/ Paul E. Newton . P.E. Agent.
City Engineer

Date of first receipt at Department of Reclamation: 8:30 A.M. April 25, 1961

Returned to applicant for correction:

Corrected application received:

Approval of State Reclamation Engineer

The number of this permit is G— 29655

Recorded in Book 104 Page 29655 Approved April 28, 1961

This is to certify that I have examined the within application for a permit to appropriate the public waters of the State of Idaho, and hereby approve the same, subject to the following limitations and conditions:

Bond in the sum of \$ to be filed on or before

Work to begin on or before

and to continue diligently and uninterruptedly to completion, unless

temporarily interrupted by circumstances over which the permit holder has no control.

One-fifth of the work above specified to be completed on or before October 28, 1963

The whole of said work to be completed and beneficial use of water appropriated in accordance herewith, to be made and proofs offered on or before April 28, 1966

Witness my hand this 28th day of April, 1961

s/ GEO. N. CARTER
STATE RECLAMATION ENGINEER.

IN TESTIMONY WHEREOF, We, ROBERT E. SMYLLIE, Governor of the State of Idaho, and ARNOLD WILLIAMS, Secretary of State of the State of Idaho, have caused this instrument to be executed in the name of the State of Idaho, and caused the Great Seal of the State of Idaho to be hereunto affixed, this 28th day of April, 1961.

Countersigned:

STATE OF IDAHO

(SEAL)

By s/ ARNOLD WILLIAMS

Secretary of State.

By s/ ROBERT E. SMYLLIE

Governor

12.

Twp.	Range	Sec.	NE $\frac{1}{4}$	NW $\frac{1}{4}$	SW $\frac{1}{4}$	SE $\frac{1}{4}$	Totals
			NE $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$	NE $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$	NE $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$	NE $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$	
			Permit No. G-29655 CERTIFICATE OF COMPLETION OF WORKS				
			TO ALL WHOM IT MAY CONCERN:				
			This is to certify that CITY OF TWIN FALLS of Twin Falls, County of Twin Falls, and State of Idaho, the holder of Permit No. G-29655, issued upon application No. G-37660 bearing date of priority of April 25, 1961, authorizing the diversion of 1.5 second feet of waters of a well County of Twin Falls, State of Idaho, for domestic, fire fighting, lawn sprinkling at municipal airport purposes, has fully complied with the provisions of the laws of the State of Idaho relating to the proof of completion of the works of diversion set out and described in said Permit; that said works are adequate for diverting and conveying to the place of intended use 1.5 second feet of the waters of a well from subterranean flow that the point of diversion of said waters NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 8, T. 11 S., R. 17 E., B.M. and that the lands proposed to be irrigated by the use of said water are described as follows, to-wit: 4 acres in E $\frac{1}{2}$ NE $\frac{1}{4}$ Sec. 8, T. 11 S., R. 17 E., B.M.				
			Witness my hand this 13th day of December, A. D. 1963. /s/ RALPH W. THOMAS Deputy State Reclamation Engineer				
			Proof of Completion of Works Made: September 12, 1963				
			LICENSE ISSUED FOR 1.5 SEC. FT. Page 7794				

December 13, 1963

Permit No. ~~0-29655~~; 0-30335;
0-31098

Paul E. Newton
City Engineer
City Hall
Twin Falls, Idaho

Dear Mr. Newton:

Enclosed are Licenses and Certificates on the above
numbered permits, which have been recorded in this office.

Also enclosed is departmental receipt in the amount
of \$29.00 covering fees.

Very truly yours,

CARL E. TAPPAN
State Reclamation Engineer

By:

(Mrs.) Edna P. Rule
Chief Clerk

EPR:ew

Enc. 6 certificates
receipt

29655

December 10, 1963

Re: Permits No. G-30335; 31098
29655

City of Twin Falls
Constance J. Leiser
Twin Falls, Idaho

Dear Madam:

Enclosed as requested, is the signed and notarized
voucher in reference to the above noted permits.

Very truly yours,

CARL E. TAPPAN
State Reclamation Engineer

By:

(Mrs.) Edna P. Rule
Chief Clerk

EPR:ew

Enc. voucher

2 9655

State of Idaho
DEPARTMENT OF RECLAMATION

Boise, Idaho
December 4, 1963

Re: Permit No. G-29655

Paul E. Newton
City Engineer
City Hall
Twin Falls, Idaho

Dear Mr. Newton:

Our field engineer's report on his inspection of proof of completion of works and application of water to beneficial use under the terms of Permit No. G-29655 shows the well is ~~(are)~~ capable of conveying ⁷⁵ miner's inches, or 1.5 c.f.s. of water for the irrigation of 4 acres domestic use and fire protection.

Upon receipt of the statutory fees, totaling \$ 9.00 , which consists of a Completion of Works fee of \$ ---- and License and Certificate of Water Right fee of \$ ----- - based at the rate of \$2.00 for each 40-acre subdivision - we will issue the Certificate of Completion of Works and the License and Certificate of Water Right confirming the right, with priority of April 25, 1961 to the use of 1.5 second feet of subterranean water with the point of diversion in the NE 1/4, Sec. 8 for domestic use, fire protection and irrigation of 4 acres in the E 1/4, Sec. 8, T. 11 S., R. 17 E., B.M.

Very truly yours,

CARL E. TAPPAN
State Reclamation Engineer
By

(Mrs.) Edna P. Rule
Chief Clerk

ELR:mr

29655

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE, IDAHO
REPORT OF ENGINEER

Permit No. 29655 ✓This proof is for Completion of Works & Beneficial Use In Water District No. _____

1. Name of applicant City of Twin Falls
2. Source of water supply: Subterranean
3. Location of point of diversion: Is in the NE 1/4 NE 1/4 of Section 8
T. 11 S R. 17 E B.M. County of Twin Falls

4. Describe works as they exist, giving dimensions and capacities of same: SBH GEMIN

"WVS 915284, Layne + Boulder Pump #29241, 8" x 400' Column.
8" discharge to 20' pipe to 10000 gallon Concrete Res. automatic flood
control operation to pump.

5. Water is used for: Domestic, fire fighting, lawn sprinkling at Municipal airport.6. State whether or not water has been turned into works of diversion: yes.

7. List legal subdivisions of lands to be irrigated. If proof is for beneficial use, give exact number of acres under cultivation in each forty-acre tract. (Describe manner and place of use if other than irrigation):

POINT OF USE: E 1/2 Sec. 8., Twp. 11 S., Rge. 17 E.B.M.Approx. 4 acres lawn in NE 1/4 Sec. 8

(Submit map on attached plat, showing location and details of above description.)

8. What large stream would the water here appropriated finally reach? ✓Remarks: Mr. Paul E. Newton City Eng. along

Discharge figured by Mr. Newton at time of installation. He used
a known area in 10000 gal Res. and the amount of time it took
to fill to that capacity.

No measurement made.This examination was made on the 15th day of November, 19 63

(Signed)

L. J. Johnson

Examiner.

29655

Paul E. Newton, City Engineer
City Hall
Twin Falls, Idaho
Permit No. G-29655

5' 100' sag at Res. Francis
536M 7 1/2 USMoles Br. blue 12'
600' 40' H.C. to VV3 9.4' 1/2' 1/2'

Examination for Completion of Works & Beneficial Use

County.....Twin Falls

Sec. 8 T. 11S R. 17 E BM

Quantity: 1.5 c.f.s.

Source: Subterranean

P.D.: NENE, Sec. 8 T. 11S, R. 17E, BM

Use: Domestic, fire-fighting, lawn
sprinkling at municipal airport

Filed: April 25, 1961

Due: April 28, 1966

Extension: —

Completion of Works: —

Other Rights: none

Run to 7000' from
P. main line.
Colum 100' x 8"
Depth 607' x 16" - 12"
Reduced to 12" at 410'
Cased 24" x 16"

INSTRUCTIONS TO EXAMINERS

1. Always carefully note the location of the point of diversion and accurately plat same.
2. When proof is for beneficial use, carefully check up the number of acres actually irrigated in each forty and accurately plat same.
3. Make a map showing the correct location of streams and ditches, and the irrigated lands, and any adjacent permanent landmarks, such as towns, lakes, large streams and public roads.
4. If any unusual conditions are discovered, make plain statement of them under remarks.
5. Always see the holder, if possible, and go over the whole ground with him and make your report only upon actual existing facts and conditions.
6. Give general characteristics of soils, topography, and crops raised.

RECEIVED
NOV 27 1963


Department of Reclamation

29655

R 17E

T
11
S

7



2
2
4

Subdivisions 2

AREA

4 acs.

.08 cts. or 4 in.

.02 cts. or 1 in.

Q

1.40 cts. 7000

1.5 cts. Total.

Drainage
Drainage
Fence Protection

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE

REPORT OF ENGINEER

PERMIT NO. G-29655

REPORT ON PROOF OF Completion of Works & Beneficial Use

Paul E. Newton, City Engineer
City Hall, Twin Falls, Idaho

50 HP G.E. Motor #WVJ915284, Layne- Bowler Pump #29241. 400' X 8" column. 20' X 8" free flow discharge pipe to a 10,000 gallon, concrete reservoir. Automatic float controll in reservoir turns well pump on and off. Two centrifugal pumps pump from the reservoir into a 7,000 gallon pressure storage tank. (1) is a 7½ HP U.S. Motor and Berkeley centrifugal pump unit. (2) is a 40 HP Motor and 4" X 3" centrifugal pump unit. WELL— 607' X 16" - 12". (410' X 16" - 197' X 12"). 24' X 16" casing.

- (1) 7½HP pump is used for ordinary use around Terminal and hanger buildings to maintain 60 -80 lb. pressure. Pump rated at 50 GPM.
 - (2) 40 HP Pump is a standby for fire protection and irrigation. This pump cuts in when pressure drops below 60 lbs. Pump rated at 600 GPM.
-

1M April 1962

~~XXXXXXXXXX~~

September 17, 1963

Re: Permit No.
S. C-29655
C-30335 & C-31098

Mr. Paul E. Newton
City Engineer
City Hall
Twin Falls, Idaho

We acknowledge receipt of the depositions of holder and two witnesses, also affidavit of publication in the Times-News, all submitted in proof of completion of works and beneficial use on Permit No. S. C-29655, C-30335 & C-31098.

Before final action is taken in the matter, the law requires that a field examination be made by an engineer from this department.

We cannot tell just when this examination will be made, but our field engineer will try and contact you at the time he makes the examination so that arrangements may be made to show him over the grounds.

Very truly yours,

~~XXXXXXXXXXXX~~
GEO. N. CARTER
State Reclamation Engineer

By:

(Mrs.) Edna P. Rule
Chief Clerk

EPR:

2 9655

To: State of Idaho, Department of Reclamation
Attention: Mrs. Edna L. Rule, Chief Clerk
State House, Boise, Idaho

P.O. No. 8373 C

City of Twin Falls, Idaho
PURCHASE ORDER

DELIVER TO: City of Twin Falls, Idaho Department DATE December 5, 1963
ADDRESS: _____
VIA: _____ On or Before _____

QUANTITY	UNIT	DESCRIPTION	CHARGE ACCOUNT	UNIT PRICE	AMOUNT
		Fees in connection with application of water to beneficial use, permits Nos. G-30335; G-31098; G-29655	8f Imp 3		29.00
		TOTAL AMOUNT			

Requested By: _____
Department Head

Approved By: *H. P. Darrick*
Purchasing Officer

SIGNATURE OF PURCHASING OFFICER NOT REQUIRED ON ORDERS UNDER \$25.00

10M-961

29655

Affidavit of Publication

No. 10029

STATE OF IDAHO,
COUNTY OF TWIN FALLS

ss.

NOTICE OF PROOF OF COMPLETION OF WORKS AND APPLICATION OF WATER TO BENEFICIAL USE

Notice is hereby given that at 4:00 P.M., on the 12 day of September 1963, at Twin Falls, County of Twin Falls, State of Idaho, before Mrs. Constantine J. Lister, Notary Public, at City Hall, City of Twin Falls, proof will be submitted of the completion of works for the diversion of 1.5 cubic feet per second of underground water from a well, and of the application to beneficial use of said water, in accordance with the terms and conditions of Permit No. C29655, heretofore issued by the Department of Reclamation of the State of Idaho.

1. The name and postoffice address of the person or corporation holding said permit is City of Twin Falls, Twin Falls, Idaho.

2. Said works of diversion will be fully completed on the date set for such completion, and the amount of water which said works are capable of conveying to the place of use is 1.5 cubic feet per second.

3. The use to which said water has been applied is domestic purposes, and the amount applied to beneficial use is 1.5 cubic feet per second.

4. The point of diversion of said water is NE $\frac{1}{4}$, NE $\frac{1}{4}$, Sec. 8 Twp. 11 S., Rge 17 E., B. M.

5. The place where said water is used is Municipal Airport.

6. The date of priority which said user is prepared to establish is April 25, 1961.

CARL E. TAPPAN
Acting State Reclamation
Engineer.

Published: Aug. 1, 8, 15, 22, 1963.

I, Mable F. Clark, Reclamation, being first duly sworn upon

oath depose and say that I am Municipal Clerk of the TIMES-NEWS, published daily, except Saturday, at Twin Falls, Idaho, and do solemnly swear that a copy of the notice of advertisement, as per clipping attached, was published in the regular and entire issue of said newspaper, and not in any supplement thereof, for four

consecutive Thursdays, commencing with the issue dated August 1, 1963, and ending with the issue dated August 22, 1963.

And I do further certify that said newspaper is a consolidation, effective February 16, 1942, of the Idaho Evening Times, published theretofore daily except Sunday, and the Twin Falls News, published theretofore daily except Monday, both of which newspapers prior to consolidation had been published under said names in said city and county continuously and uninterruptedly during a period of more than twelve consecutive months, and said TIMES-NEWS, since such consolidation, has been published as a daily newspaper except Saturday, under said name in said city and county continuously and uninterruptedly.

And I further certify that pursuant to Section 60-108 Idaho Code, Thursday of each week has been designated as the day on which legal notice by law or by order of any court of competent jurisdiction within the state of Idaho, to be published weekly, will be published; and that at the head of the editorial column of said combined newspapers, and in each issue thereof, Thursday is announced as the day on which said legal notices will be published.

Subscribed and sworn to before me this 23rd day of

August, 1963.

Mable F. Clark
Notary Public in and for the County of Twin Falls,
State of Idaho, residing at Twin Falls, Idaho.

29655

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE, IDAHO

RECEIVED
SEP 24 1961

Department of Reclamation

Permit No. G29655

Proof of Application of Water to Beneficial Use
and Completion of Works

Deposition of Holder

Ques. 1. State your name, residence, occupation and postoffice address.

Ans. City of Twin Falls, Twin Falls County, Idaho
(by Paul E Newton, City Engineer, City Hall)

Ques. 2. If acting in behalf of corporation, state its name, principal place of business (if a foreign corporation, give name of postoffice of statutory agent), your position with reference to same, and your authority for appearing in its behalf.

Ans. City of Twin Falls, Idaho by Paul E Newton, City Engineer

Ques. 3. State number and date of permit, and date of priority you propose to establish under the permit.

Ans. No. G29655, April 28, 1961, April 28, 1961

Ques. 4. State source of water supply and give exact location of point of diversion.

Ans. Subterranean, NE⁴ NE⁴ Sec 8, T11S, R17E, B.M.

Ques. 5. Describe your works of diversion, and state amount of water they are capable of conveying from point of diversion to place of use, and give name of canal or ditch or other works by which water is conducted to such place of use. If a well, state depth of well, depth and size of casing and depth to water. If pump is used, state discharge of pump and tell how it was measured or determined. If sprinkler irrigation, give number and size of nozzles and operating pressure.

Ans. 607' deep, 16" dia casing 0' to 24', static water 220',
pumping level 240', 8" dia discharge piping into
10,000 gallon storage. Flow measured by change of
water level in accurately measured concrete reservoir
over a measured period of time Discharge 1.615 cfs

Ques. 6. State for what purpose water is used and describe place of use. (If for irrigation, name each subdivision in which used, and number of acres in each subdivision that have actually been irrigated with said water.) State whether cultivated or natural meadow land and the nature of all improvements which have been made as a direct result of said use.

Ans. Domestic use, fire fighting and lawn sprinkling
at municipal airport. E² Sec 8, T11S, R17E

Ques. 6-a If this is a ground water permit, give name and address of person that drilled the well.

Ans. Mack Gray Well Drilling, Kimberly, Idaho

29655

Ques. 7. If for other than irrigation purposes; state how applied, amount of horse power generated, etc.

Ans. Used in a closed pipe system for domestic and fire protection purposes.

Ques. 8. What is the minimum amount of water required for the purpose specified above?

Ans. 1.5 cfs.

Ques. 9. If you are not the person or representative of the corporation to whom above mentioned permit was originally issued, please state how ownership was acquired by present holder.

Ans. _____

Ques. 10. State when, how, in what amount and to what extent the water diverted under above mentioned permit has been used.

Ans. _____

Ques. 11. State when, how, in what amount and to what extent waters other than those diverted under the above mentioned permit have been diverted and applied to beneficial use upon the lands herein described. Give full particulars regarding such other appropriations and rights claimed thereunder.

Ans. _____

(Sign)

Paul E. Newton
P.E. License No. 1175

I hereby certify that the foregoing testimony was read to the above subscribed before its signing, that I believe him to be the person he represents himself to be, and that said testimony was subscribed and sworn to before me, at my office in Twin Falls, County of Twin Falls, State of Idaho, on this 12 th day of September, A. D. 1963.

Carl L. Lamm
Notary Public for Idaho
Residing at Twin Falls, Idaho

My commission expires September 10, 1966

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE, IDAHO
Permit No. 629655

RECEIVED
SEP 13 1962
Department of Reclamation

PROOF OF APPLICATION OF WATER TO BENEFICIAL USE

and Compliance

DEPOSITION OF WITNESS

The deposition of two witnesses on this form, taken separately, required in each case

Ques. 1. State your name, age, residence, occupation and postoffice address:

Charles W Glasby, 43, Twin Falls, Consulting Civil Engineer,
925 Shoshone St. No. Twin Falls, Idaho

Ques. 2. Are you acquainted with the City of Twin Falls, the holder of
Permit No. 629655? How long have you known him and where does he reside:

Yes, Resident of the area 6 yrs

Ques. 3. Have you read or heard said Permit No. 629655 read, and are you familiar
with its provisions and conditions: Yes: ✓ No:

Ques. 4. State source of water supply: Subterranean

State place of diversion: NE 1/4 NE 1/4 Sec 8, T11S, R17E, B1N, Twin Falls County

Describe works for conveying water to place of use: Well pumping unit
with 10,000 gallon storage

Ques. 5. How many second feet of water do you estimate said works will safely conduct
to place of use: 1.615 How much water have you seen being so
conveyed: 1.615

Ques. 6. If for irrigation, show number of acres irrigated in each subdivision, giving
full legal description:

Ques. 7. If for power or other purposes than irrigation, state how water has been used.

Domestic use, fire fighting, lawn sprinkling at
municipal airport

Ques. 8. (If for irrigation) state character of land that has been reclaimed, and give your estimate of the amount of water required for its profitable cultivation:

Ques. 9. Have you any interest in the works, water or lands above mentioned? If so, in what way and to what extent: No

Ques. 10. When did you first see this water used: Nov. 1961

Other times you have seen such use: Intermittently since 1961

(Signed)

Charles D. Shashy
P.E. License 727

I hereby certify that the foregoing testimony was read to the above subscriber before its signing, that I believe him to be the person he represents himself to be, and that said testimony was subscribed and sworn to before me in Twin Falls

_____, County of Twin Falls, State of Idaho, on this 12th day of September,

A. D., ~~1962~~ 1963.

William J. Linn

Notary Public for State of Idaho

Residing: Twin Falls, Idaho

My commission expires: September 10, 1966

RECEIVED
SEP 18 1963

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE, IDAHO

Department of Reclamation

Permit No. G29655

PROOF OF APPLICATION OF WATER TO BENEFICIAL USE
and Completion of Works

DEPOSITION OF WITNESS

The deposition of two witnesses on this form, taken separately, required in each case

Ques. 1. State your name, age, residence, occupation and postoffice address:

Dean Milor 40 831 Alturas Drive Twin Falls, Idaho
consulting Engineer 1039 Blue Lakes No. Twin Falls, Idaho.

Ques. 2. Are you acquainted with City of Twin Falls, Idaho, the holder of
Permit No. G29655? How long have you known him and where does he reside:

Yes 15 years City of Twin Falls, Idaho

Ques. 3. Have you read or heard said Permit No. G29655 read, and are you familiar
with its provisions and conditions: Yes: ✓ No:

Ques. 4. State source of water supply: Subterranean

State place of diversion: NE 1/4 NE 1/4 Section 8, T. 11 S., R. 17 E., B.M.

Describe works for conveying water to place of use: Well pumping unit
with 10,000 gallons storage

Ques. 5. How many second feet of water do you estimate said works will safely conduct
to place of use: 1.615 How much water have you seen being so
conveyed: 1.615 cfs.

Ques. 6. If for irrigation, show number of acres irrigated in each subdivision, giving
full legal description:

29655

Ques. 7. If for power or other purposes than irrigation, state how water has been used:

Domestic use, fire fighting and lawn sprinkling at
municipal Air port

Ques. 8. (If for irrigation) state character of land that has been reclaimed, and give your estimate of the amount of water required for its profitable cultivation:

Ques. 9. Have you any interest in the works, water or lands above mentioned? If so, in what way and to what extent: No

Ques. 10. When did you first see this water used: November 1961

Other times you have seen such use: At least once monthly since
November, 1961

(Signed)

Jean Miller
P.E. Idaho #784

I hereby certify that the foregoing testimony was read to the above subscriber before its signing, that I believe him to be the person he represents himself to be, and that said testimony was subscribed and sworn to before me in Twin Falls

_____, County of Twin Falls, State of Idaho, on this 12th day of September,

A. D., ~~1962~~ 1963

Thomas J. Green
Notary Public for State of Idaho
Residing: Twin Falls, Idaho

My commission expires: September 10, 1965

NOTICE OF PROOF OF COMPLETION OF WORKS and APPLICATION OF WATER TO BENEFICIAL USE

Notice is hereby given that at 4:00 P.M., on the 12 day of September 1963, at Twin Falls, County of Twin Falls, State of Idaho, before Mrs. Constance J. Leiser, Notary Public, at City Hall City of Twin Falls, proof will be submitted of the completion of works for the diversion of 1.5 cubic feet per second of underground water from a well, and of the application to beneficial use of said water, in accordance with the terms and conditions of Permit No. G29655, heretofore issued by the Department of Reclamation of the State of Idaho.

1. The name and postoffice address of the person or corporation holding said permit is City of Twin Falls, Twin Falls, Idaho.

2. Said works of diversion will be fully completed on the date set for such completion, and the amount of water which said works are capable of conveying to the place of use is 1.5 cubic feet per second.

3. The use to which said water has been applied is domestic purposes, and the amount applied to beneficial use is 1.5 cubic feet per second.

4. The point of diversion of said water is NE $\frac{1}{4}$, NE $\frac{1}{4}$, Sec. 8 Twp. 11 S., Rge 17 E., B. M.

5. The place where said water is used is Municipal Airport.

6. The date of priority which said user is prepared to establish is April 25,

CARL E. TAPPAN
Acting State Reclamation
Engineer.

Publish: 1, 2, 15, 22, 1963 29655

NOTICE OF PROOF OF COMPLETION OF WORKS
and
APPLICATION OF WATER TO BENEFICIAL USE

Notice is hereby given that at 4:00 P. M., on the 12 day of September 1963, at Twin Falls, County of Twin Falls, State of Idaho, before Mrs. Constance J. Leiser, Notary Public, at (address) City Hall City of Twin Falls, proof will be submitted of the completion of works for the diversion of 1.5 cubic feet per second of underground water from a well, and of the application to beneficial use of said water, in accordance with the terms and conditions of Permit No. G 29655, heretofore issued by the Department of Reclamation of the State of Idaho.

1. The name and postoffice address of the person or corporation holding said permit is City of Twin Falls, Twin Falls, Idaho

2. Said works of diversion will be fully completed on the date set for such completion, and the amount of water which said works are capable of conveying to the place of use is 1.5 cubic feet per second.

3. The use to which said water has been applied is domestic purposes, and the amount applied to beneficial use is 1.5 cubic feet per second.

4. The point of diversion of said water is NE¹/₄, NE¹/₄, Sec. 8, Twp 11 S., Rge 17 E., B. M.

5. The place where said water is used is Municipal Airport

6. The date of priority which said user is prepared to establish is April 25, 1961.

CARL E. TAPPAN, Acting

State Reclamation Engineer

See authorization in G-31098

29655

July 29, 1963

Re: Permit No. G-29655
City of Twin Falls

Times-News,
Twin Falls, Idaho.

Gentlemen:

Enclosed you will find notice for publication, once a week for four consecutive weeks prior to September 12, 1963, the date set for proof; the expense of the publication is to be paid by the applicant, City of Twin Falls, Twin Falls, Idaho, to whom you should furnish proof of publication on or prior to the date set for proof.

Please acknowledge receipt of this notice and furnish this office with a copy or tear sheet of the first publication.**

Very truly yours,

CARL E. TAPPAN, Acting
State Reclamation Engineer

**If the first copy is not received in this office for checking purposes and errors appear in subsequent issues, it is possible that re-publication of corrected copy will be at your own expense.

Encl.
CET:spak

29655

July 29, 1963

Re: Permit No. G-29655

City of Twin Falls,
Twin Falls, Idaho.

Gentlemen:

This acknowledges the Notice of Proof of Completion of Works and Application of Water to Beneficial Use under Permit No. G-29655. The proofs are to be made at 4:00 o'clock P.M., on the 12th day of September, 1963, before Mrs. Constance J. Leiser, City Hall - Twin Falls, Idaho, Notary Public.

As of this date we have mailed the Notice to the Times-News Twin Falls, Ida. with instructions to publish it once a week for four consecutive weeks prior to the date set for final proof then mail the affidavit of publication and statement of costs to you.

It is important that the enclosed depositions be executed by you and two disinterested witnesses who are familiar with the terms of the permit and the work done thereunder, at the place, on the date, and at the time and before the Notary, as advertised. It is very important and necessary that each question be answered in detail.

In returning the depositions to this office, be sure that all copies have been signed, the Notary's seal has been placed on each and that all depositions, (holder and two witnesses) are being returned. Also be sure to enclose the Affidavit of Publication.

Very truly yours,

~~Geo. P. Gifford~~

State Reclamation Engineer

By:

(Mrs.) Edna P. Rule
Chief Clerk

Enc.
EPR:pmk
cc: Notary

29655

May 3, 1961

Re: Permit No. G-29655
City of Twin Falls

City Engineer,
City Hall,
Twin Falls, Idaho.

Dear Sir:

We enclose Permit No. G-29655 in which we direct your attention to the limitations and conditions as given on the fourth page under approval of the State Reclamation Engineer.

We also enclose Departmental Receipt No. G-5876 which was issued covering payment in the amount of \$5.25 for the filing fee of the above mentioned permit.

You will note, under Question 10, that we have changed the required time for completion of works and complete application of the water to the proposed use to five years. However, you may make the required proofs at any time you are prepared to do so within that time.


Very truly yours,

GEO. N. CARTER
State Reclamation Engineer
By

(Mrs.) Edna P. Rule
Chief Clerk

Encl.
EPR:pak

29655



Time	GPM as measured by orifice	Water Level from ground level down	Remarks
3:00 P. M.			Pump stopped. Screen backflushed.
3:02	---	229	
3:10	---	227	
3:15	1000	235	Pump started. Water murky but much cleaner.
3:20	960	258	Screens plugged again. Backflushed. Changed to 6" orifice.
3:30	---	230	Started pump
3:32	600	233	Water clearing.
3:55	600	232	Water clear.
4:08	580	232	
4:25	620	233	
4:30	620	233	Temp. 60° F.
4:35	---	---	Turned on full engine
4:36	Too much flow to measure	256	
4:40		258	Screens clogging. Water dirty. Flow decreasing
4:43		258	Pump stopped.
4:45		230	
4:50		227	

1. Test data and flow measurements taken by P. E. Newton, City Engineer April 11, 1961
2. Test pumping equipment furnished by Layne and Bowler (300 H. P. Engine, 12" closed impellor pump set at 400 foot depth.
3. Well drilled to 607 foot depth by Mack Gray. Hole 16 inch diameter to 400 feet and 12 inch diameter from 400 feet to 607 feet.

TEST PUMPING RECORD OF AIRPORT WELL
April 11, 1961

Time	GPM as measured by orifice	Water Level from ground level down	Remarks
9:10 A. M.	----	218 (static)	
9:20	1100	---	Started pumps. Measurement by 8½" orifice on 10" pipe
9:25	1620	233	
9:30	1140	232	Water temperature 60°F.
9:33	----	---	Pump stopped
9:35	----	223	
9:45	----	220	Pump started
9:50	1020	223	
10:00	1020	229	Temp 60° F. water clear
10:10	1700	241	
10:15	Flow decreased rapidly	257	Water dirty, pump screens plugged by talc and shale. Pump stopped.
10:20	----	223	
10:25	----	221	Started pump. Water dirty.
10:30	1100	232	
10:55	1120	232	
10:56	----	---	Stopped pump to change to 6" orifice on 10" pipe.
11:00	----	225	
11:05	----	223	Started pump
11:10	600	226	
11:15	600	226	Water clear. Temp 60° F.
1:10 P. M.	600	227	Took water samples for bac- teriological & chemical analysis
1:20	----	227	Stopped pump to change to 8½" orifice on 10" pipe
1:25	----	224	
1:30	----	223.5	
1:33	----	223	Started pump
1:35	1200	230	
1:40	1200	234	
2:00	1200	236	
2:15	1200	240	
2:35	980	246	Water dirty. Flow decreased. Pump screen clogged
2:40	1200	247	Pump speed increased.
2:45	980	247	Water dirty. Flow decreased
2:50	920	246	Flow decreasing.