

State of Idaho
Department of Water Resources

WATER RIGHT LICENSE

WATER RIGHT NO. 29-08059

Priority: March 28, 1991

Maximum Diversion Rate:

6.00 CFS

This is to certify, that CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N RIO VISTA RD
POCATELLO ID 83202

has complied with the terms and conditions
of the permit, issued pursuant to Application for Permit dated March 28, 1991; and
has submitted Proof of Beneficial Use on May 27, 1993. An examination indicates
that the works have a diversion capacity of 7.130 cfs of water from a GROUNDWATER
source, and a water right has been established as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
-----------------------	----------------------	--------------------------	----------------------

IRRIGATION	03/15 to 11/15	6.00 CFS	
------------	----------------	----------	--

LOCATION OF POINT(S) OF DIVERSION:

SENE , Sec. 30, Township 05S, Range 34E
BANNOCK County

PLACE OF USE: IRRIGATION

<u>TWN</u>	<u>RGE</u>	<u>SEC</u>	<u>ACRES</u>	<u>ACRES</u>	<u>ACRES</u>	<u>TOTAL</u>
05S	34E	30	NWNE 38	SWNE 39	SENE 37	
			NENW 35	SENW 37	NESW 40	
			NWSW 37	SWSW 33	SESW 37	
			NWSE 40	SWSE 36	SESE 32	441

Total number of acres irrigated: 441

CONDITIONS OF APPROVAL AND REMARKS

1. This water right is appurtenant to the described place of use.
2. This right is subject to all prior water rights and may be forfeited by five years of non-use.
3. Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho law.
4. The use of water under this right shall not give rise to any claim against the holder of a senior water right based upon the theories of forfeiture, abandonment, adverse possession, waiver, equitable estoppel, estoppel by laches or customary preference.
5. The Director retains jurisdiction of the right to incorporate the use into a water district, require streamflow augmentation or other action needed to protect prior surface water and groundwater rights.
6. The right holder shall use the full allotment of appurtenant surface water rights in conjunction with groundwater diverted under this right and shall only divert groundwater under this right when water from the appurtenant surface water rights cannot be delivered to the right holder.

JUN 27 1996

State of Idaho
Department of Water Resources**WATER RIGHT LICENSE**


WATER RIGHT NO. 29-08059

CONDITIONS OF APPROVAL AND REMARKS

7. This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor exceed a combined annual diversion volume of 1764.0 af for the lands above.
8. This right shall not be used if the surface water right(s) appurtenant to the place of use is sold, transferred, leased, or used on any other place of use.

This license is issued pursuant to the provisions of Section 42-219, Idaho Code. Witness the seal and signature of the Director, affixed at Boise, this 14TH day of JUNE, 1996.

Acting for


KARL J. DREHER Director

JUN 27 1996

State of Idaho
Department of Water Resources

RECEIVED

JUN 06 1996

Department of Water Resources

APPLICATION FOR AMENDMENT

(For Licensing Purposes)

WATER RIGHT NO. 29-08059

Date of Priority: March 28, 1991 **Maximum Diversion Rate:** 6.00 CFS
Comes now CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N RIO VISTA RD
POCATELLO ID 83202 and represents to the Director of the

Idaho Department of Water Resources:

That he is the owner and holder of Permit to Appropriate the Public Waters of the State of Idaho No. 29-08059, and requests that the permit be changed as follows:

Source: GROUNDWATER

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
IRRIGATION	03/15 to 11/15	6.00 CFS	

LOCATION OF POINT(S) OF DIVERSION:

~~NENE~~, Sec. 30, Township 05S, Range 34E
Tom SENE BANNOCK County

PLACE OF USE: IRRIGATION

<u>TWN</u>	<u>RGE</u>	<u>SEC</u>	<u>ACRES</u>	<u>ACRES</u>	<u>ACRES</u>	<u>TOTAL</u>
05S	34E	30	NWNE 38	SWNE 39	SENE 37	
			NENW 35	SENW 37	NESW 40	
			NWSW 37	SWSW 33	SESW 37	
			NWSE 40	SWSE 36	SESE 32	441

Total number of acres irrigated: 441

Permit holder asserts that no one will be injured by such change and that such change will be made at permit holder's own risk.

Signed at _____, this 4 day of June, 1996.

RECORDED

JUN 27 1996

Paul E. Miller
(Signature)

State of Idaho
Department of Water Resources

APPLICATION FOR AMENDMENT
(For Licensing Purposes)
WATER RIGHT NO. 29-08059

FOR DEPARTMENT USE ONLY

Preliminary check by _____ Fee = 50.00 Received by RB # C035755 Date 10/16/96

ACTION OF THE DEPARTMENT OF WATER RESOURCES

I, Karl J. Dreher, of the Department of Water Resources hereby approve the above Application for Amendment for Permit No. 29-08059 with the following;

CONDITIONS OF APPROVAL AND REMARKS

1. This water right is appurtenant to the described place of use.
2. This right is subject to all prior water rights and may be forfeited by five years of non-use.
3. Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho law.
4. The use of water under this right shall not give rise to any claim against the holder of a senior water right based upon the theories of forfeiture, abandonment, adverse possession, waiver, equitable estoppel, estoppel by laches or customary preference.
5. The Director retains jurisdiction of the right to incorporate the use into a water district, require streamflow augmentation or other action needed to protect prior surface water and groundwater rights.
6. The right holder shall use the full allotment of appurtenant surface water rights in conjunction with groundwater diverted under this right and shall only divert groundwater under this right when water from the appurtenant surface water rights cannot be delivered to the right holder.
7. This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor exceed a combined annual diversion volume of 1764.0 af for the lands above.
8. This right shall not be used if the surface water right(s) appurtenant to the place of use is sold, transferred, leased, or used on any other place of use.

Witness my hand this 14TH day of JUNE, 1996.

Acting for KARL J. DREHER, Director

JUN 27 1996

RECEIVED

MAY 27 1993

Department of Water Resources

OFFICE USE ONLY
Amt. of Fee \$ 225.00
Date 5-27-93
Receipt No. 0027653
Receipt by CA

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

PROOF OF BENEFICIAL USE

The Idaho Department of Water Resources considers this form a statement that the permit holder(s) has/have completed all development that will occur under this permit and that water has been applied according to the provisions of the permit for the beneficial use(s) described below. This form must be accompanied by a license examination fee, when necessary, or a completed field examination report prepared by a certified water right examiner who has been appointed by the department.

1. Permit No. 29-08059 Telephone No. (208) 237-6154

2. Name(s) of Permit Holder(s): L. D. S. Church dba Pocatello Tyhee Farm

3. Mailing Address: 13037 N. Rio Vista Rd. Pocatello, ID 83202

4. Source of Water: ground water

If **GROUNDWATER**, Well Driller's Name: Jack Cushman Drilling Date Drilled: 4-4-91 to 5-24-91

OPTIONAL:

Pump horsepower: 200 Pressure (psi): 80 Dynamic pumping level (ft.): 73.6

5. Extent of Use (as authorized by the permit):

Domestic _____ (No. of households) Stockwater _____ (No. and type of stock)

Irrigation 448 (No. of acres) Other _____

6. Total rate and/or volume for which proof is submitted 6.0 cfs OR _____ acre/feet

7. Refer to the approval conditions on your permit and respond accordingly:

Measuring device: Required? _____ Yes ✓ No _____ Installed? _____ Yes _____ No

OR

Flow Measurement Port: Required? ✓ Yes _____ No _____ Installed? _____ Yes _____ No

8. Fee Enclosed: \$ 225.00 (See License Fee Schedule on back of Instruction Sheet)

9. Person to contact to accompany the Department representative during field examination of the water system.

Taft C. Miller 237-6154
Name Telephone No.

13037 N. Rio Vista Rd., Pocatello, Idaho
Address

10. The above information is my true statement of the extent to which the above numbered permit has been developed and I relinquish any undeveloped portion of the permit to the state of Idaho.

May 21, 1993
Date

Taft C. Miller Farm Mgr.
Signature (and title, if on behalf of a company or organization)

RECORDED
JUN 28 1993

State of Idaho
Department of Water Resources

Permit To Appropriate Water

NO. 29-08059

Proposed Priority: March 28, 1991 Maximum Diversion Rate: 6.00 CFS
This is to certify, that CHURCH OF JESUS CHRIST OF LATTER DAY SAINTS

POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.
POCATELLO, ID 83202

has applied for a permit to appropriate water from: GROUNDWATER
and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
IRRIGATION	03/15 to 11/15	6.00 CFS

LOCATION OF POINT(S) OF DIVERSION: NWNE Sec. 30, Township 05S, Range 34E
BANNOCK County

PLACE OF USE: IRRIGATION

<u>TWN</u>	<u>RGE</u>	<u>SEC</u>	<u>ACRES</u>	<u>ACRES</u>	<u>ACRES</u>	<u>TOTAL</u>
05S	34E	30	NWNE 38	SWNE 38	SENE 36	
			NENW 38	SENE 38	NESW 40	
			NWSW 34	SWSW 36	SESW 36	
			NWSE 40	SWSE 38	SESE 36	448

Total number of acres irrigated: 448

CONDITIONS/REMARKS:

1. Proof of construction of works and application of water to beneficial use shall be submitted on or before June 1, 1993.
2. Subject to all prior water rights.
3. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which permit holder had no control.
4. A flow measurement port or other device as specified by the Department shall be installed by the permit holder to provide for the installation of measuring equipment and the determination of the rate of diversion by the Department.
5. The right to the use of water acquired under this permit shall not give rise to any right or claim against the holder of a senior right based upon the theories of forfeiture, abandonment, adverse possession, waiver, equitable estoppel, estoppel by laches or customary preference.
6. The Director retains jurisdiction of the permit and any license subsequently issued to incorporate the use into a water district, require streamflow augmentation or other action needed to protect prior surface water and groundwater rights.

MICROFILMED

JUL 01 1991

State of Idaho
Department of Water Resources


Permit To Appropriate Water

NO. 29-08059

7. The rate of diversion of water for irrigation under this permit and all other water rights on the same land shall not exceed 0.02 cubic feet per second for each acre of land.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the seal and signature of the Director, affixed at Boise, this

31st day of May, 1991.

for 
R. Keith Higginson, Director

RECORDED

JUL 01 1991

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT

Ident. No. _____

To appropriate the public waters of the State of Idaho

1. Name of applicant Pocatello Tyhee Farm (LDS church) Phone 237-6154
Post office address 13037 N. Rio Vista Rd, Pocatello Id 83202
2. Source of water supply Groundwater which is a tributary of _____
3. Location of point of diversion is _____ $\frac{1}{4}$ of NW $\frac{1}{4}$ of NE $\frac{1}{4}$, Govt. Lot _____
Sec. 30 Township 5S Range 34E B.M. Bannock County; additional
points of diversion if any: _____
4. Water will be used for the following purposes:
Amount 6.0 for Irrigation purposes from 3/15 to 11/15 (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
5. Total quantity to be appropriated is (a) 6.0 and/or (b) _____
cubic feet per second acre feet per annum
6. Proposed diverting works:
 - a. Description of ditches, flumes, pumps, headgates, etc. well, pump, mainline to
laterals with sprinklers
 - b. Height of storage dam _____ feet; active reservoir capacity _____ acre-feet; total
reservoir capacity _____ acre-feet; period of year when water will be diverted to storage:
_____ to _____ inclusive.
 - c. Proposed well diameter is 20 inches; proposed depth of well is 250 feet.
 - d. Is ground water with a temperature of greater than 90°F being sought? _____
7. Time required for the completion of the works and application of the water to the proposed use is
2 years (minimum 1 year).

MICROFILMED
JUL 01 1991

8. Description of proposed uses (if irrigation only, go to item 9):

- Hydropower; show total feet of head and proposed capacity in KW. _____
- Stockwatering; list number and kind of livestock. _____
- Municipal; show name of municipality. _____
- Domestic; show number of households. _____
- Other; describe fully. _____

9. Description of place of use:

- If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
- If water is used for other purposes, place a symbol of the use (example: *D* for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RANGE	SEC.	NE¼				NW¼				SW¼				SE¼				TOTALS
			NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	
5S	34E	30		38	38	36	38			38	40	34	36	36		40	38	36	448

Total number of acres to be irrigated 448

10. Describe any other water rights used for the same purposes as described above. Fort Hall Irr. Co. Shares

- Who owns the property at the point of diversion? *Applicant
- Who owns the land to be irrigated or place of use? *Applicant
- If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing. _____


12. Remarks: Robert Hart - committee chairman
Eugene Hancock - Priesthood leader
Taft C. Miller - Farm Manager

*Per Conversation with Taft Miller, 28 5-29-91

RECORDED

JUL 01 1991

13. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

Harry C. Miller Farm Mgr.
(Applicant)

Assisted by KCW
 Received by KCW Date 3-28-1991 Time 1500hrs Preliminary check by _____
 Fee \$ 145⁰⁰ Receipted by KCW # E015879 Date 28 Mar 1991
 Publication prepared by RB Date 5-2-9-91 Published in Idaho State Journal
 Publication approved RB Date 5-20-91

ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. _____, and said application is hereby _____.

1. Approval of said application is subject to the following limitations and conditions:

a. SUBJECT TO ALL PRIOR WATER RIGHTS.

b. Proof of construction of works and application of water to beneficial use shall be submitted on or before _____, 19 ____.

c. The rate of diversion, if water is to be used for irrigation under this permit, when combined with all other water rights for the same land shall not exceed 0.02 cubic feet per second for each acre of land.

d. The water right acquired under this permit if for hydropower purposes shall be junior and subordinate to all rights to the use of water, other than hydropower, within the State of Idaho that are initiated later in time than the priority of this permit and shall not give rise to any right or claim against any future rights to the use of water, other than hydropower, within the State of Idaho initiated later in time than the priority of this permit.

e. Other:

MICROFILMED

JUL 01 1991

PROOF OF PUBLICATION

STATE OF IDAHO
County of Bannock

ss.

Department of Water Resources
Custom District Office

Erin E. Jones

being first duly sworn on oath deposes and says: That _____ she
was at all times herein mentioned a citizen of the United States of America,
more than 21 years of age, and the Principal Clerk of THE IDAHO
STATE JOURNAL, a daily newspaper, printed and published at Pocatello,
Bannock County, Idaho, and having a general circulation therein.

That the document or notice, a true copy of which is attached, was
published in the said IDAHO STATE JOURNAL, on the following dates,
to-wit:

2 May	19 91	19
9 May	19 91	19
	19	19
	19	19
	19	19
	19	19

That said paper has been continuously and uninterruptedly published
in said County for a period of seventy-eight weeks prior to the publication
of said notice or advertisement and is a newspaper within the meaning
of the laws of Idaho.

Erin E Jones

STATE OF IDAHO

COUNTY OF Bannock

On this 9th day of May in the year of 1991, before me,
a Notary Public, personally appeared Erin E. Jones,
known or identified to me to be the person whose name subscribed to the within instrument,
and being by me first duly sworn, declared that the statements therein are true, and
acknowledged to me that he executed the same.

John L. Peterson
Notary Public for Idaho

Residing at Pocatello

My commission expires: July 1991

APPLICATION FOR WATER RIGHTS
628-08058
CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.
POCATELLO, ID 83202
Source: GROUNDWATER
Diversion Pt: NWNE Sec 30 T 05S R 34E
Use: IRRIGATION (6,000 CFS)
Total Diversion: (6,000 CFS)
Date Filed: 3/28/1991
In: T05S R34E S30 NWNE SWNE SENE NENW
SENE NENW
SENE NENW NWSW SWSW
SENE NENW SWSE SESE
448.0 ACRES TOTAL
29-08060
WARD, DIXIE J.
WARD, WILLIAM
23010 S. MARSH CREEK RD.
DOWNEY, ID 83234
Source: GROUNDWATER
Diversion Pt: NENE Sec 35 T 11S R 36E
Use: IRRIGATION (.870 CFS)
Total Diversion: (.870 CFS)
Date Filed: 4/9/1991
In: T11S R36E S25 SWSW S25 SESE
S25 NENE
S25 NENW
43.6 ACRES TOTAL
(The permits) will be subject to all prior water rights. Protests may be submitted based on the criteria of Sec. 42-203A, Idaho Code and/or the new public interest criteria of Sec. 42-203C, Idaho Code. Protests must be filed with the Director, Dept. of Water Resources, 150 Shoup Ave., Suite 15, Idaho Falls, Idaho 83402 on or before MAY 20, 1991.
S/R Keith Higginson, Director
May 2, 9, 1991
Idaho

PROOF OF PUBLICATION

STATE OF IDAHO
County of Bannock

§ 5

Notary Public
Notary District Office

Erin E. Jones

APPLICATION FOR WATER RIGHTS (29-08059)

CHURCH OF JESUS CHRIST LATTER
DAY SAINTS

POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.

POCATELLO, ID 83202

Source: GROUNDWATER

Diversion Pt: NWNE Sec 30 T 05S R
34E

Use: IRRIGATION (6,000 CFS)

Total Diversion: (6,000 CFS)

Date Filed: 3/28/1991

In: T05S R34E S30 NWNE SWNE

SENE NENW

SENEW NESW NWSW SWSW

SESEW NWSE SWSE SESE

448.0 ACRES TOTAL

29-08060

WARD, DIXIE J.

WARD, WILLIAM

23010 S. MARSH CREEK RD.

DOWNNEY, ID 83234

Source: GROUNDWATER

Diversion Pt: NENE Sec 35 T 11S R
36E

Use: IRRIGATION (1,870 CFS)

Total Diversion: (1,870 CFS)

Date Filed: 4/9/1991

In: T11S R36E S25 SWSW

S26 SESE

S35 NENE

S36 NWNW

43.5 ACRES TOTAL

The permit(s) will be subject to all prior
water rights. Protests may be submitted
based on the criteria of Sec. 42-203A,
Idaho Code and/or the new public inter-
est criteria of Sec. 42-203C, Idaho
Code. Protests must be filed with the
Director, Dept. of Water Resources, 150
Shoup Ave., Suite 15, Idaho Falls,
Idaho 83402 on or before MAY 20,
1991.

S/R Keith Higginson, Director
May 2, 9, 1991

Ln.482

being first duly sworn on oath deposes and says: That _____
was at all times herein mentioned a citizen of the United States of Amer-
ica, more than 21 years of age, and the Principal Clerk of THE IDAHO
STATE JOURNAL, a daily newspaper, printed and published at Pocatello,
Bannock County, Idaho, and having a general circulation therein.

That the document or notice a true copy of which is attached, was
published in the said IDAHO STATE JOURNAL, on the following dates,
to-wit:

May	19 91	19
May	19 91	19
	19	19
	19	19
	19	19

That said paper has been continuously and uninterruptedly published
in said County for a period of seventy eight weeks prior to the publication
of said notice or advertisement and is a newspaper within the meaning
of the laws of Idaho.

STATE OF IDAHO

COUNTY OF Bannock

On this _____ day of _____ in the year of 1991, before me,
a Notary Public, personally appeared _____
known or identified to me to be the person whose name subscribed to the within instrument,
and being by me first duly sworn, declared that the statements therein are true, and
I acknowledged to me that he executed the same.

Notary Public for Idaho

Residing at _____

My commission expires: _____



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

June 18, 1996

CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N RIO VISTA RD
POCATELLO ID 83202

RE: WATER RIGHT NO. 29-08059

Dear Water Right Holder(s):

Enclosed is a copy of the Water Right License issued on the above referenced permit along with a copy of your approved Application for Amendment.

Should you have any questions regarding these documents, please contact me.

Sincerely,

Shelley W. Keen
Water Rights Supervisor

SK:rl

Enclosure

RECEIVED

JUN 27 1996

MEMORANDUM

DATE: June 6, 1996

TO: File 29-08059

FROM: Shelley W. Keen *SWK*

RE: Verification of the point of diversion

This morning Eastern Region field examiner Paul Meyer called to tell me that he revisited the point of diversion for right 29-08059 and found that the point of diversion is a few feet south of the fenceline between the SENE and the NENE. Therefore, before the right can be licensed the permit should be amended to change the point of diversion to the SENE.

JUN 27 1996

MEMORANDUM

DATE: May 20, 1996

TO: File 29-08059

FROM: Shelley W. Keen ^{SWK}

RE: Verification of the point of diversion

This morning Taft Miller called me to say that he is still pursuing documentation he can use to demonstrate that the point of diversion is in the SE $\frac{1}{4}$ NE $\frac{1}{4}$, Section 30, Township 5 South, Range 34 East. After speaking with Mr. Miller, I called Eastern Region Sr. Agent Paul Meyer to discuss the situation with him. Paul said he would contact Mr. Miller and take the GPS unit out to verify the point of diversion description for this right.

RECEIVED

JUN 27 1996



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

May 16, 1996

ATTN TAFT MILLER
CHURCH OF JESUS CHRIST OF LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N RIO VISTA RD
POCATELLO ID 83202

RE: Water Right No. 29-08059

Dear Mr. Taft:

On April 1, 1996, I wrote to inform you that Water Right Permit 29-08059 is being reviewed for licensing and to request that you amend your permit to conform with the findings of the field examiner. Since then you have called me twice to discuss your concern that the field examiner's finding that your well is located in the NE $\frac{1}{4}$ NE $\frac{1}{4}$, Section 30, Township 5 South, Range 34 East, is incorrect. You told me that you believe that the well is located in the SE $\frac{1}{4}$ NE $\frac{1}{4}$, Section 30, Township 5 South, Range 34 East. During our last conversation, on April 19, you indicated that you will send me documentation to support your conclusion. I have not yet received your documentation.

Please submit the information you have collected or submit the application for amendment of your permit within fourteen (14) days. In case the amendment form I sent you has been misplaced, a new one is enclosed. Please note that the filing fee for the amendment is \$50.00.

If I have not heard from you within fourteen days, I will assume you no longer have an interest in this water right, and I will pursue cancellation of your permit.

If you have any questions, please contact me at 208-327-7946.

Respectfully,

A handwritten signature in cursive script that reads "Shelley Walter Keen".

Shelley Walter Keen
Water Rights Supervisor

A rectangular filing stamp with the text "RECEIVED" and "MAY 22 1996" in a bold, sans-serif font.

JUN 27 1996

MEMORANDUM

DATE: April 19, 1996

TO: File 29-08059

FROM: Shelley W. Keen *SWK*

RE: Phone call from Taft Miller

Today Taft Miller of Pocatello Tyhee Farm called to discuss my request for a licensing amendment for permit 29-08059. After reviewing the field report Mr. Miller still believes the well is actually located in the SENE. In addition, Mr. Miller wants credit for an additional acre in the SWNE Sec. 30. He says there is a one-acre rocky strip that grow no crop but is irrigated for pasture. Mr. Miller will send me documentation to support the changes he recommends.

RECEIVED

JUN 27 1996

MEMORANDUM

DATE: April 9, 1996

TO: File 29-08059

FROM: Shelley W. Keen *SWK*

RE: Phone call from Taft Miller

Today Taft Miller of Pocatello Tyhee Farm called to discuss my request for a licensing amendment for permit 29-08059. His main concern was that the examiner placed the point of diversion in the NENE, which is not owned by Pocatello Tyhee Farm. Mr. Miller believes the well is actually located in the SENE. In addition, Mr. Miller wanted to know how the acreage recommendation had been prepared. I agreed to send Mr. Miller a photocopy of the field report so that he could review it. If he disagrees with the report after reviewing it, he will send me documentation to support any changes he recommends.

RECEIVED

JUN 27 1996



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

April 1, 1996

CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N RIO VISTA RD
POCATELLO ID 83202

RE: WATER RIGHT NO. 29-08059

Dear Water Right Holder(s):

The above referenced water right is in the process of being licensed. However, before a license can be issued, your permit must be amended to depict your water right as it has actually been developed.

The enclosed Application for Amendment contains information that will be included on the license when it is issued. The amendment reflects a change in the location of the point(s) of diversion. Please review carefully and if you concur, sign the amendment and return with the \$50.00 filing fee within 14 days.

The last page of the Application for Amendment form contains a list of CONDITIONS/REMARKS proposed for the license when it is issued. These conditions/remarks may be modified upon further administrative review.

If you do not concur, or if you have any questions about this information, please contact me as soon as possible. My telephone number is (208) 327-7946.

Sincerely,

Shelley Walter Keen

JIM JOHNSON, Manager
Water Right Permits Section

JJ:rl

Enclosure

JUN 27 1996

B/U FIELD EXAM REVIEW
Cindy Zimmerman

01/96

Permit #: 29-8059 Name: WDS/Pac. Three farm Date: 3/12/96 ✓ Lots ✓
Chng Same

NAME ✓ Or Address Change?

SOURCE ✓ Clarify source
 Prelim. Order to Void - Source change.

P/D ✓ Amendment Needed? SAME P39
Overlap(s) none

P/U ✓ Amendment Needed? reduce overall acres to 441 P41
Overlap(s) Fort hall lvs. under 27-2007 & 2035 & 2087
(Gov't special #'s) *P/D & P/U Amend? P37

RATE ✓ Permit/fee limits: 6.00 / 6.00
 Measured Q= cfs/Theoretical Q= cfs
limited by permit Polysonic = $3198.0 \text{ gpm} = 7.13 \text{ cfs}$; $441.0 \text{ ac} \times 0.02 \text{ cfs/ac} = 8.82$
(HP) $8.8 \times 0.70 \times \frac{200}{65+10 + (2.31 \times 50)} = \frac{1232.0}{190.5} = 6.47 \text{ cfs}$
 ✓ Recommended capacity 7.13 cfs
 ✓ Recommended rate 6.00 cfs

VOLUME ✓ Season: (C / 4.0) 4/1 - 10/31 = 2/4 days
Calculations: 441 ac x 4.0 AF/ac = 1764.0 AF

 ✓ Flow limit: x x 1.9835 = AF
Recommended volume 1764.0 AF

USES ✓ Same Nature of Use? P46
 Amendment Needed?

REMARKS Multiple p/d's in 1/4? W32
✓ ① W37 ② W38

CONDITIONS Measuring (R01)/Locking (R02) Devices
 Watermaster Control (R04) - WD #
 Irrigation rate/volume overlap
 GW irrigation replaces surface water (050)
065 GW irrigation supplements surface water (065)
✓ Water Quality/Other 048,049

PRIORITY App Rcd 3/28/91 Due 6/1/93 Rc'd 5/27/93
Receipt# 0027653 Fee OK? Yes/No
Order to Reinstate Needed? Yes/No Done?
If Yes, Advanced? Yes/No to:
Priority 3/28/91 Examined 6/21/95

COMMENTS: Supplemental gw irr.

USE	CFS	DIV VOL	SRBA Overlap
<u>Irr.</u>	<u>6.00</u>	<u> </u>	<u>none</u>
<u> </u>	<u> </u>	<u> </u>	<u>Adjustment Memo</u>
<u> </u>	<u> </u>	<u> </u>	<u>LICENSE LTR: P49</u>
<u> </u>	<u> </u>	<u> </u>	<u>#1 AMEND LTR: P39/P38</u>
<u>TOTAL</u>	<u>6.00</u>	<u> </u>	<u>#2 AMEND LTR: P42/P47</u>

JUN 27 1996

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

RECEIVED
MAR 17 1996
Department of Water Resources

A. GENERAL INFORMATION

Permit No. 29-08059

Church of Jesus Christ Latter Day Saints Phone: (208) 237-6154
Pocatello Tyhee Farm
13037 North Rio Vista Road, Pocatello, Idaho 83202

2. Accompanied by: TAYLOR MILLER EXAM DATE: 6-21-95

Address: _____ Phone No. _____

Relationship to Permit Holder: OPERATOR/MANAGER

3. Source: GROUNDWATER tributary to _____

B. OVERLAP REVIEW

- Other water rights with the same place of use: FOOT HILL IRRIGATION SYSTEM
- Other water rights with the same point of diversion: —

C. DIVERSION AND DELIVERY SYSTEM

1. Point(s) of Diversion:

Ident No.	Gov't Lot	1/4	1/4	1/4	Sec.	Twp.	Rge.	County	Method of Determination/Remarks
		SW	NE	NE	30	5S	34E	BANWICK	USGS, ASCS, NAPP, ONSITE


2. Place(s) of Use:

Indicate Method of Determination Same

TWP	RGE	SEC	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
5S	34E	30		38	39	37	35			37	40	37	33	37		40	36	32	441

JUN 27 1996

3. **Delivery System Diagram:** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe I.D. as applicable.



Scale: 1" = _____

____ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

____ Aerial Photo Attached (required for irrigation of 10+ acres)

____ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
	US Motors	200	6349/003001 02007E-4	UNKNOWN	

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date
POLISONIC flow meter		TYMEX				

2. Measurements: $Q_{meas} = 3.198 E^3 \text{ GPM} = 3198.0 \text{ GPM} = 7.13 \text{ CFS}$

JUN 27 1996

E. NARRATIVE/REMARKS/COMMENTS

WELL AND TURBINE PUMP TO PRESSURIZED SPRINKLER SYSTEM FOR IRRIGATION
OF 441 ACRES OF THE DEATELLO THREE FARM OWNED BY LDS CHURCH.

* AMENDMENT NEEDED TO CHANGE POINT OF DIVERSION FROM
NWNE 30-55-34E TO SWNE SAME SECTION

* NOTE: WR DATABASE INDICATES OVERLAP IN $S\frac{1}{2}SE\frac{1}{4}$ 30-55-34E
WITH 29-07437 (J.R. SIMPSON CO.). THERE IS NO OVERLAP WITH
THIS WATER RIGHT.

* ASSUME 50 PSI OPERATING PRESSURE AT TIME OF EXAM

* FROM WELL LOG: STATIC H_2O AT 65'.

* ASSUME STANDARD EFFICIENCY OF 75%

* FERT WALL SHARES ALSO USED.

Have conditions of permit approval been met? ☐ yes ☐ no

JUN 27 1996

F. FLOW CALCULATIONS

Additional Computation Sheets Attached

Measured Method:

$$Q_{MEAS} = 3198.06 \text{ GPM} \\ = 7.13 \text{ CFS}$$

$$Q_{THEOR} = \frac{200 \text{ HP} (8.814) \cdot 75 \text{ EFF}}{65' \text{ LIPT} + (2.308 \times 50 \text{ PSI})} = 7.33 \text{ CFS}$$

LIMITED BY PERMIT TO 6.0 CFS

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = 441 \times 4.0 = 1764.0$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 = 6.0 \times 214 \times 1.9835 = 2546.8$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 1764.0$$

2. Volume Calculations for Other Uses:

H. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
<u>IRRIGATION</u>	<u>4-1</u>	<u>10-31</u>	<u>6.00</u>	<u>1764.0</u>
Totals:			<u>6.00</u>	<u>1764.0</u>

2. Recommended Amendments

☒ Change P.D. as reflected above ☐ Add P.D. as reflected above ☐ None
☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name DDM Date 2-26-96

Reviewer _____ Date _____

JUN 27 1996

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTRECEIVED
JUL 15 1992
JUN 27 1992State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name L.D.S. Church Stake Farm
Address 13037 N. Rio Vista Pocatello, Idaho
Owner's Permit No. 29-91-E-011

2. NATURE OF WORK

- ☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

3. PROPOSED USE

- ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

- ☐ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary
☒ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
3/8 inches	20 inches	1 foot	190 feet
1/4 inches	16 inches	265 feet	325 feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet


Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☒ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☒ Torch
Size of perforation 1/4 inches by 6 inches

Number	From	To
240 perforations	290 feet	315 feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____
Placed from _____ feet to _____ feet
Surface seal depth 20' Material used in seal: ☒ Cement grout
☐ Bentonite ☐ Pudding clay ☐ _____
Sealing procedure used: ☐ Slurry pit ☒ Temp. surface casing
☐ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent
Weld _____
☐ Cemented between strata
Describe above part 2" Pipe on 20" Casing

6. LOCATION OF WELL

Sketch map location must agree with written location.

Subdivision Name _____
Lot No. _____ Block No. _____County Bannock

NW 1/4 NE 1/4 Sec. 30, T. 5, N.R. 34E

7. WATER LEVEL

Department of Water Resources
Eastern District OfficeStatic water level 65' feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature 54 °F. Quality Good
Describe artesian or temperature zones below.

8. WELL TEST DATA

☐ Pump ☐ Sifter ☐ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped

9. LITHOLOGIC LOG

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
24"	0	2	Clay		X
	2	17	Boulders & Gravel		X
	17	20	Gravel		X
20"	20	28	Gravel		X
	28	57	Coarse Sand		X
	57	87	Clay		X
	87	97	Brown Sand		X
	97	107	Pea Gravel & Sand		X
	107	123	Sand		X
	123	142	Clay		X
	142	151	Sandstone & Clay		X
	151	165	Clay		X
	165	173	Sandstone & Clay		X
	173	190	Gravel & Clay		X
	190	203	Basalt		X
	203	206	Cinders		X
	206	287	Basalt		X
	287	293	Broken Basalt		X
	293	295	Firm Basalt		X
	295	313	Broken Basalt & Some Clay		X
	313	322	Sticky Clay		X
	322	325	Firm Basalt		X
16"	325	331	Firm Basalt		X
	331	347	Broken Basalt		X
	347	350	Firm Basalt		X
	350	352	Cinders		X

10.

Work started 4/4/91 finished 5/24/91

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Jack Cushman Drilling Firm No. #94
1405 South Broadway
Address Blackfoot, Idaho Date 5/28/91Signed by (Firm Official) Bob Cushman
and
(Operator) Myke Bailey

MODE SELECT
INPUT

OUTER DIAMETER
12.000 IN

PIPE MATERIAL
? CS-88

WALL THICKNESS
0.1420 IN

INNER LINING
? NO LING.

KIND OF FLUID
? ANOTHER

SOUND VELOCITY
1440 M/S-

SENSOR MOUNTING
? U

TYPE OF SENSOR
? SMALL

DATA CHANGE
? NO

SPACING
0.975 IN U

DAMPING SET
20 SEC

MODE SELECT
DATA SET

DATA SET MODE
? PRINTER

0443.9 MSEC
099.72 % T0

00-01 23:5600 *R
+002.70 % A12

0443.9 MSEC
099.72 % T0

00-01 23:5600 *R
+ 3.146E 36PM

00-01 23:5600 *R
+ 3.172E 36PM

OUTER DIAMETER
12.0000 IN

WALL THICKNESS
0.1421 IN


SOUND VELOCITY
1450 M/S-

SPACING
0.955 IN U

00-01 23:5703 *R
+ 3.198E 36PM

0401 WAC 56-12-9 65080-62

JUN 27 1956



T178
JOHN BEN

T885
Pocatello Tyhee Farm
#1043

T887
Pocatello Tyhee Farm
#1043

T852
7.7
7.7
8.8
HEL

T883
Pocatello Tyhee Farms
#1043

TSS
R34E

62.5

SEC. 30

HEL 2
54.5

T1182
L. Cole Ellis
#422

T64
#372
Cedar Mt. Farm

T886
Pocatello Tyhee Farm
#1043

T887
Pocatello Tyhee Farm
#1043

4.1
HEL

HEL
HEL
6.1
23.9

HEL
15.5

HEL

HEL
3.4

88.1

HEL
4.4

ROAD

65080-62

T178




Fig. 1 - Point of diversion looking north.



Fig. 2 - Point of diversion looking southwest.

May 28, 1993

CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.
POCATELLO ID 83202

PROOF ACKNOWLEDGMENT LETTER

RE: PERMIT NO. 29-08059

Dear Permit Holder:

The department acknowledges receipt of the proof of beneficial use form submitted for the above referenced permit. The next step in the process of developing a water right is for the department to conduct a field examination to determine and confirm the use being made of the water.

I note that the permit issued to you by the department requires the installation of a flow measurement port to allow the department to determine the rate of diversion. The proof which you submitted does not show that you have installed this equipment.

The installation of the flow measurement port must be complete by the time the department representative conducts the examination of your system unless the department has rescinded the requirement prior to the field examination. In some cases, the equipment requirement can be rescinded because the equipment cannot be physically installed, is not appropriate or can be accommodated with other measuring methods.

If you have questions concerning this matter, please feel free to contact the EASTERN Regional Office in Idaho Falls at (208)525-7161.

Sincerely,

Karen L. Gustafson
Secretary/Records Manager

c: IDWR - Region

Microfilm

JUN 29 1993

March 31, 1993

CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.
POCATELLO ID 83202

PROOF DUE NOTICE

RE: PERMIT NO. 29-08059

Dear Permit Holder:

One of the conditions of approval of the above referenced water permit was that proof of the extent of your beneficial use must be submitted to this office on or before June 1, 1993. (See last page of your approved permit or your last approved extension request.) Enclosed is a form which when accompanied by the license examination fee or a complete field examination report prepared by a certified water right examiner may be used to submit the required proof.


If you have not fully completed your project, and you or a previous owner of this permit have not received a prior extension of time, you may request an extension of time if the delay is for reasonable cause as provided in Section 42-204, Idaho Code. If you have been prevented from proceeding by a governmental agency or by litigation which might bring title to the water in question, more than one extension of time can be granted. An extension of time request form is enclosed for your convenience.

Either an acceptable proof of beneficial use submittal or an acceptable request for an extension of time must be received by this department on or before the above described proof due date. If neither is received, the department will send you a lapse notice. Within sixty (60) days of the mailing of the lapse notice, the permit will no longer be of any force nor effect.

SINCERELY,

Karen L. Gustafson
Secretary/Records Manager

Enclosures



MICROFILMED

JUN 29 1993

June 5, 1991

CHURCH OF JESUS CHRIST OF LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.
POCATELLO, ID 83202

PERMIT APPROVAL NOTICE

RE: PERMIT NO. 29-08059

Dear Permit Holder:

Enclosed is a copy of your approved application for permit. We direct your attention to the conditions of approval on the final page.

As a permit owner you must commence the excavation or construction of the diverting works within one year of the date the permit was issued, and you must proceed diligently until the project is completed. The date shown under condition no. 1 is the date when the project must be completed. You will receive a "Proof Due Notice" from this Department approximately 60 days prior to the completion date requiring you to file either a Proof of Beneficial Use form stating that the project has been completed or file a Request for an Extension of Time in which to file the proof statement.

Be sure to note the special condition requiring you to install a measuring device. Enclosed, for your reference, is a list of measuring device options.

Sincerely,

JIM JOHNSON
Water Rights Supervisor

JJ:blm

Enclosure

MICROFILMED

JUL 01 1991

25-Apr-1991

POCATELLO TYHEE FARM
13037 N RIO VISTA RD
POCATELLO ID 83202

RE: Application No. 29-8059

Dear Water Right Applicant:

The Department of Water Resources acknowledges receipt of your water right permit. This office is currently in the process of advertising the application in Idaho State Journal on May 2 & 9, 1991. The advertisement will be published for two consecutive weeks, and a period of ten days following the second publication will be allowed for the submittal of protests.

If the application is protested, you will be sent a copy of the protest. The protest must be resolved before the application is approved or denied. If the protest is not resolved voluntarily, this Department will conduct a conference and/or hearing on the matter.

If the application is not protested, it will be forwarded to our state office in about five weeks. State office personnel will conduct a complete review prior to final processing of the application and will notify you of the outcome of this review. When a permit is issued, you will be sent a copy. A typical processing time for an unprotested application is about eight weeks.

Please feel free to contact this office if you have any questions regarding this procedure.

Sincerely,

HAROLD W. JONES
Water Rights Supervisor

HWJ/rb

RECEIVED
WATER RIGHTS

JUL 01 1991

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
Eastern Region
150 Shoup Ave., Suite 15

Idaho Falls, Idaho 83402
(208) 525-7161

APRIL 23, 1991

IDAHO STATE JOURNAL
P.O. BOX 431
POCATELLO, ID 83204

Gentlemen:

Enclosed you will find a legal notice which we wish to have published on the dates indicated (once a week for two consecutive weekly issues) in your newspaper. If you cannot publish the notice on the proposed dates, please contact us immediately.

An affidavit of publication must be submitted to the Department along with the publication bill. Your cooperation is appreciated.

Please send the affidavit of publication and publication billing to this office before MAY 20, 1991.

Yours truly,

Rita Bodell
Secretary

Encl.

JUL 01 1991

29-08059

CHURCH OF JESUS CHRIST LATTER DAY SAINTS
POCATELLO TYHEE FARM
13037 N. RIO VISTA RD.
POCATELLO, ID 83202

Source: GROUNDWATER

Diversion Pt: NWNE Sec 30 T 05S R 34E

Use: IRRIGATION (6.000 CFS)
 Total Diversion: (6.000 CFS)

Date Filed: 3/28/ 1991

In: T05S R34E S30	NWNE	SWNE	SENE	NENW
	SENE	NESW	NWSW	SWSW
	SESW	NWSE	SWSE	SESE

448.0 ACRES TOTAL

RECORDED

JUL 01 1991

7/90

Drilling Permit No. 29-91-E-011

Water Right Permit No. 29-8059

Injection Permit No. _____

"Expedited"

State of Idaho
Department of Water Resources

"Expedited"

APPLICATION FOR DRILLING PERMIT

1. Applicant (please print) Pocatello Tyhee Farm (LDS Church)
2. Mailing Address 13037 N. Rio Vista Rd, Pocatello Id 83202
Telephone 237-6154

☒ Well Owner ☐ Well Operator ☐ Other, specify _____

3. Proposed well location NW 1/4 NE 1/4, or Gov't Lot No. _____
Sec. 30, Twp. 5S, Rge. 34E, County Bannock
Street Address of Well Site _____
Lot, block and subdivision _____

4. Proposed use of well:

☐ Domestic: The use of water for homes, organization camps, public campgrounds, livestock and for any other purpose in connection therewith, including irrigation of up to 1/2 acre of land, if the total use is not in excess of 13,000 gpd; or any other uses, if the total use does not exceed a diversion rate of 0.04 cfs and a diversion volume of 2500 gpd.

Domestic does not include water for multiple ownership subdivisions, mobile home parks, commercial or business establishments, unless the use does not exceed a diversion rate of 0.04 cfs and a diversion volume of 2500 gpd.

☒ Non-Domestic: Any beneficial use not included within the definition of domestic.

☐ Injection

☐ Monitoring - A well bore schematic and map is required for each well.
No. of proposed wells: _____

5. Well construction information:

A. ☒ New well ☐ Deepen ☐ Replace - See Condition 9

B. Proposed Surface Diameter 20" Proposed Maximum Depth 250

C. Anticipated bottom hole temperature:

- ☒ 85°F or less (Cold water well)
- ☐ 85°F to 212°F (Low temp. geothermal well)
- ☐ 212° or more (Geothermal well)

MICROFILMED
JUL 01 1991

6. Construction Start Date April 2, 1991

7. Anticipated Well Driller Cushman Well Drilling
NOTE: The actual well driller must be identified prior to drilling.

8. Applicant's signature [Signature] Date 4-1-91
Title Farm mgr. L.D.S. Church Farm
(Owner, Firm Representative, Other)

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This Permit is Approved

Date 4-1-1991

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. READ CAREFULLY!

GENERAL CONDITIONS:

1. The well must be constructed in compliance with the applicable statutes, specific conditions of approval shown on the water right permit, injection well permit, transfer or amendment and the rules and regulations of the Department for water appropriation, injection wells and well construction standards.
2. This drilling permit is valid for two (2) months from the above approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
3. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare which may be required before construction of this well.
4. The well shall be constructed by a driller currently licensed in the State of Idaho who must maintain a copy of the drilling permit at the drilling site.
5. Approval of this drilling permit does not authorize trespass on the land of another party.
6. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.
7. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
8. If a bottom hole temperature of 85° or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
9. If this permit is for a replacement well, the well being replaced must be abandoned in accordance with Department Rules and Regulations.

SPECIFIC CONDITIONS:

SEE ATTACHED CONDITIONS

MICROFILMED

JUL 01 1991

Signature of Authorized Department Representative

Title

REGIONAL MANAGER

Receipt No. E 015885 Received by KCW Fee 200⁰⁰ Date 4-1-1991

EXTENSION OF DRILLING PERMIT

Extension approved by _____ Approval Date _____

This extension is good for 60 days beyond the above extension approval date.

Drilling Permit
29-91-E-011

ADDENDUM TO DRILLING PERMIT

1. APPLICATIONS, AS NECESSARY, ARE ON FILE SEEKING AUTHORIZATION TO USE THE WELL FOR THE PURPOSE FOR WHICH IT IS BEING DRILLED.
2. THERE ARE NO APPARENT REASONS THAT THE PENDING APPLICATIONS WILL NOT BE APPROVED AUTHORIZING USE OF THE WELL.
3. THE APPLICANT HAS REQUESTED BY LETTER THROUGH HIS AGENT THAT EXPEDITED APPROVAL IS NEEDED FOR IMMEDIATE CONSTRUCTION.
4. THE DRILLING PERMIT IS CONDITIONED TO SHOW THAT THERE IS NO AUTHORIZATION FOR DIVERSION AND USE OF WATER UNTIL THE WATER RIGHT APPLICATION IS APPROVED.
5. THE APPLICANT BY ACCEPTING THIS DRILLING PERMIT AND COMMENCES CONSTRUCTION ACKNOWLEDGES THAT HE ACCEPTS ALL RISK THAT THE WELL MAY NOT BE APPROVED FOR USE.

RECEIVED
JUL 01 1991

SD-36	Township: 05S	Range: 34E	Section: 30	T	ct:	Lot:	Max # Records	10	
S	L	ST. L	O	W	T	Priority	Use		
E	O	Water	Name	N	AC	G	Date	Code Desc	
L	Tract	T	Right No.	Last, First					
			27-02007	U.S. DEPT. OF INTERIOR	C		L	09/03/1907	01 IRR
								43 DOMEST	
			27-02035	U.S. DEPT. OF INTERIOR	C		L	02/06/1928	01 IRR
								43 DOMEST	
			27-02087	U.S. DEPT. OF INTERIOR	C		P	11/02/1923	01 IRR
								43 DOMEST	
	SENE		29-07437	J.R. SIMPLOT CO.	C	40	P	05/20/1978	01 IRR
								02 IRR S	
								03 IRR FS	
								55 DIV S	
	SWNW		29-07343	DAVIS, DALE T.	C		L	08/16/1976	04 STOCK
								43 DOMEST	
	SESW		29-04388	CHURCH OF JESUS CHRIST	C		S	04/01/1930	04 STOCK
								43 DOMEST	
	NWSE		29-07437	J.R. SIMPLOT CO.	C	40	P	05/20/1978	01 IRR
								02 IRR S	

(Enter-Continue)

(GOLD 7=This Query)

(Menu _____)

MICROFILMED
JUL 01 1991

SD-36	Township: 05S	Ran : 34E	Section: 30	Tract:	Lot:			
S	L	STA	O	Max # Records	10			
E	O	Water	Name	Priority	Use			
L Tract T	Right No.	Last, First	N	AC	G			
Date	Code	Desc						
NWSE	29-07437			40	P	05/20/1978	03	IRR FS
							55	DIV S
SWSE	29-07437	J.R. SIMPLOT CO.	C	40	P	05/20/1978	01	IRR
							02	IRR S
							03	IRR FS
							55	DIV S
SESE	29-04390	CHURCH OF JESUS CHRIST	C		S	01/01/1924	04	STOCK
							43	DOMEST
SESE	29-07437	J.R. SIMPLOT CO.	C	40	P	05/20/1978	01	IRR
							02	IRR S
							03	IRR FS
							55	DIV S

(Enter=Continue)

(GOLD 7=This Query)

(Menu _____)

RECEIVED
JUL 01 1991

FROM: POCATELLO TYHEE FARM

28 MARCH 1991

TO: APPLICATION FOR PERMIT - GROUNDWATER

SUBJECT: SUPPLEMENTAL INFORMATION

RULE 4,5,3,1,3 - THIS GROUNDWATER WELL WILL BE USED ONLY AS A SUPPLEMENTAL WATER RIGHT WHEN FORT HALL IRRIGATION CO. WATER IS NOT AVAILABLE.

RULE 4,5,3,2,1 - NORMAL IRRIGATION SEASON FOR FORT HALL WATER 05/05 TO 10/15 FOR 169 DAYS.

AVERAGE ANNUAL CONSUMPTIVE IRRIGATION REQUIREMENT FOR THE MOST CONSUMPTIVE USE (ALFALFA) FOR POCATELLO = 1.88 AF/A (448 ACRES X 1.88 AF/A = 843.7 AFA)

APPLICANT PLANS TO USE THIS WELL ONLY AFTER HIS FORT HALL WATER HAS BEEN CUT. THEREFORE AT THE PROPOSED DIVERSION RATE THE AFA WOULD EQUAL:

@ 6.0 CFS X 1.9835 X 245 DAYS = 2915.7 AFA

@ 6.0 CFS X 1.9835 X 169 DAYS = 2011.3 AFA

ASSUMING THAT THE APPLICANT GETS SOME WATER FROM FORT HALL THE ANNUAL VOLUME SHOULD BE LESS THAN EVEN THE 2011.3 AFA SINCE HE WILL ONLY OPERATE THE SYSTEM AFTER THE FORT HALL WATER IS CUT.

APPLICATION IS FOR ONLY 0.0133 CFS/ACRE = 0.67 MINERS INCHES PER ACRE. WHICH IS SUFFICIENT FOR MOST CORPS USING SPRINKLER IRRIGATION.


RULE 4,5,3,2,2 - THERE ARE SEVERAL WELLS IN THE AREA. SOME OF THE WELLS ARE DRILLED FROM 77 TO 89 FEET, OTHERS ARE DRILLED FROM 113 TO 204 FEET. THERE APPEARS TO BE A CLAY LAYER SEPARATING THESE SHALLOW AND THE DEEPER WELLS. THE STATIC WATER LEVEL FOR THE SHALLOW WELLS STANDS AT 35 TO 49 FEET, AND FOR THE DEEP WELLS FROM 28 TO 83 FEET. (SEE ATTACHED WELL LOGS.)

THE APPLICANT PLANS TO DRILL APPROXIMATELY 250 FEET. WITH THE LIMITED USE OF THIS WELL IT WOULD SEEM THAT THERE SHOULD BE ONLY MINIMAL IF ANY AFFECT ON THE OTHER WELLS IN THE AREA.

RULE 4,5,3,3 - THE POCATELLO TYHEE FARM IS A FARM OF THE LDS WELFARE SYSTEM. ONLY THE WELL NEEDS TO BE DRILLED AS THE IRRIGATION SYSTEM IS ALREADY IN PLACE TO DELIVER THE FORT HALL IRRIGATION CO. WATER.

FILED
JUL 01 1991


TAFT C. MILNER



PROPOSED WELL

MICHIGAN
JUL 01 1991

Pocatello Tyhee farm.

Rule A, 5, 3, 1, 2

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer
within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Herman Refort
Address 619 S. 11 Pocatello, Idaho
Owner's Permit No. _____

7. WATER LEVEL

Static water level 114 50 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☐ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning) _____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
20	none	1

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☒ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 87 feetCasing schedule: ☐ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>80</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____


Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal? ☒ Yes ☐ No To what depth 18 feet
Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.

County Tennock1/4 Sec. 20 T. 5 N/S, R. 34 E/W

10.

Work started 11/23/70 finished 11/24/70

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is
true to the best of my knowledge.

BOHN, CUSHMAN DRILLING CO. Number _____

Address 415 Division Road Blackfoot, Idaho 83201

Signed By _____ Date _____

USE TYPEWRITER OR
BALL POINT PEN

State of Idaho
Department of Water Administration

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer
within 30 days after completion or abandonment of the well.

DEC 29 1971

RECEIVED

1. WELL OWNER

Name Don Mihu
18. E. Laughlin Rd.
Address Bonanza, Idaho 83201
Owner's Permit No. _____

7. WATER LEVEL

Department of Water Administration
Eastern District Office

Static water level 35 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

air test
☐ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
20	none	

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 77 feet
Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches
Number _____ From _____ To _____
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet


Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☒ Yes ☐ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal? ☒ Yes ☐ No To what depth / 18 feet
Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.



MICROFILMED
July 01, 1991

County Bannock
Bingham
N. 1/4 Sec. 30, T. 5 S. N/S, R. 10 E/W

10.

Work started Sept. 9, 71 finished Sept. 13, 71

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

Donz Gushean Drilling Co.
Driller's or Firm's Name _____ Number _____
Rt. 3 Box 1 Blackfoot, Idaho
Address _____
Donz Gushean
Signed By _____ Date 12/29/71

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE, BLUE, AND PINK COPIES TO THE DEPARTMENT

POOR QUALITY
RECEIVED 663

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources, within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name RON BEFORT

Address Rt 2 , North, Lofgren Road, Pocatello,
ID 83201

Owner's Permit No. _____

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 80 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness

Diameter

From

To

.250 inches 6 inches + 1 feet 79 feet

_____ inches _____ inches _____ feet _____ feet

_____ inches _____ inches _____ feet _____ feet

_____ inches _____ inches _____ feet _____ feet

_____ inches _____ inches _____ feet _____ feet

Was casing drive shoe used? ☒ Yes ☐ No

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☐ Yes ☒ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number

From

To

_____ perforations _____ feet _____ feet

_____ perforations _____ feet _____ feet

_____ perforations _____ feet _____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 18' Material used in seal ☐ Cement grout

☒ Puddling clay ☐ Well cuttings

Sealing procedure used ☐ Sherry pit ☐ Temporary surface casing

☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.

N

W

E

S

</

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT

POOR QUALITY

State law requires that this report be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

USE ADDITIONAL SHEETS IF NECESSARY FORWARD THE WHITE, BLUE, AND PINK COPIES TO THE DEPARTMENT

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Administration within 30 JUL 30 1974
days after the completion or abandonment of the well.Department of Water Resources
Eastern District Office

1. WELL OWNER

Name Jack Woodward
Address _____
Owner's Permit No. _____

7. WATER LEVEL

Static water level 28' feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature 46° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning) _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other
Discharge G.P.M. 40-45 Draw Down _____ Hours Pumped 7 hrs.

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type) _____
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED


☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 151 feet
Casing schedule: ☒ Steel ☐ Concrete
Thickness Diameter From To
.250 inches 6 inches 1 feet 151 feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feetWas a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☒ Torch
Size of perforation _____ inches by _____ inches
Number From To
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feetWell screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter Slot size Set from _____ feet to _____ feet
Diameter Slot size Set from _____ feet to _____ feetGravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal depth 18 Material used in seal ☒ Cement grout
☐ Pudding clay ☐ Well cuttings
Sealing procedure used ☐ Slurry pit ☐ Temporary surface casing
☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location:



Subdivision Name _____

Lot No. _____ Block No. _____

County Bannock
NE 1/4 NW 1/4 Sec. 30, T. 5 N. R. 34 E

10.

Work started June '74 finished June '74

11. DRILLERS CERTIFICATION

Firm Name Northwest Drilling Firm No. 238
Address 1423 Rushing Date _____
Signed by (Firm Official) Dean Mitchell
and
(Operator) _____

USE TYPEWRITER OR
BALL POINT PEN

State of Idaho
Department of Water Resources

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name VIRGIL HATHOWAY
Address WEST CHURBUCK ROAD
Owner's Permit No. _____

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☒ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 143 feet
Casing schedule: ☐ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>.250</u> inches	_____ inches	<u>18"</u> feet	<u>143</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal depth 20' Material used in seal ☐ Cement grout
☒ Puddling clay ☐ Well cuttings
Sealing procedure used ☐ Shurry pit ☐ Temporary surface casing
☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.

Sketch map location must agree with written location. 59
Subdivision Name _____
Lot No. _____ Block No. _____
County BANNECK
NW 1/4 NW 1/4 Sec. 30 T. 5 N/S. R. 34 E/W

7. WATER LEVEL

Static water level 55' feet below land surface
Flowing? ☐ Yes ☐ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☒ Bailor ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
<u>15</u>	<u>140'</u>	

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
8"	0	20	TOP SOIL		☒
6"	20	28	TOP SOIL		☒
	28	41	GRAVEL & CLAY		☒
	41	68	CLAY		☒
	68	82	SAND		☒
	82	97	CLAY & SAND		☒
	97	126	SAND		☒
	126	140	CLAY		☒
	140	143	FINE GRAVEL		☒

RECEIVED

JAN 5 1978

Department of Water Resources
Eastern District Office

10.

Work started 11/28/75 finished 12/12/75

11. DRILLERS CERTIFICATION

Firm Name DUBBE DRILLING Firm No. 148

Address P.O. Box 4465 Date 12/21/75

Signed by (Firm Official) M. H. Dubbe

and
(Operator) Original Signed

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name BERT HUTH

Address Box 1026 PONTIELLO ID 83201

Owner's Permit No. _____

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe in remarks) _____

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test

☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☒ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 8" inches Total depth 154.6" feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness .250 inches Diameter 8.125 inches From 0.0 feet To 154.6 feet

1 inches 8.125 inches _____ feet _____ feet

1 inches 8.125 inches _____ feet _____ feet

1 inches 8.125 inches _____ feet _____ feet

1 inches 8.125 inches _____ feet _____ feet

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☐ Yes ☒ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number _____ From _____ To _____

_____ perforations _____ feet _____ feet

_____ perforations _____ feet _____ feet

_____ perforations _____ feet _____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal? ☒ Yes ☐ No To what depth 20 feet

Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.

N

W

E

S

WELL SITE

County BANWICK

NE 1/4 Sec 30 T 5 S R 34 E 4

7. WATER LEVEL

Static water level 58' feet below land surface

Flowing? ☐ Yes ☒ No G.P.M. flow _____

Temperature _____ ° F. Quality _____

Artesian closed-in pressure _____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☒ Bailer ☐ Other

Discharge G.P.M.

Draw Down

Hours Pumped

120

NONE

4 HRS

1 HP PUMP

15 G.P.M.

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
10"	0	20	DIRTY ROCK		
8"	20	31	ROCK DOOLIES		
"	31	50	SAND		
	50	70	CLAY HARD PAN		
	70	87	GRAVEL		
	87	108	CLAY ROCK CONGLOMERATE		
	108	120	CLAY HARD PAN		
	120	149	REAL FINE SAND		
	149	154.6	PEA GRAVEL & COARSE SAND		

10.

Work started 12/20/70 finished 1/4/71

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

Dubbe Drilling

Driller's or Firm's Name

147

Number

P.O. Box 4465 PONTIELLO ID 83201

Address

1000 H.D.

Signed By

2/5/71

Date

POOR QUALITY

RECEIVED

DEC 29 1971

[illegible]

FORWARD THE WHITE, BLUE, AND PINK COPIES TO THE DEPARTMENT

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer
within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Rate Sevuell
Address tyhee Idaho
Owner's Permit No. NONE

7. WATER LEVEL

Static water level 47 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature 51 ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pump ☒ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☒ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6" inches Total depth 185 feet
Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>280</u> inches	<u>6"</u> inches	<u>0</u> feet	<u> </u> feet


Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To

Well screen installed? ☐ Yes ☒ NoManufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feetGravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal? ☒ Yes ☐ No To what depth 18 feet
Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.

County Minnehaha
SW 1/4 Sec 30 T. 5 S. R. 34 E/W

10.

Work started Sept. '70 finished Sept. '70

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is
true to the best of my knowledge.

Driller's or Firm's Name

Number

Address

Signed By

Date

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

JAN 15 1982

1. WELL OWNER Name <u>Ronald Miller</u> Address <u>Rt. #2 Box 1885, Pocatello, ID</u> Owner's Permit No. _____	7. WATER LEVEL Dep. _____ Eastern District Office Static water level <u>83</u> feet below land surface. Flowing? ☐ Yes ☒ No G.P.M. flow _____ Artesian closed-in pressure _____ p.s.i. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature <u>56</u> °F. Quality _____																																																			
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe method of abandoning) _____	8. WELL TEST DATA ☐ Pump ☐ Bailor ☒ Air ☐ Other _____<table border="1" style="width:100%; border-collapse: collapse;"><tr><th>Discharge G.P.M.</th><th>Pumping Level</th><th>Hours Pumped</th></tr><tr><td style="text-align: center;">30</td><td></td><td></td></tr></table>	Discharge G.P.M.	Pumping Level	Hours Pumped	30																																															
Discharge G.P.M.	Pumping Level	Hours Pumped																																																		
30																																																				
3. PROPOSED USE ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type)	9. LITHOLOGIC LOG<table border="1" style="width:100%; border-collapse: collapse;"><tr><th rowspan="2">Hole Diam.</th><th colspan="2">Depth</th><th rowspan="2">Material</th><th colspan="2">Water</th></tr><tr><th>From</th><th>To</th><th>Yes</th><th>No</th></tr><tr><td rowspan="8" style="text-align: center; vertical-align: middle;">6"</td><td style="text-align: center;">0</td><td style="text-align: center;">30</td><td>Clay bolder</td><td></td><td style="text-align: center;">X</td></tr><tr><td style="text-align: center;">30</td><td style="text-align: center;">70</td><td>Fine Sandy gravel</td><td></td><td style="text-align: center;">X</td></tr><tr><td style="text-align: center;">70</td><td style="text-align: center;">80</td><td>Clay-white</td><td></td><td style="text-align: center;">X</td></tr><tr><td style="text-align: center;">80</td><td style="text-align: center;">86</td><td>Brown Clay</td><td style="text-align: center;">X</td><td></td></tr><tr><td style="text-align: center;">86</td><td style="text-align: center;">96</td><td>Sand-gravel/ brown clay</td><td style="text-align: center;">X</td><td></td></tr><tr><td style="text-align: center;">96</td><td style="text-align: center;">118</td><td>White clay</td><td style="text-align: center;">X</td><td></td></tr><tr><td style="text-align: center;">118</td><td style="text-align: center;">145</td><td>Gravel</td><td style="text-align: center;">X</td><td></td></tr><tr><td style="text-align: center;">145</td><td style="text-align: center;">150</td><td>Gravel</td><td style="text-align: center;">X</td><td></td></tr></table>	Hole Diam.	Depth		Material	Water		From	To	Yes	No	6"	0	30	Clay bolder		X	30	70	Fine Sandy gravel		X	70	80	Clay-white		X	80	86	Brown Clay	X		86	96	Sand-gravel/ brown clay	X		96	118	White clay	X		118	145	Gravel	X		145	150	Gravel	X	
Hole Diam.	Depth		Material	Water																																																
	From	To		Yes	No																																															
6"	0	30	Clay bolder		X																																															
	30	70	Fine Sandy gravel		X																																															
	70	80	Clay-white		X																																															
	80	86	Brown Clay	X																																																
	86	96	Sand-gravel/ brown clay	X																																																
	96	118	White clay	X																																																
	118	145	Gravel	X																																																
	145	150	Gravel	X																																																
4. METHOD DRILLED ☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary ☐ Cable ☐ Dug ☐ Other _____	RECEIVED DEC 29 1981 Department of Water Resources Eastern District Office MICROFILMED July 01, 1991																																																			
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other <table style="width:100%;"><tr><td>Thickness</td><td>Diameter</td><td>From</td><td>To</td></tr><tr><td><u>.250</u> inches</td><td><u>6</u> inches</td><td><u>1</u> feet</td><td><u>149</u> feet</td></tr><tr><td>_____ inches</td><td>_____ inches</td><td>_____ feet</td><td>_____ feet</td></tr><tr><td>_____ inches</td><td>_____ inches</td><td>_____ feet</td><td>_____ feet</td></tr><tr><td>_____ inches</td><td>_____ inches</td><td>_____ feet</td><td>_____ feet</td></tr></table>Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☐ Yes ☒ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation _____ inches by _____ inches <table style="width:100%;"><tr><td>Number</td><td>From</td><td>To</td></tr><tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr><tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr><tr><td>_____ perforations</td><td>_____ feet</td><td>_____ feet</td></tr></table>Well screen installed? ☐ Yes ☒ No Manufacturer's name _____ Type _____ Model No. _____ Diameter _____ Slot size _____ Set from _____ feet to _____ feet Diameter _____ Slot size _____ Set from _____ feet to _____ feet Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____ Placed from _____ feet to _____ feet Surface seal depth <u>18</u> Material used in seal: ☐ Cement grout ☒ Puddling clay ☐ Well cuttings Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☒ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld ☐ Cemented between strata Describe access port _____		Thickness	Diameter	From	To	<u>.250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>149</u> feet	_____ inches	_____ inches	_____ feet	_____ feet	_____ inches	_____ inches	_____ feet	_____ feet	_____ inches	_____ inches	_____ feet	_____ feet	Number	From	To	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet																			
Thickness		Diameter	From	To																																																
<u>.250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>149</u> feet																																																	
_____ inches	_____ inches	_____ feet	_____ feet																																																	
_____ inches	_____ inches	_____ feet	_____ feet																																																	
_____ inches	_____ inches	_____ feet	_____ feet																																																	
Number	From	To																																																		
_____ perforations	_____ feet	_____ feet																																																		
_____ perforations	_____ feet	_____ feet																																																		
_____ perforations	_____ feet	_____ feet																																																		
6. LOCATION OF WELL Sketch map location must agree with written location. N W E S Subdivision Name _____ Lot No. _____ Block No. _____ County <u>Bannock</u> SW ¼ SE ¼ Sec. <u>30</u>T. <u>5</u> N/S. R. <u>34</u> E/W	10. Work started <u>8-24-81</u> finished <u>8-24-81</u> 11. DRILLERS CERTIFICATION I/We certify that all minimum well construction standards were complied with at the time the rig was removed. Doug Cushman Firm Name <u>Drilling Co.</u> Firm No. <u>367</u> <u>945 S. Broadway</u> Address <u>Blackfoot, ID</u> Date <u>12-2-81</u> Signed by (Firm Official) _____ and _____ (Operator) _____ 1453																																																			

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30
days after the completion or abandonment of the well.

1. WELL OWNER

Name Steven Wheeler
Address 1109 Wilson Ave
Poc, Ida
Owner's Permit No. _____

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or
Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 132 feet
Casing schedule: ☐ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>132</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet


Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feetGravel packed? ☐ Yes ☐ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal depth 20 Material used in seal ☒ Cement grout
☐ Puddling clay ☐ Well cuttings
Sealing procedure used ☐ Slurry pit ☒ Temporary surface casing
☐ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County BannockNW 1/4 NW 1/4 Sec. 30, T. 5 N. S. R. 34 E. N

7. WATER LEVEL

Static water level 65 feet below land surface
Flowing? ☐ Yes ☐ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailor ☒ Other Air test

Discharge G.P.M.	Draw Down	Hours Pumped
<u>20-25</u>		<u>1</u>

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
8	0	9	Brown clay		☒
8	9	20	SAND + GRAVEL + GAULT		☒
6	20	40	GRAVEL + SAND		☒
6	40	50	" "		☒
	50	60	tan clay		☒
	60	75	green clay		☒
	75	80	Brown quick sand		☒
	80	100	" "		☒
	100	125	Brown clay		☒
	115	132	SAND + GRAVEL		☒

RECEIVED

MAY 28 1975

Department of Water Resources
Eastern District OfficeMICROFILMED
July 04 1971

10.

Work started 5-17-75 finished 5-19-75

11. DRILLERS CERTIFICATION

Firm Name Lundstrom Well Drilling Firm No. 118Address 441 South 2th Poc Date 5-19-75Signed by (Firm Official) Arnell Lundstrom
and
(Operator) Arnell Lundstrom

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

RECEIVED
 1964 JUN 10 10 30 AM
 1964 JUN 10 10 30 AM

[illegible]