

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

October 11, 2001

COPY

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Bill Arkoosh  
2005 Hwy 26  
Gooding, Idaho 83330

Dear Bill,

Zane advised me that your diversion Devaney # 86-P, needs to have a meter installed on the pump. Please have this meter installed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.


Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,



Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

October 11, 2001

COPY

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Moj Brodie  
P O Box 706  
Picabo, Idaho 83348

Dear Moj,

Skip, advises me that you need to repair the headgate at your Brodie #23 diversion. Please have these repairs completed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, appearing to read "Lee R. Peterson".  
Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES



LEE R. PETERSON  
Watermaster

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451

COPY

October 11, 2001

Fred Brossey  
Box 669  
Shoshone, Idaho 83352

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear Fred,

The following diversions need to have meters installed on the pumps, Meyers # 74 and Meyers 75-A1. Please have these meters installed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.


Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,



Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

COPY

October 11, 2001

Richard Dinges  
2490 East 1700 South  
Gooding, Idaho 83330

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear Richard,

Zane advised me that your diversion Hitchcock # 82 needs to have a meter installed on the pump. Please have this meter installed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".

Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

October 11, 2001

COPY

Alton Huyser  
72 Hwy 75  
Shoshone, Idaho 83352

RECEIVED

OCT 15 2001

Department of Water Resources  
Southern Region

Dear Alton,

Skip has advised me that you need to install workable meters at your White 68-P, White 68-P1 and White 68-P2 diversions. Please have these meters installed on or before April 1, 2002. There will be no delivery of water to these diversions until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".

Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

COPY

October 11, 2001

Calvin Kuntz  
P O Box 124  
Gooding, Idaho 83330

Dear Mr. Kuntz,

Zane advised me that your diversion Kuntz # 98P, needs to have a meter installed on the pump. Please have this meter installed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.


Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,



Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451

COPY



LEE R. PETERSON  
Watermaster

October 11, 2001

A. W. Molyneux  
1174 Gannett Picabo Road  
Bellevue, Idaho 83313

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear Bill,

Skip, advises me that your Mac # 38 diversion needs to have repairs made to the headgate. Also your Molly 39-P diversion needs to have a meter installed on the pump. Please have these repairs completed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".

Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

October 11, 2001

COPY

Rick Oneida  
621 Silver Beach Dr.  
Jerome, Idaho 83338-6486

RECEIVED

OCT 15 2001

Department of Water Resources  
Southern Region

Dear Mr. Oneida,

My deputy advises me that you need to repair the headgate at your Bock #67 diversion. Please have these repairs completed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, appearing to read "Lee R. Peterson", is written over the typed name.

Lee R. Peterson  
Watermaster

CC: IDWR



STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

COPY

October 11, 2001

Gary Osborne  
1776 E 1625 S  
Gooding, Idaho 83330

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear Gary,

Zane advised me that the meter on the pump at your diversion, Jones 35-P3, is not working and needs to be repaired. Please have the necessary repairs done on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in black ink, appearing to read "Lee R. Peterson", is written over a horizontal line.

Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

October 11, 2001

COPY

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

William Palacio  
P O Box 281  
Gooding, Idaho 83330

Dear Bill,

Zane advised me that your diversion Deasey # 30, needs to have a meter installed on the pump. Please have this meter installed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".

Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES



LEE R. PETERSON  
Watermaster

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451

October 11, 2001

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Bud Purdy  
P O Box 688  
Picabo, Idaho 83348

COPY

Dear Bud,

Skip, advises me that the Gillihan # 11 diversion needs to have repairs made to the headgate. Please have these repairs completed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".  
Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

October 11, 2001

COPY

James Ritter  
Star Route  
Richfield, Idaho 83349

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear Mr. Ritter,

My deputy advises me that you need to repair the headgate at your Ritter #65 diversion. Please have these repairs completed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.


Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

  
Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES



LEE R. PETERSON  
Watermaster

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451

COPY

October 11, 2001

David Sliman  
1642 B Hwy 46  
Gooding, Idaho 83330

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear David,

Zane advised me that the meter on the pump at your diversion, Silk 31-P, is not working and needs to be repaired. Please have the necessary repairs done on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".  
Lee R. Peterson  
Watermaster

CC: IDWR

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

**WATER DISTRICT NO. 37 & 37 M**

P.O. Box T  
Shoshone, Idaho 83352  
(208) 886-2451



LEE R. PETERSON  
Watermaster

COPY

October 11, 2001

Joe Sorenson  
45 Old State Hwy  
Carey, Idaho 83370

**RECEIVED**

**OCT 15 2001**

Department of Water Resources  
Southern Region

Dear Joe,

Skip, advises me that the following diversions need to have meters installed on the pumps, Ragsdale 44-P, Ragsdale 44-P1, and Cook 41-P. Please have these meters installed on or before April 1, 2002. There will be no delivery of water to this diversion until the necessary repairs are complete.


Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

If we can be of any assistance please feel free to call.

Sincerely,

  
Lee R. Peterson  
Watermaster

CC: IDWR