Water District 36-A Diversion Report January 2004

diversion name	Measuring Device	Remarks
JOHNSON HATCHERY	Weir	OK by IDWR; ck w/Frank
JONES HATCHERY	Weir	Good Condition
JONES IRRIGATION PUMPS	PCC calibration	Calibrations by IDWR, may require flow meter
JOSEPH HYDROPOWER	No use	
LEE HATCHERY (Schrank)	Weir	OK by IDWR; ck w/Frank?
MAIN SPRING (Nat'l. Hatchery)	Marshall Flume	Combined w/USFWS springs 8-11
MCFADDEN PUMP Billingsly, JR	PCC calibration	Currently owned by Idaho State Parks
MUSSER PIPE		No Water Delivered In 2003
MUSSER PUMP AT SPRING CK.	PCC ?	
NORWOOD SUBDIVISION PIPE	Flow Meter	Good Condition
OSTER LAKES STATE WEIR	Weir	Good Condition
PADGETT DITCH *	Submerged orifice	Install New Device In 2004
POTTER SPRINGS	Flow meter ?	Watermaster did not visit, owner said flow meter won't turn water
RANGEN HATCHERY	Weir	Good Condition
RANGEN PIPE *		Probably should have flow meter
RILEY CREEK	OK	
RILEY PUMPBACK		
SANDS DITCH	Weir - Rated Section	Need To Check Accuracy
SPRING 10, TUNISON	OK	
SPRING 11	OK	
SPRING 12	OK	
SPRING 13	OK	
SPRING 14	OK	
SPRING 15	OK	
SPRING 16	OK	
SPRING 17	OK	
SPRING 8 & 9	OK	
SPRING CREEK SPRING PIPE	None	
TALBOTT PONDS	Weir	
THREE SPRINGS & WEATHERBY	Flow Meter	Good Condition
TUPPER HATCHERY	Weir	mats over concrete boards
UPR TUCKER LARGE PIPE	Flow Meter	Good Condition
UPR TUCKER SMALL PIPE	Flow Meter	Good Condition

Water District 36-A Diversion Report January 2004

SUBMITTED by FRANK OWEN

diversion name	Measuring Device	Remarks
ANDERSON POND DITCH IDFG *	PARSHALL Flume	Submergence Conditions. Need replacement or upgrade
BAR-S DITCH	Weir	Good Condition
BARLOGI DITCH	~~Cut-throat~~ Flume	Need to check accuracy
BICKEL LAKE	Weir	Good Condition
BIG BEND DITCH - LOWER *	Weir - TRAPEZOIDAL	Needs Staff Gauge - Submergence Summer Mos
BIG BEND DITCH-UPPER	Weir -	Good Condition / Both Devices not mess/read frequently enough
BIG SPRING PIPELINE *	Pitot Tube	Contact Gary Lemman
BILLINGSLEY BAY HTCHERY	Weir	Good Condition
BOYER PONDS	Weir	Good Condition
BRAILSFORD DITCH	Weir	Good Condition
BRANCHFLOWER HYDROPOWER	Rated Turbines	Acceptable by IDWR
BUCKEYE DITCH	Weir	Hard to read head on staff gauge
CANDY PIPE	NONE	Delivered Domestic and one drip line 30 Gal / Hour
CONYERS DITCH	Weir	Good Condition - Reports 40 cfs each year
CRANDLEMIRE PIPE	NONE	No Water Delivered In 2003
CURRAN DITCH	Weir	Good Condition
E.M. BELL DITCH *	RATED SECTION	Need to check accuracy.
FISHERIES DEV/BILLINGSLEY	Weir	Good Condition
FISHERIES DEV/SPRINGS	Weir	Good Condition
FLORENCE LIVESTOCK SPRING	Flow Meter	Good Condition
FLORENCE SPRING IDFG WMA	WEIRS	IDFG WMA
GRIDLEY ISLAND PIPELINE	None	Working on measuring device for 2004
HAGERMAN HATCHERY Flow CK	Flow Meter ?	Need to check accuracy
HAGERMAN WATER USERS ASSN	Weir	Good Condition
HIDDEN SPRINGS HATCHERY	Weir	Good Condition
HOAGLAND TUNNEL DITCH *	None	Install in 2004
HUNT DITCH *	Submerged Orifice	Install New Device In 2004
IDAHO POWER DITCH	Weir	Good Condition
IDAHO POWER PIPE DITCH	Flow Meter	Calibrated by IDWR or last mo. ?
IDAHO SPRGS @ BILLINGSLEY	RACEWAY WEIRS	
IDAHO SPRINGS @ BIG SPGS	RACEWAY WEIRS	
IDAHO SPRINGS @TUPPER	RACEWAY WEIRS	
JOHN BELL DITCH	Weir	Good Condition