

Water District No. 63 Little Camas/Cat Creek sub-district

Date	Little Camas Creek (inflow, cfs/creek level)	Cat Creek (inflow, cfs/creek level)	Little Camas reservoir Level (out-flow)	Rhead Reservoir level (out-flow)
3-23-17			25'6" - 6966 A.F.	Filled Last fall with well to 50%
4-3-17			32'0" - 12,400 A.F.	70% full
4-12-17	LOTS OF WATER MAKING	500" - 10 C.F.S.	34'6" - 15,150 A.F.	
4-25-17			37'0" - 17,650 A.F.	
4-28-17	Over 2000"	PAT SPLASH BOUNDS IN 400" - 8 C.F.S.	37'6" - 18,945 A.F.	80% full
5-2-17			38'0" - 19,130 A.F.	
5-15-17	1800"	250" 5 C.F.S.	39'0" - 21,045 A.F.	95% full
5-16-17	1200		OPEN LC RESUIOR 15 THURS	
5-22-17	1800 - 16 CFS	150" - 3 C.F.S.	OPEN LC 2 THURS	100% full
5-31-17		200 - 4 C.F.S.	38'9" - 2200" @ LTW	
6-27-17	400" - 8 CFS	25" - .5 CFS.		100% full
7-7-17	300" 4 C.F.S.		Broke LC. Headgate stem Fixed stem @ LC.	90% full
7-18-17				
7-20-17			34'0" - 14,570 A.F.	
7-31-17	75" 1.5 C.F.S.		32'6" - 12,920 A.F.	80% full
8-15-17	10" - .2 CFS	0 - dry	30'3" - 10,675 A.F.	75% full
8-18-17			28'0" - 8780 A.F.	
9-1-17			23'6" - 5708 A.F.	70% full
9-15-17			CLOSE LC Reservoir	
9-24-17			20'6" 4058 A.F.	60% full

There will be no budget for 2018 water year again  
 Jerry Seegrist water master 63-C