Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp ____ Rge ____ Sec ____
____ 1/4 ____ 1/4 ____ 1/4
Lat: : : Long: : :

POSTED

1. WELL TAG NO. D 0022402
DRILLING PERMIT NO. 79-877
Other IDWR No.

2. OWNER:
Name Steve King
Address 8607 384th AVE S.E.
City Snoqualmie State WA Zip 98065

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 59 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 23 ____ 1/4 NE (10 acres) 1/4 NW (40 acres) 1/4 (160 acres)
Gov't Lot ____ County Bonner
Lat: : : Long: : :
Address of Well Site _____
City Coolin
(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentnite	0	18	6	Temp casing

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 84
Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	84	250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
Perforations
Screens
Method _____
Screen Type Telescoping

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
84	89	25		6	SS	☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
45 ft. below ground Artesian pressure ____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

59N 4W 23

11. WELL TESTS:
☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10+	1 Foot	46'	2 hours

Water Temp. Cold Bottom hole temp. _____
Water Quality test or comments: _____
Depth first Water Encounter 48

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	18	Sand Boulders		✓
6	18	30	Sand Boulders		✓
6	30	48	Sand "med"		✓
6	48	90	Sand "fine - med"	✓	

RECEIVED
SEP 23 2002
IDWR North

RECEIVED
FEB 18 2003
IDWR North

Completed Depth 89 (Measurable)
Date: Started 7-3-02 Completed 7-29-02

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Carl Pitts & Son Drilling Firm No. 168
Firm Official Steve Pitts Date 8-2-02
and
Driller or Operator Joe Ockert Date 8-2-02
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES