

RECEIVED

DEC 17 2024

Form 235-3, 9/2023

IDAHO DEPARTMENT OF
WATER RESOURCES

Idaho Dept. of Water Resources

WATER RESOURCES
SOUTHERN REGION

Department Use Only

Permit ID: 918718

Basin No.: 65

Metal Tag No.: D0106128

Start Card Permit - Single Family Domestic Well Only

(Cold Water less than 85°F)

1. **Property Owner (please print):** Better Budget Builders

2. **Current Mailing Address:** 4713 W HEARST DR

City: MERIDIAN State: ID Zip Code: 83642-4691 Telephone ()

3. **Proposed Well Location:** Twp. 10N Rge. 01E Sec. 24 1/4 NE 1/4 SW 1/4

Gov't Lot No. 0 County GEM COUNTY Lat. 44 11.069000 Long. -116 17.232000

Street Address of Well Site 22350 High Valley Rd City OLA

Give at least name of road + Distance to Nearest Road or Landmark

Lot, block and subdivision Unknown Unknown Unknown

4. Are all adjacent septic tanks and drain fields accurately located? By Property Owner: Yes ☒ No ☐

By Health District: Yes ☐ No ☒

5. **Well Construction Information:** A. ☒ New well ☐ Replace ☐ Deepen ☐ Modify

Previous well #: N/A B. Proposed Casing Dia. 6 C. Proposed Maximum Depth: 300

6. **Construction Start Date:** 12/17/2024 7. **Well Drilling Co.:** VALLEY PUMP & EQUIPMENT Co. **Driller's Lic. No.** 708

Principal Driller's Signature: RYAN FULLERTON(online) **Date:** 12/17/2024

The Driller hereby accepts the terms and conditions of the Start Card Permit and agrees to provide the well owner a copy of the start card.

Property Owner's Signature: **Date:**

CONDITIONS FOR USE OF START CARD:

1. This permit authorizes the construction or modification of one domestic well for a single-family residence. No additional residences, businesses, or dwellings may be connected to this well without a valid water right. Limited to irrigation of 1/2 acre lawn/garden and 13,000 gpd.
2. Start cards must be submitted to the Department at least two office hours prior to commencing construction of the well. The start construction date shall be no more than 10 days after the Department receives the permit.
3. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare. All wells must be drilled a minimum distance of 100' from a drain field. Domestic wells must be drilled a minimum of 50' from a septic tank.
4. Only Well Drillers licensed in Idaho may use a Start Card for construction of a well. The driller shall maintain a copy of the Start Card and the well I.D. tag at the drilling site during construction.
5. This drilling permit does not authorize trespass on the land of another party.
6. This drilling permit does not constitute other local, county, state, or federal approvals which may be required for construction of a well.
7. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
8. If a bottom hole temperature of 85°F or greater is encountered, well construction shall cease and the well driller shall contact the Department immediately.
9. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or his contractors to contact "Digline" (Digline is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "Digline" Number for your area is 1-800-342-1585.
10. The stainless steel I. D. tag must be welded to the well casing by the driller upon completion of the well, and prior to removing the drill rig from the drill site and must remain permanently attached above ground level for the life of the well. The well tag shall be attached by welding at least 3 sides or using four (4) stainless steel, closed-end pop rivets.
11. A start card is not valid for drilling in Areas of Drilling Concern, Critical Groundwater Areas, Groundwater Management Areas, or other Areas as Identified by the Department.
12. The possession of a well tag does not authorize construction of a well.
13. Any well being replaced by a new well shall be properly abandoned by the well driller prior to removing the drilling equipment unless otherwise authorized by the department.