6/07

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D 0082377
Drilling Permit No. 893017
Water right or injection well #

2. OWNER: Brian Scott
Name Brian Scott
Address Lot 13 East River Road
City Coolin State ID Zip 83856

3. WELL LOCATION:
Twp. 59 North ☒ or South ☐ Rge. 04 East ☐ or West ☒
Sec. 15 ____ 1/4 SE 1/4 NW 1/4
Gov't Lot ____ County Bonner
Lat. 48 ° 28.039 N. (Deg. and Decimal minutes)
Long. 116 °50.65W (Deg. and Decimal minutes)
Address of Well Site Lot 13 East River Road
(Give at least name of road + Distance to Road or Landmark) City Coolin
Lot. 13 Blk. ____ Sub. Name

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other

5. TYPE OF WORK:
☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other

6. DRILL METHOD:
☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
Bentonite	0	20'	14 bags	Dry Poured
Grout	20'	40'	slurry	Pumped in

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/ Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	255	.250	Steel	☒	☐	☐	☒
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 255'

9. PERFORATIONS/SCREENS:
Perforations ☐ Y ☒ N Method
Manufactured screen ☒ Y ☐ N Type Johnson
Method of installation Pullback

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
255'	260'	14	5'	5"	S.S.	

Length of Headpipe 5' Length of Tailpipe 1'
Packer ☒ Y ☐ N Type K-Packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method

11. FLOWING ARTESIAN:
Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG)
Describe control device

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 8' Static water level (ft) 52'
Water temp. (°F) Cold Bottom hole temp. (°F) Cold
Describe access port Bolt on Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method: Pump	Bailer	Air	Flowing artesian
100%	4-5 G.P.M.	1 hr	☐	☐	☒	☐
			☐	☐	☐	☐

Water quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y	Water N
10"	0'	2'	Top Soil		X
	2'	12'	Sand and Gravel	X	
	12'	210'	Silty Sand with Clay Seams Tan Wet	X	
	210'	249'	Clay Hard Gray		X
	249'	260'	Sand Fine with some Gravels w/wate	X	
	260'	263'	Clay Gray Hard		X

RECEIVED
APR 07 2020
IDWR/NORTH

RECEIVED
APR 07 2020
IDWR/NORTH

Completed Depth (Measurable): 260'
Date Started 02/26/2020 Date Completed 03/14/2020

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Carl Pitts & Sons Well Drilling Co. No. 168
*Principal Driller Lauie Hinner Date 03/14/2020
*Driller Lauie Hinner Date 3/14/2020
*Operator II ____ Date ____
Operator I Mike Taylor Date 03/14/2020

* Signature of Principal Driller and rig operator are required.