Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED
SEP 17 1999
IDWR/North

77205

Office Use Only
Inspected by _____
Twp ____ Rge ____ Sec ____
____ 1/4 ____ 1/4 ____ 1/4
Lat: : : Long: : :

1. WELL TAG NO. D 0010151
DRILLING PERMIT NO. ____-____-____
Other IDWR No. 97-99-N-28

2. OWNER:
Name James Ward
Address Leclerc Rd
City Old Town State ID Zip 83822

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

POSTED

N / W / E / S — X

Twp. 56 North ☑ or South ☐
Rge. 6 East ☐ or West ☑
Sec. 24, ____ 1/4 SW 1/4 SE 1/4
Gov't Lot ____ County Bonner
Lat: : : Long: : :
Address of Well Site Hwy 2 1/2 mile E of Selkirk Hardware City Old Town
(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☐ Air Rotary ☑ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	18	6	Temp casing

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s) 95
Was drive shoe seal tested? ☐ Y ☐ (N) How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	95	250	Steel	☑	☐	☑	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
Perforations
(Screens)
Method _____
Screen Type Johnson

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
95	100	20		6	SS.	☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
60 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:
☐ Pump ☑ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
8	5 Feet		1 Hr

Water Temp. Cold Bottom hole temp. _____
Water Quality test or comments: _____
Depth first Water Encounter 70

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	18	fine Sand		✓
6	18	40	fine Sand & clay		✓
6	40	70	fine Sand		✓
6	70	100	Med Sand	✓	

Completed Depth 100 (Measurable)
Date: Started 8-5-99 Completed 8-9-99

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Carl Pitts & Sons Firm No. 168
Firm Official Carl Pitts Date 8-25-99
and
Driller or Operator Joe Ockert Date 8-25-99
(Sign once if Firm Official & Operator)

56N 6W 24 FORWARD WHITE COPY TO WATER RESOURCES