

Form 238-7
6/07IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTGPS amended to
match correct
well site
parcel

1. WELL TAG NO. D 0084860

Drilling Permit No. 845168

Water right or injection well # _____

2. OWNER:

Name Darin BradburyAddress 127 W. Beardmore Ave.City Priest River State ID Zip 83856

3. WELL LOCATION:

Twp. 56 North ☒ or South ☐ Rge. 05 East ☐ or West ☒Sec. 20 1/4 SE 1/4 SE 1/4Gov't Lot _____ County BonnerLat. 48 10.9541N (Deg. and Decimal minutes)Long. 116 59.1073W (Deg. and Decimal minutes)Address of Well Site 2771 Hwy 2.City Priest River

Lot _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite Chips	0	38	1,000 lbs.	Temporary Casing

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Linear	Threaded	Welded
6"	+2	230	.250	Steel	☒	☐	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) @ 230'

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method Air PerforatorManufactured screen ☐ Y ☒ N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
203	230	1/4x1	12	6"	Steel	.250

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
NA				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 8' Static water level (ft) 179'Water temp. (°F) Cold Bottom hole temp. (°F) ColdDescribe access port Welded Steel Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
NA	45 gpm	240	☐	☐	☒	☐

Test method:

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
12"	0	1	Topsoil		X
12"	1	38	Gravel and Clay	X	
8"	38	57	Gravel and Clay		X
8"	57	83	Grey Clay and Sand		X
8"	83	106	Dark Grey Clay		X
8"	106	122	Large Sand and Brown Clay		X
8"	122	194	Grey Clay and Fine Sand		X
8"	194	224	Coarse Sand and Gravel	X	
8"	224	230	Green Granite	X	
6"	230	244	Green Granite		X
6"	244	251	Peach Granite		X
6"	251	255	Fractured Granite	X	
6"	255	267	Green Granite		X
6"	267	269	Peach and Green Granite		X
6"	269	283	Fractured Granite	X	
6"	283	300	Green Granite		X

RECEIVED

JUL 31 2020

IDWR/NORTH

Completed Depth (Measurable): 300'Date Started: 7/27/2020Date Completed: 7/30/2020

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Horsley Drilling, Inc. Co. No. 632*Principal Driller C. Mark Horsley Date 7/30/2020*Driller Justin Durazo Date 7/30/2020

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Field	Value
ACRES	1.4
ADDRESS1	2605 E HIGHWAY 2
ADDRESS2	
CITY	OLDTOWN
COUNTY	Bonner
ID	15684644
LEGAL1	29-56N-5W TAX 15 LESS E 714FT
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	HOOD, KENT & CATHERINE
P_ADDRESS	2605 HIGHWAY 2 HWY
P_ZIPCODE	83822
ParcelCount	1
PIN	RP56N05W290610A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	
UPDATED	6/17/2023
YEAR_BUILT	1938
ZIPCODE	83822-9250