

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 00 29286

Drilling Permit No. 890985

Water right or Injection well # CHRIS PFAL

2. OWNER: CHRIS PFAL

Name PO BOX 43804370

Address GOLDENDA RD

City Wallace State ID Zip 83873

3. WELL LOCATION:

Twp. 5N North ☒ or South ☐ Rge. 4 East ☐ or West ☒

Sec. 17 1/4 11W 1/4 3E 1/4

Gov't Lot 48 County BONNER

Lat. 48 22 0080 (Deg. and Decimal minutes)

Long. -116 53 0520 (Deg. and Decimal minutes)

Address of Well Site 1334 FARMER RD

City PRIEST RIVER

(Give at least name of road & distance to road or landmark)

Lot Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection

☐ Other

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well

☐ Abandonment ☐ Other

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
Bentonite	0	38	24.50	Overbore
Hole Plug			Bags	

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner	Threaded	Welded
6" +2	155	1250	5	Steel	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s)

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method

Manufactured screen ☒ Y ☐ N Type Stainless Steel Johnsons

Method of installation Telescoping

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
155	160	14	5	5"	S.S.	

Length of Headpipe 4 Length of Tailpipe 0

Packer ☒ Y ☐ N Type R Packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method
0				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG)

Describe control device

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 45 Static water level (ft) 10

Water temp. (°F) Cold Bottom hole temp. (°F) Same

Describe access port Bolt on Cape

Well test: Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Ball	Air	Flowing artesian
150	30+	1 hr	☐	☐	☒	☐

Water quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	16	Sandy Top Soil		X
	16	21	SAND & GRAVEL		X
	21	38	Clayish Fine Sand		X
6	38	130	SAND Fine w/ 2-3 GPM		X
	130	160	SAND w/ Small Gravel		X

RECEIVED

NOV 04 2019

IDWR / NORTH

Completed Depth (Measurable): 1100

Date Started: 8-23-19 Date Completed: 8-27-19

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Carl Pitts & Sons Co. No.

*Principal Driller Procie Hanner Date 8-26-19

*Driller J. E. H. Date 8-26-19

*Operator II Date

Operator I Date 8/26/19

* Signature of Principal Driller and rig operator are required.