

97-7852 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value
ACRES	4.6
ADDRESS1	1 HOLLY GLENN WEST
ADDRESS2	
CITY	PRIEST RIVER
COUNTY	Bonner
ID	15673344
LEGAL1	22-56N-5W HOLLEY GLEN SUB LOT 31 2000 FLEETWOOD 27 X 60 RP CPWRS
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	ENGLISH, JOSEPH L & ANNIE
P_ADDRESS	1 HOLLY GLENN
P_ZIPCODE	83856
ParcelCount	1
PIN	RP006050000310A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	HOLLEY GLEN SUB
UPDATED	6/17/2023
YEAR_BUILT	<null>
ZIPCODE	83856-8714

RECEIVED

Form 238-7

3/95 JAN 07 1998

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

097468

NORTHERN REGION

1. DRILLING PERMIT NO. D-000-3073Other IDWR No. 97-47-N-30

2. OWNER:

Name Joe English
Address 605 N-3rd Street
City Avenal State Calif Zip 93204

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		Twp. <u>56</u> North ☒ or South ☐	
E		Rge. <u>5</u> East ☐ or West ☒	
S		Sec. <u>22</u> 1/4 <u>SW</u> 1/4 <u>SE</u> 1/4	
W		Gov't Lot _____ County <u>Bonnie</u> 10 acres 40 acres 160 acres	
		Lat: _____ Long: _____	
Address of Well Site <u>Holley Glen Rd.</u>			
City <u>Thirst River</u>			

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Bk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Feet	Pounds	
Bentonite	0	18	6	18	Temp Casing

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) _____Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	65	250	Steel	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
2 1/2	110	110	2 hrs

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8	0	18	Sand, Gravel, Boulders		X
6	18	25	Sand, Gravel		X
	25	40	Sand, Gravel		X
	40	60	Decomposed Granite		X
	60	80	Granite, Salt, pepper		X
	80	100	Granite, Salt, pepper, Very little		X
	100	120	Granite, s/p		X
	120	150	Granite s/p		X
	150	160	Granite s/p 2 1/2 GPM	X	
	160	170	Granite s/p		X

Ran 4 hr pump
test 2 week later
Ran 5 GPM for
4 hrs 10'
drawdown.

Completed Depth 170' (Measurable)
Date: Started 10-28-97 Completed 11-24-97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Carl Potts & Son Drilling Inc. 168Firm Official Carl Potts Date 11-24-97and
Supervisor or Operator Joe Akut Date 11-24-97

(Sign once if Firm Official & Operator)

SWSE 22 56N 5W

WARD WHITE COPY OF WATER RESOURCES