

97-8166 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value
ACRES	4.8
ADDRESS1	PO BOX 554
ADDRESS2	
CITY	PRIEST RIVER
COUNTY	Bonner
ID	15701113
LEGAL1	18-56N-4W STEWART ACRES BLK 1 LOT 1
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	JOHNSON, GARY E
P_ADDRESS	65 BELKNAP LN
P_ZIPCODE	83856
ParcelCount	1
PIN	RP027650010010A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	STEWART ACRES
UPDATED	6/17/2023
YEAR_BUILT	2016
ZIPCODE	83856

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D0069243

Drilling Permit No. 875120

Water right or injection well # _____

2. OWNER: Mac Haserot

Name _____

Address 4751 Beckwith Rd.

City Kingsville State OH Zip 44048-9733

3. WELL LOCATION:

Twp. 56 North ☒ or South ☐ Rge. 04 East ☐ or West ☒

Sec. 18 1/4 SW 1/4 NE 1/4

Gov't Lot _____ County Bonner

Lat. 48 ° 12.250 (Deg. and Decimal minutes)

Long. 116 ° 52.807 (Deg. and Decimal minutes)

Address of Well Site 65 Belknap Ln.

City Priest River

Lot. 12 Blk. _____ Sub. Name Stewart Acres

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	1,250 lbs	Dry Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	91	.250	Steel	☒	☐	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 94'

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____

Manufactured screen ☒ Y ☐ N Type Stainless Steel

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
92	97	.10	5'	5"	SS	

Length of Headpipe 1' Length of Tailpipe 0

Packer ☒ Y ☐ N Type K-Packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
-----------------	-----------	---------	------------------------------------	------------------

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 60 Static water level (ft) 50

Water temp. (°F) Cold Bottom hole temp. (°F) Cold

Describe access port Welded Steel Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
97	15	1 hr.	☐	☐	☒	☐

Water quality test or comments: Clear

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	38	Sand, Clay & Gravel		X
8	38	60	Sand, Clay & Gravel		X
8	60	89	Fine Sand	X	
8	89	92	Fine Sand & Gravel	X	
8	92	97	Fine Sand	X	

RECEIVED

MAY 26 2015

IDWR / NORTH

Completed Depth (Measurable): 97'
Date Started: May 1, 2015 Date Completed: May 4, 2015

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name H2O Well Service Inc. Co. No. 448

*Principal Driller [Signature] Date May 5, 2015

*Driller [Signature] Date 5-6-15

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.