

97-9144 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value	
ACRES	20	
ADDRESS1	PO BOX 293	
ADDRESS2		
BackfillFr		
CITY	PRIEST RIVER	
COUNTY	Bonner	
FID	623	
LEGAL1	5-56N-4W 1994 FLEETWOOD 14 X 66 VIN IDFLP04A16321BM TITLE A93512871	
LEGAL2		
LEGAL3		
LEGAL4		
LEGAL5		
LEGAL6		
OWNER	STEUBE, DAVID DEWITT	
OwnerFromA		
OwnerFromI		
P_ADDRESS	ID	
P_ZIPCODE	83856	
PIN	MH56N04W056003A	
Previous_T	STEUBE, DAVID DEWITT	
Shape	Polygon	
Shape_Area	82391.939237	
Shape_Leng	1604.409518	
SOURCE		
StandardAd		
STATE	ID	
SUB_NAME	UNPLATTED	
TempUnique	624	
UPDATED	8/14/2018	
YEAR_BUILT	2005	
ZIPCODE	83856	

Form 238-7
6/02

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

1. WELL TAG NO. D 0028563
DRILLING PERMIT NO. 804436 JUL 21 2003
Water Right or Injection Well No. IDWR/North

2. OWNER:
Name Dave Steube
Address 4392 East Side Rd
City Priest River State Id. Zip 83856

3. LOCATION OF WELL by legal description:
You must provide address or Lot, Blk, Sub. or Directions to well.
Twp. 56 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 5 1/4 NE 1/4 NE 1/4
Gov't Lot 10 acres County Bonner 160 acres
Lat: : : Long: : :
Address of Well Site Same
City Priest River
(Give at least name of road + Distance to Road or Landmark)
Lt. Blk. Sub. Name

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD:
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>25</u>	<u>200</u>	<u>over Bone</u>

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 65
Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6</u>	<u>H</u>	<u>64</u>	<u>20</u>	<u>Steel</u>	☒	☐	☒	☐
<u>4</u>	<u>-10</u>	<u>285</u>	<u>20</u>	<u>plastic</u>	☐	☒	☒	☐

Length of Headpipe Length of Tailpipe
Packer ☐ Y ☒ N Type

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method skill saw
Screen Type & Method of Installation

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
<u>-210</u>	<u>285</u>	<u>1/4</u>	<u>200</u>	<u>4</u>	<u>plastic</u>	☐	☒

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

20 ft. below ground Artesian pressure lb.
Depth flow encountered 265 ft. Describe access port or control devices:
well seal
56 N 4 W 5

Office Use Only			
Well ID No. _____			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____		1/4 _____	
Lat: : : _____	Long: : : _____		

12. WELL TESTS:

Yield gal./min.	Drawdown	Pumping Level	Time
<u>12</u>	<u>210</u>	<u>285</u>	<u>1</u>

Water Temp. 450 Bottom hole temp. _____
Water Quality test or comments: _____

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8</u>	<u>0</u>	<u>35</u>	<u>Sand Gravel Boulders</u>		☒
<u>8</u>	<u>35</u>	<u>65</u>	<u>Soft Granite</u>		☒
<u>6</u>	<u>65</u>	<u>265</u>	<u>Granite</u>		☒
<u>6</u>	<u>265</u>	<u>280</u>	<u>Falt in Rock</u>	☒	
<u>6</u>	<u>210</u>	<u>280</u>	<u>Granite</u>		☒
<u>6</u>	<u>280</u>	<u>285</u>	<u>Falt in Rock</u>	☒	

Completed Depth 285 (Measurable)
Date: Started 7-7-03 Completed 7-10-03

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Bob Pitts' Sons Firm No. 235
Principal Driller Bob Pitts Date 7-10-03
and
Driller or Operator II _____ Date _____
Operator I Mark Johnson Date 7-10-03

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

FORWARD WHITE COPY TO WATER RESOURCES