

97-9165 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value
ACRES	2.1
ADDRESS1	1034 E SETTLEMENT RD
ADDRESS2	
CITY	PRIEST RIVER
COUNTY	Bonner
ID	15683991
LEGAL1	19-56N-4W SESE S OF ROAD LESS TAX 28
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	COX, PATRICK L
P_ADDRESS	1034 E SETTLEMENT RD
P_ZIPCODE	83856
ParcelCount	1
PIN	RP56N04W199341A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	
UPDATED	6/17/2023
YEAR_BUILT	1979
ZIPCODE	83856-9771

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

1. WELL TAG NO. D 0056212
Drilling Permit No. 856293
Water right or injection well # _____

2. OWNER: Johana Blumenkamp
Name _____
Address 1647 Peninsula Loop Rd
City Priest River State Id. Zip 83856

3. WELL LOCATION:
Twp. 56 North ☒ or South ☐ Rge. 04 East ☐ or West
Sec. 19 $\frac{1}{4}$ SE $\frac{1}{4}$ SE $\frac{1}{4}$
TO ACRES 40 ACRES 160 ACRES

Gov't Lot _____ County Bonner
Lat. N 48 ° 10.843 (Deg. and Decimal minutes)
Long. W 116 ° 52.426 (Deg. and Decimal minutes)
Address of Well Site 1034 E Settlement Rd City Priest Rd.
(Give at least name of road • Distance to Road or Landmark)
Lot. _____ Blk. _____ Sub. Name _____

4. USE: ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well

☐ Abandonment ☐ Other _____

6. DRILL METHOD:
☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
Bentonite	0	30	200	Temp casing

8. CASING/LINER:					Casing	Liner	Threaded	Welded
Diameter (nominal)	From (ft)	To (ft)	Gauge/ Schedule	Material				
6	1	200	250	Steel	☒	☐	☒	
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 100

9. PERFORATIONS/SCREENS:
 Perforations ☐ Y ☒ N Method _____
 Manufactured screen ☐ Y ☒ N Type _____
 Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____
Packer ☐ Y ☒ N Type _____

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:
Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____
Describe control device well seal

SlcN 04W 19

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) ~~250~~ 450 Static water level (ft) 200
Water temp. (°F) 48° Bottom hole temp. (°F) _____
Describe access port Top of well

Well test:			Test method:			
Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
300	1.5	120	☐	☐	☒	☐

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

[illegible]

Completed Depth (Measurable): 495
Date Started: 5-25-09 Date Completed: 5-30-09

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Bob Pitts: Sons Co. No. 235
 *Principal Driller Dale Pitts Date 6-4-09
 *Driller Dale Pitts Date _____
 *Operator II _____ Date _____
 Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.