

97-8436 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value
ACRES	0.3
ADDRESS1	3500 BUCKBOARD WAY
ADDRESS2	
CITY	LAKE HAVASU CITY
COUNTY	Bonner
ID	15706719
LEGAL1	10-59N-4W 1ST ADD TO COOLIN BLK 11 LOTS 9 & 10 1998 FLEETWOOD 26 X 51 MH
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	HAMILTON TRUST; HAMILTON, JACK W & SHARON I TRUSTEES
P_ADDRESS	509 SCRANTON AVE
P_ZIPCODE	83821
ParcelCount	1
PIN	RP00072011009AA
SHAPE	Polygon
SOURCE	<null>
STATE	AZ
SUB_NAME	COOLIN 1ST ADD RPLT BLK 4 LOTS 1 2 3 5
UPDATED	6/17/2023
YEAR_BUILT	<null>
ZIPCODE	86404-3449

IDAH0 DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only					
Well ID No. _____					
Inspected by _____					
Twp _____		Rge _____		Sec _____	
_____ 1/4		_____ 1/4		_____ 1/4	
Lat: : :		Long: : :			

1. WELL TAG NO. D D0040668
 DRILLING PERMIT NO. 836503
 Water Right or Injection Well No. _____

2. OWNER: 
Name Jack Hamilton
Address 332 Satchell Terrace Drive
City Newport State WA Zip 99156

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 59 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 10 1/4 NW 1/4 NW 1/4
Gov't Lot _____
County Pocon
Lat: : : Long: : :
Address of Well Site Scranton Rd.
City Scranton
(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic	☐ Municipal	☐ Monitor	☐ Irrigation
☐ Thermal	☐ Injection	☐ Other	

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD: ☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
Bentonite	0	18	8	Temp Casing

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 115
Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	11.5	250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe no Length of Tailpipe no
Packer ☒ Y ☐ N Type K Packer

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method _____
Screen Type & Method of Installation Johnson Pull Back

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
115	120	15		6	SS	☐	☐
						☐	☐
						☐	☐

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method
no				

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
100 ft. below ground Artesian pressure _____ lb.
 Depth flow encountered 100 ft. Describe access port or control devices:

59N 4W 10

12. WELL TESTS:

☐ Pump	☒ Bailer	☐ Air	☐ Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
10	5	105	2

Water Temp. _____ Bottom hole temp. _____
Water Quality test or comments: Cold

13. LITHOLOGIC LOG: (Describe repairs or abandonment) _____ Depth first Water Encounter 100 _____ Water

[illegible]

Completed Depth 120' (Measurable)
Date: Started 10-3-05 Completed 10-7-05

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name CAL Pitts + Sons Firm No. 168

Principal Driller Steve Pitts Date 10-5-05

and
Driller or Operator II Joe Ockert Date _____

Operator I _____ Date _____

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

FORWARD WHITE COPY TO WATER RESOURCES