

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D 0055532

Drilling Permit No. 853763

Water right or injection well # _____

2. OWNER:

Name Linda M CrossAddress N 16616 Lower Green Bluff RdCity Colbert State WA Zip 99005

3. WELL LOCATION:

Twp. 57 North ☒ or South ☐ Rge. 4 East ☐ or West ☒Sec. 31 1/4 NE 1/4 NE 1/4Gov't Lot _____ County Bonner

Lat. _____ (Deg. and Decimal minutes)

Long. _____ (Deg. and Decimal minutes)

Address of Well Site 1004 Peninsula RdCity Priest River

(Give at least name of road + Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
bentonite	0	18	400lbs	overbore

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+1 1/2	308 1/2	250	steel	☒	☐	☐	☒
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 308 1/2 ft

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____Manufactured screen ☐ Y ☒ N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 278 Static water level (ft) 265Water temp. (°F) cold Bottom hole temp. (°F) _____Describe access port cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
	9-10	240

Test method:

Pump ☐ Bailer ☐ Air ☒ Flowing artesian ☐Water quality test or comments: clear

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
8	0	18	tan clay some gravel		
6	18	28	blue clay some gravel		
	28	73	tan clay some gravel		
	73	75	boulder		
	75	78	sand&gravel		
	78	90	fine sand		
	90	113	tan-grey clay some gravel		
	113	122	silty tan grey clay		
	122	124	sand		
	124	154	tan-grey clay some gravel		
	154	199	tan-grey clay		
	199	202	tan clay some gravel		
	202	255	tan-grey clay		
	255	257	tan clay&gravel		
	257	274	tan-grey clay		
	274	278	tan clay&gravel		
	278	325	sand&gravel some silty clay	X	

RECEIVED

NOV 18 2008

IDWR/North

Completed Depth (Measurable): 310 ftDate Started: 10-7-08Date Completed: 10-15-08

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Bronson Water Wells Co. No. 360*Principal Driller Clint Bronson Date 10/16/08

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

57N 04W 31