

97-8123 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value
ACRES	0.5
ADDRESS1	2104 WINCHESTER WAY
ADDRESS2	
CITY	SANDPOINT
COUNTY	Bonner
ID	15706684
LEGAL1	10-59N-4W 1ST ADD TO COOLIN BLK 2 LOTS 4,5, & VACATED BAYVIEW BLVD BLK 6 TAX 1 LESS TAX 3 PT VACATED BAYV
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	BAUER FAMILY LLC; BAUER, CHARLES L & MARY M
P_ADDRESS	438 BAYVIEW DR
P_ZIPCODE	83821
ParcelCount	1
PIN	RP00072002004CA
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	COOLIN 1ST ADD RPLT BLK 4 LOTS 1 2 3 5
UPDATED	6/17/2023
YEAR_BUILT	1968
ZIPCODE	83864

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D0058195

Drilling Permit No. 59461

Water right or injection well # _____

2. OWNER: CHUCK BAUER

Name CHUCK

Address 2104 Winchester Way

City Sandpoint State ID Zip 83864

3. WELL LOCATION:

Twp. 59 North ☒ or South ☐ Rge. 04 East ☐ or West ☒

Sec. 10 1/4 NW 1/4 SW 1/4

Gov't Lot _____ County Bonner

Lat. 48 28 878 (Deg. and Decimal minutes)

Long. 116 50 878 (Deg. and Decimal minutes)

Address of Well Site 438 Bayshore Blvd

City Civilian

(Give at least name of road + Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection

☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well

☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☐ Air Rotary ☐ Mud Rotary ☒ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	15	450 lbs	Temp Casing

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6 1/4	45	250	250	Steel	☒	☐	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 45'

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____

Manufactured screen ☒ Y ☐ N Type Johnson 301

Method of installation Push Back

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
45	50	20	5'	6	SS Steel	250

Length of Headpipe _____ Length of Tailpipe _____

Packer ☒ Y ☐ N Type K Packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

59N 04W 10

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 3' Static water level (ft) 1'

Water temp. (°F) Cold Bottom hole temp. (°F) Cold

Describe access port _____

Well test: _____ Test method: _____

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
12'	8.6 gpm	1 Hr	☐	☒	☐	☐

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water
10	0	1	TOP SOIL	☒
10	1	3	SAND & GRAVEL	☒
10	3	22	SAND & SMALL GRAVEL	☒
6	22	43	Fine SAND Light Brown	☒
6	43	46	SAND 20% TAN	☒
6	46	50	SAND 25% TAN	☒
6	50	51	Clay	☒

RECEIVED

AUG 11 2010

IDWR/NORTH

RECEIVED

SEP 20 2010

IDWR / NORTH

Completed Depth (Measurable): 50'

Date Started: 7/13/10 Date Completed: 7/15/10

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Curtis & Sons Co. No. 148

*Principal Driller Steve Patten Date 7/19/10

*Driller _____ Date _____

*Operator II John Patten Date 7/19/10

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.