Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D D0088455
Drilling Permit No. 960772
Water right or injection well #

2. OWNER: Jeff Gallagher
Name
Address 4207 W. Reese Court
City Spokane State WA Zip 99208

3.WELL LOCATION:
Twp. 59N North ☒ or South ☐ Rge. 04W East ☐ or West ☒
Sec. 10 ____ 1/4 NW 1/4 NW 1/4
(10 acres / 40 acres / 160 acres)
Gov't Lot ____ County Bonner
Lat. 48 ° 29 . 072 (Deg. and Decimal minutes)
Long. 116 ° 50 . 714 (Deg. and Decimal minutes)
Address of Well Site Paul Jones Rd
(Give at least name of road + Distance to Road or Landmark) City Collin
Lot. ____ Blk. ____ Sub. Name

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other

5. TYPE OF WORK:
☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other

6. DRILL METHOD:
☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
Benonite	0	38	850 lbs	Temp. Casing

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/ Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	53	.250	Steel	☒	☐	☐	☒
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 53'

9. PERFORATIONS/SCREENS:
Perforations ☐ Y ☒ N Method
Manufactured screen ☒ Y ☐ N Type Alloy
Method of installation Telescoping

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
53	58	16	5'	5"	S.S.	

Length of Headpipe 5' Length of Tailpipe
Packer ☒ Y ☐ N Type K-Packer

10.FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method

11. FLOWING ARTESIAN:
Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG)
Describe control device

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 49' Static water level (ft) +1
Water temp. (°F) Cold Bottom hole temp. (°F) Cold
Describe access port Welded Steel Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
	25	60

Test method:

Pump	Bailer	Air	Flowing artesian
☐	☐	☒	☐
☐	☐	☐	☐

Water quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y	Water N
10	0	1	Topsoil		X
10	1	5	Sand		X
10	5	38	Clay & Sand		X
8	38	49	Clay & Sand		X
8	49	58	Sand	X	

RECEIVED
JUL 21 2021
IDWR/NORTH

Completed Depth (Measurable): 58'
Date Started: July 13, 2021 Date Completed: July 13, 2021

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name H2O Well Service Inc. Co. No. 448
*Principal Driller [signature] Date 7-14-21
*Driller [signature] Date 7-14-21
*Operator II Date
Operator I [signature] Date 7-14-21

* Signature of Principal Driller and rig operator are required.