

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D DOO 76537

Drilling Permit No. 884954

Water right or Injection well # _____

2. OWNER: Dana Haag

Name Dana Haag

Address 1522 W 1500 N NO 451-6366

City Farmington State UT Zip 84025

3. WELL LOCATION:

Twp. 52 North ☒ or South ☐ Rge. 05 East ☐ or West ☒

Sec. 23 1/4 SW 1/4 NE 1/4

Gov't Lot _____ County Bonner

Lat. 48° 16.638 (Deg. and Decimal minutes)

Long. -116° 55.308 (Deg. and Decimal minutes)

Address of Well Site 450 Bear Road

(Name of road or name of road - Distance to Road or Landmark) City Preist River

Lot _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection

☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well

☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
Bentonite	0	38	17 bags	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner Threaded Welded
6	-2	335	625	Steel	☒ ☐ ☐ ☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 335

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☐ N Method _____

Manufactured screen ☒ Y ☐ N Type Johnson

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
335	340	.20		5 in	Stainless	

Length of Headpipe _____ Length of Tailpipe _____

Packer ☒ Y ☐ N Type K

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 100 Static water level (ft) 200

Water temp. (°F) 45 Bottom hole temp. (°F) 45

Describe access port well cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:
260	17 gpm	1 Hour	Pump ☐ Bailor ☐ Air ☒ Flowing artesian ☐

Water quality test or comments: good

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y H
10	0	38	Seal	
6	0	100	Dry clay	
6	100	270	wet clay	
6	270	310	Clay sand silt	
6	310	325	thick sand gravel	
6	325	340	coarse sand and gravel	

RECEIVED

JAN 31 2018

IDWR / NORTH

Completed Depth (Measurable): 340

Date Started: Jan 22-17 Date Completed: Jan 24-17