

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Administration within 30 days after the completion or abandonment of the well.

RECEIVED
DEC 12 1973
Department of Water Administration

1. WELL OWNER

Name Richard Slinger
Address Rte. 4, Box 42, Newport, Wash.
Owner's Permit No. 97-73-N-4 99156

7. WATER LEVEL

Static water level 160 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other

Discharge G.P.M. Draw Down Hours Pumped

Est. 10 GPM

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 300 feetCasing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>0.25</u> inches	<u>6</u> inches	<u>1</u> feet	<u>137</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☒ Yes ☐ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet


Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 20' Material used in seal ☐ Cement grout☒ Puddling clay ☐ Well cuttingsSealing procedure used ☒ Sherry pit ☐ Temporary surface casing☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County BonnerNE 1/4 SW 1/4 Sec. 18, T. 56 N. R. 5 W.

10.

Work started 5 Dec. 73 finished 8 Dec. 1973

11. DRILLERS CERTIFICATION

Firm Name L.E. Neilson, Inc. Firm No. 264E-6010 BldgAddress Spokane, Wash. 99211 Date 12 Dec 73Signed by (Firm Official) Stanley D. Neilson

and

(Operator) Sheldene R. Newhouse