Form 238-7
1/94

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

95680

1. DRILLING PERMIT NO. 97-94-N-0089-000
Other IDWR No.

2. OWNER:
Name Forest Larson
Address P.O. Box 1453
City Priest River State Id Zip 83856

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 56 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 1, SE 1/4 (10 acres) NW 1/4 (40 acres) ____ 1/4 (160 acres)
Gov't Lot ____ County Bonner

Address of Well Site Shadow Drive City Priest River
(Give at least name of road + Distance to Road or Landmark)

Lt. 1 Blk ____ Sub. Name Whispering Shadows Subdivision

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	19	5 sacks	Overbore

Was drive shoe used? Y ☒ N ☐
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+1	19	.250	Steel	☒	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
30 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 225 ft. Describe access port or control devices:
SENW 1 56N 5W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
2½		302	1 hr

Water Temp. 50° Bottom hole temp.
Water Quality test or comments: Clear

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	6	Sand + gravel		☒
	6	17	Decomposed Granite		☒
	17	19	Granite - S+P - med		☒
6	19	225	Granite - S+P - med		☒
	225	226	Granite S+P - frac @ 2½	☒	
	226	302	Granite - S+P - med		☒

RECEIVED
JAN 05 1995
NORTHERN REGION
IDWR

OFFICE USE ONLY
Inspected by TDK
Twp 56N Rge 5W Sec 01
NW 1/4 NE 1/4 NW 1/4
MICROFILMED
DEC 29 1998
AUG 25 1999

Completed Depth 302 (Measurable)
Date: Started 11-25-94 Completed 11-28-94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Intermountain Drilling Firm No. 513
Firm Official [signature] Date 11-29-94
and
Supervisor or Operator same Date
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES