

RECEIVED

AUG 30 2001

Form 238-7
11/97

IDWR/North

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
_____ 1/4	_____ 1/4	_____ 1/4	
Lat: _____	_____	Long: _____	_____

1. WELL TAG NO. D 0017456

DRILLING PERMIT NO. _____

Other IDWR No. 770008

2. OWNER:

Name Pat Kent

Address 5218 W Edgewood CT

City Spokane

State WA Zip 99208

POSTED

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		Twp. 59		North ☒ or South ☐	
W		Rge. 4		Eas ☐ or West ☒	
E		Sec. 22		1/4 NW 1/4 1/4 SW 1/4	
S		Gov't Lot _____		County Bonner	
		Lat: _____		Long: _____	
Address of Well Site East Side Rd - 1/4 mile N of cutoff Rd					
City Coeur d'Alene					

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
Benitrite	0	18	6	Temp casing

Was drive shoe used? ☒ Y ☐ N Shoe Depths 170Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	1	170	250	Steel	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations

Method

Screens

Screen Type Tetra-spooling

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
170	175	25		6	SS	☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

158 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 160 ft. Describe access port or control devices: _____

11. WELL TESTS:

- ☐ Pump ☒ Bailor ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
8+	2		1

Water Temp. COLD

Bottom hole temp. COLD

Water Quality test or comments: _____

Depth first Water Encounter 160

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8	0	18	Sand & gravel		☒
6	18	40	Sand & clay		☒
6	40	92	Fine sand & clay		☒
6	92	120	clay		☒
6	120	160	Fine sand & clay		☒
6	160	175	Sand "med"		☒

Completed Depth 175 (Measurable)

Date: Started 7-20-01 Completed 7-29-01

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Carl Pitts & Sons Drilling Firm No. 168

Firm Official Steve Pitts Date 8-2-01

and

Driller or Operator Joe Coker Date 8-2-01

(Sign once if Firm Official & Operator)

59N 4W 22

FORWARD WHITE COPY TO WATER RESOURCES