RECEIVED
MAY 04 1995
IDWR

Form 238-7
7/94

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 97-95-N-0022-000
Other IDWR No.

2. OWNER:
Name Kameron and Sherrie Lawson
Address P.O.Box 1194
City Priest River State ID Zip 83856

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 56 North ☒ or South ☐
Rge. 05 East ☐ or West ☒
Sec. 22, SW 1/4 (10 acres) NE 1/4 (40 acres) 1/4 (160 acres)
Gov't Lot ____ County Bonner

Address of Well Site Holley Glen
City Priest River
(Give at least name of road + Distance to Road or Landmark)

Lt. 30 Blk. ____ Sub. Name Holley Glen

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	19	5sacks	Overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s)
Was drive shoe seal tested? Y☐ N☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+1	71	250	steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
65 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 65 ft. Describe access port or control devices:
SWNE 22 56N 5W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
1 gpm		300'	1 hr.

Water Temp. 50 F Bottom hole temp.
Water Quality test or comments: clear

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	13	Sand,gravel,boulders		X
8	13	19	Clay-gray		X
6	19	41	Clay-gray		X
	41	70	Decomposed granite	X	
	70	300	Granite-s&p-med	X	

MICROFILMED
MAR 09 1999

Completed Depth 300' (Measurable)
Date: Started 4/28/95 Completed 5/1/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Intermountain Drilling Firm No. 513
Firm Official ____ Date 5/3/95
and
Supervisor or Operator same Date
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES