Form 238-7
1/94

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED
JUN 13 1994
NORTHERN REGION
IDWR

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 97-94-N.0008-000
Other IDWR No.

2. OWNER:
Name THOMAS Petck
Address HCR 60 Box 42A
City PRIEST RIVER State Id Zip 83856

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 58 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 22, SW 1/4 (10 acres) SE 1/4 (40 acres) ____ 1/4 (160 acres)
Gov't Lot ____ County

Address of Well Site: EAST River Rd
(Give at least name of road + Distance to Road or Landmark) City Priest River

Lt. ____ Blk. ____ Sub. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☐ Air Rotary ☒ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	18	10	Dry Temp Casing

Was drive shoe used? Y ☒ N ☐
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	0	18	250		☐	☐	☒	☐
6	18	123			☒	☐	☒	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method Johnson
☒ Screens Screen Type Telescoping

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
123	128	20		6"	Stainless	☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
60 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:
SW SE 22 58N 4W

11. WELL TESTS:
☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10	10	70'	1 hr

Water Temp. ____ Bottom hole temp. ____
Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	18	Clay		X
6	18	25	Clay		X
	25	40	Clay		X
	40	60	Clay		X
	60	123	Quicksand + Clay	X	
	123	128	Sand	X	

OFFICE USE ONLY
Inspected by TDK
Twp 58N Rge 4W Sec 22
NW 1/4 SW 1/4 SE 1/4

MICROFILMED
DEC 29 1998

Completed Depth 128' (Measurable)
Date: Started 2-25-94 Completed 3-10-94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Carl Potts & Sons Firm No. 168
Firm Official Carl Potts Date 3-10-94
and
Supervisor or Operator Steve Potts Date 3-10-94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES