

WELL DRILLER'S REPORT

Office Use Only
 Inspected by _____
 Twp _____ Rge _____ Sec _____
 _____ 1/4 _____ 1/4 _____ 1/4
 Lat: : : Long: : :

1. WELL TAG NO. D0040498
Drilling Permit No: 835295
Other IDWR No.

2. OWNER
Name SCHMALTZ, RONALD & VICKI Well Number: 1028

Address 7120 E UTAH
City SPOKANE State WA Zip 99212

3. LOCATION OF WELL by legal description
sketch map location must agree with written location


 Twp. 56 ☒ North or ☐ South
 Rge. 05 ☐ East or ☒ West
 Sec. 24 ☐ 1/4 NE ☐ 1/4 SE ☐ 1/4 SW
 Gov't Lot _____ County BONNER
 Lat. : : Long. : :

Address of Well Site 401 EASTSIDE RD
City PRIEST RIVER

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	300 LBS	TEMP CASING

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 65

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

[illegible]

Length of Headpipe 5' Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations Method

✓ Screens	Method	Screen Type	JOHNSON
-----------	--------	-------------	---------

From	To	Slot Size	Number	Diameter	Material
65	70	20		6	S/S

Casing

☐

Liner

☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

20 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

56N 5W 24

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
8			2.5 HRS

Water Temp. COLD Bottom Hole Temp COLD

Water Quality test or comments: CLEAR

Depth first Water encountered 30

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	f
8	0	2	TOP SOIL	☐	☒
8	2	8	CLAY BROWN	☐	☒
8	8	30	CLAY BLUE W/SAND LAYERS	☐	☒
8	30	60	SAND, MED	☒	☐
8	60	70	SAND, GRAVEL, MED	☒	☐
RECEIVED DATE 11/1/84					

Completed Depth 70 (Measurable)
Date: Started 8/25/2005 Completed 8/29/2005

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official [Signature] Date 9-2-05

and

Supervisor or Operator Robert Keen Date 08/31/05

ROBERT KERN

(Sign Once if Firm Official and Operator)