

RECEIVED

DEC 17 1997

IDAHO DEPARTMENT OF WATER RESOURCES

WELL

DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

097464

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	

NORTHERN REGION

1. DRILLING PERMIT NO. TAG#D0003459

Other IDWR No.

2. OWNER

Name EDWARDS, WAYNE

Well Number:

633


Address 395 N FORDHAM AVE

City FRESNO

State CA Zip 93727

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 56



North or



South

Rge. 05



East or



West

Sec. 13

1/4

NE

1/4

NE

1/4

Gov't Lot

County

BONNER

Lat:

:

Long:

:

:

:

Address of Well Site

City PRIEST RIVER

(Give at least name of road + Distance to Road or Landmark)

Blk.

Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	20	0 GALLO	20' OVERBORE

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s) 0Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner Welded	Threaded
6	+2	239	.250	STEEL	☒	☐	☒

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☐ Perforations Method☒ Screens Screen Type JOHNSON STAINLESS

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
340	345	20	1	5	stainless steel	☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

275 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:



Pump



Bailer



Air



Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10-15 GPM			2 HRS

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
10	0	1	TOPSOIL	☐	☒
10	1	20	Sand Gravel W/Clay	☐	☒
8	20	62	Sand & Gravel 3/4 Minis	☐	☒
8	62	85	Clay Gray Soft	☐	☒
8	85	230	Silty Blue Clay	☐	☒
8	230	330	Silty Sand Wet Blue	☒	☐
8	330	350	Sand Coarse W/Water	☒	☐
8	350	355	Sand Fine W/Water	☒	☐
	0	0	1- 6" Bolt on Cap 2 hour development	☐	☐
	0	0	15' of 5" Casing	☐	☐
	0	0	1- 5" K Packer	☐	☐
	0	0	5' of 20 slot screen	☐	☐

Completed Depth 355' (Measurable)

Date: Started 11/26/97 Completed 12/2/97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Date 12/2/97

and Supervisor or Operator Date 12/2/97

(Sign Once if Firm Official and Operator)

(Louie Hanner)

NENE 13 56N 5W