

97-8514 EVIDENCE OF PRIORITY

Bonner County parcel data

Field	Value
ACRES	40
ADDRESS1	PO BOX 819
ADDRESS2	
CITY	PRIEST RIVER
COUNTY	Bonner
ID	15684335
LEGAL1	11-56N-5W SWSW
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	HARMS, RUSSELL
P_ADDRESS	
P_ZIPCODE	
ParcelCount	1
PIN	RP56N05W116150A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	
UPDATED	6/17/2023
YEAR_BUILT	2018
ZIPCODE	83856

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT1. WELL TAG NO. D D0076514Drilling Permit No. 888149

Water right or injection well # _____

2. OWNER: Russell HarmsName PO Box 819Address 7500 Slippery Slope TrailCity Boise River State Id. Zip 83856

3. WELL LOCATION:

Twp. S6 North ☒ or South ☐ Rge. S East ☐ or West ☒Sec. 11 1/4 SW 1/4 SW 1/4Gov't Lot _____ County BonnerLat. N 48° 12.754 (Deg. and Decimal minutes)Long. 116° 50.070 (Deg. and Decimal minutes)Address of Well Site 7500 Slippery Slope TrailCity Boise River ID

(Give at least name of road + distance to road or landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material From (ft) To (ft) Quantity (lbs or ft³) Placement method/procedurePortland 0 38 25 bags Poured DryExp. plug _____ _____ _____ _____

8. CASING/LINER:

Diameter (nominal) From (ft) To (ft) Gauge/Schedule Material Casing Liner Threaded Welded

6" 2 110 250 Steel ☒ ☐ ☐ ☒4" 10 200 200 PVC ☐ ☒ ☐ ☐☐ ☐ ☐ ☐☐ ☐ ☐ ☐Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 110'

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method Down Hole perforator 80' to 100'Manufactured screen ☒ Y ☐ N Type PVCMethod of installation Telescoped

From (ft) To (ft) Slot size Number/ft Diameter (nominal) Material Gauge or Schedule

170 180 10 10 4" PVC 200 psi☐ ☐ ☐ ☐ ☐ ☐☐ ☐ ☐ ☐ ☐ ☐Length of Headpipe 160' Length of Tailpipe 20'Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material From (ft) To (ft) Quantity (lbs or ft³) Placement method☐ ☐ ☐ ☐☐ ☐ ☐ ☐☐ ☐ ☐ ☐

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 38' Static water level (ft) 70'Water temp. (°F) Cold Bottom hole temp. (°F) SameDescribe access port Bottom Cap

Well test: _____ Test method: _____

Drawdown (feet) Discharge or yield (gpm) Test duration (minutes) Pump Bailer Air Flowing artesian

100% 5 gpm 1 hr ☐ ☐ ☒ ☐

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in) From (ft) To (ft) Remarks, lithology or description of repairs or abandonment, water temp. Water Y N

10 _____ _____ _____ _____0 12 Longau top Soil Tan _____ X12 16 Gravel _____ _____16 31 Clayish Soil w/ Gravel _____ X6 31 Sandy Gravel w/ clay S&G _____ _____31 50 water at 38 ft. 1 gpm _____ X50 55 Gravel Decom _____ X55 84 Cemented Gravel w/ clay _____ X84 110 Clay Reddish tan w/ large Gravel _____ X110 185 Granite Light Green soft _____ X185 200 Granite Green med _____ X☐ ☐ ☐ ☐