USE TYPEWRITER OR BALL POINT PEN

State of Idaho
Department of Water Resources

ENT'D

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, **Department of Water Resources within 30** days after the completion or abandonment of the well.

1. WELL OWNER

Name E.G. Bond

Address Rt. 1 Box 241 Spokane, Wa. 99204

Owner's Permit No. 97-76-N-14

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 132 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
inches	6 inches	+ 1 feet	80 feet
inches	inches	feet	feet
inches	inches	feet	feet
inches	inches	feet	feet

Was casing drive shoe used? ☐ Yes ☐ No

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☒ Yes ☐ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation 1/8 inches by 6 inches

Number	From	To
perforations	110 feet	130 feet
perforations	feet	feet
perforations	feet	feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name

Type Model No.

Diameter Slot size Set from feet to feet

Diameter Slot size Set from feet to feet

Gravel packed? ☒ Yes ☐ No Size of gravel 1/4

Placed from 60 feet to 130 feet

Surface seal depth 18 Material used in seal ☒ Cement grout ☐ Puddling clay ☐ Well cuttings

Sealing procedure used ☐ Slurry pit ☐ Temporary surface casing ☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.

97



Subdivision Name Government Lot

Lot No. 4 Block No.

County Bonner County

SW ¼ SW ¼ Sec. 9, T. 59 N/S, R. 4 E/W

7. WATER LEVEL

Static water level feet below land surface

Flowing? ☒ Yes ☐ No G.P.M. flow 1/2

Temperature 52° F. Quality good

Artesian closed-in pressure 3 p.s.i.

Controlled by ☐ Valve ☒ Cap ☐ Plug

Flowing well gether cement

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
6	0	3	loam		
	3	96	gray clay		
	96	101	sand stone	x	
	101	119	gray clay		
	119	130	decomposed granite		
	130	132	granite		

101751

10. Work started 6-20-75 finished 6-25-76

11. DRILLERS CERTIFICATION

Firm Name Bartholomew Drilling Firm No. 52

Address Nine Mile Falls, Wa. Date 6/25/76

Signed by (Firm Official) A.E. Bartholomew

and

(Operator) Same

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT