97-8877 EVIDENCE OF PRIORITY

BONNER COUNTY PARCEL DATA

Field	Value
ACRES	26
ADDRESS1	PO BOX 626
ADDRESS2	
CITY	FILER
COUNTY	Bonner
ID	15697348
LEGAL1	30-57N-4W S2NENE & N2SENE LYING E OF W R/W OF ACCESS ROAD
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	PENINSULA TRUST; SAVAGE, OTHO M & THERESA L TRUSTEES
P_ADDRESS	1649 PENINSULA LP LOOP
P_ZIPCODE	83856
ParcelCount	1
PIN	RP57N04W300451A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	
UPDATED	6/17/2023
YEAR_BUILT	1980
ZIPCODE	83328

Form 238-7
8/90

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

RECEIVED
MAR 0 4 1994
Department of Water Resources

USE TYPEWRITER OR POINT PEN

POSTED

1. WELL OWNER
Name Otho H. Savage
Address 6855 Pine St. Loop Sandpoint Id 83864
Drilling Permit No. 97-93-N-86-000
Water Right Permit No. _____

2. NATURE OF WORK
☒ New well ☐ Deepened ☐ Replacement
☐ Well diameter increase
☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

3. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED
☒ Rotary ☒ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION
Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
.250 inches	6 inches +	1 feet	188 feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☐ Torch ☐ Gun
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☒ Yes ☐ No
Manufacturer's name Cook
Type Stainless Model No. _____
Diameter 6 Slot size .25 Set from 188 feet to 193 feet
Diameter ___ Slot size ___ Set from _____ feet to _____ feet
Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____
Placed from _____ feet to _____ feet
Surface seal depth 19' Material used in seal: ☐ Cement grout
☒ Bentonite ☐ Puddling clay ☐ _____
Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing
☒ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld
☐ Cemented between strata
Describe access port _____

6. LOCATION OF WELL
Sketch map location must agree with written location.

N / W / E / S

Subdivision Name _____
Lot No. _____ Block No. _____
County Bonner
SE ¼ NE ¼ Sec. 30, T. 57 N ☒ S ☐ R. 1 E ☐ W ☒

7. WATER LEVEL
Static water level 50 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature 50 °F. Quality Clear
Describe artesian or temperature zones below.

8. WELL TEST DATA
☐ Pump ☐ Bailer ☒ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
20	193	1 hr.

090769

9. LITHOLOGIC LOG

Bore Diam.	Depth From	Depth To	Material	Water Yes	Water No
10	0	17	Sand + gravel		✓
9⅝	17	185	Clay - gray		✓
6	185	194	Sand & gravel	✓	

RECEIVED
FEB 24 1994
NORTHERN REGION
IDWR

MICROFILMED
FEB 09 1995

10.
Work started 1-6-94 finished 1-10-94

11. DRILLERS CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Intermountain Firm No. 513
Address HCE 5 Box 1A Priest River, Id 83856 Date 1-30-94
Signed by (Firm Official) _____
and
(Operator) Same

USE ADDITIONAL SHEETS IF NECESSARY — FORWARD THE WHITE COPY TO THE DEPARTMENT