

97-9727 – EVIDENCE OF PRIORITY
FROM BONNER COUNTY PARCEL DATA

Field	Value
ACRES	0.5
ADDRESS1	PO BOX 39
ADDRESS2	
CITY	COOLIN
COUNTY	Bonner
ID	15706711
LEGAL1	10-59N-4W 1ST ADDN TO COOLIN BLK 9 LOT 10,11 & 12
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	WHITE, MICHAEL & KIM
P_ADDRESS	246 SLEE ST
P_ZIPCODE	83821
PIN	RP00072009010AA
SOURCE	<null>
STATE	ID
SUB_NAME	COOLIN 1ST ADD RPLT BLK 4 LOTS 1 2 3 5
UPDATED	6/17/2023
YEAR_BUILT	2001
ZIPCODE	83821-0039

Form 238-7
6/02

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Well ID No.			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat:	:	Long:	:

1. WELL TAG NO. D 0041146
DRILLING PERMIT NO. 837970
Water Right or Injection Well No. _____

2. OWNER:
Name Kim White
Address 2416 Slee Rd.
City Coonlin State ID Zip 83821

3. LOCATION OF WELL by legal description:
You must provide address or Lot, Blk, Sub. or Directions to well.
Twp. 59 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 10 1/4 NW 1/4 SW 1/4
Gov't Lot _____ County Bonner
Lat: : : Long: : :
Address of Well Site Same City Coonlin
(Give at least name of road + Distance to Road or Landmark)
Lt. _____ Blk. _____ Sub. Name _____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD:
☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

Seal Material	From	To	Weight/Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>18</u>	<u>300 lbs</u>	<u>Temp Casing</u>

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 120
Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>+1</u>	<u>120</u>	<u>250</u>	<u>Steel</u>	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____
Packer ☒ Y ☐ N Type K

9. PERFORATIONS/SCREENS PACKER TYPE
Perforation Method Factory
Screen Type & Method of Installation Alloy pull back

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
<u>120</u>	<u>125</u>	<u>14</u>	<u>304</u>	<u>6"</u>	<u>SS</u>	☐	☐

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
110 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

12. WELL TESTS:
☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>5+</u>	<u>2'</u>	<u>112'</u>	<u>1 hr</u>

Water Temp. Cold Bottom hole temp. _____
Water Quality test or comments: _____

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0</u>	<u>18</u>	<u>Sand</u>		
<u>6"</u>	<u>18</u>	<u>52</u>	<u>Sand</u>		
<u>6"</u>	<u>52</u>	<u>110</u>	<u>Sand</u>		
<u>6"</u>	<u>110</u>	<u>125</u>	<u>Sand</u>		

RECEIVED
MAY 11 2006
IDWR/North

Completed Depth 125 (Measurable)
Date: Started 12-29-05 Completed 1-15-06

14. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
Company Name Cop & Pigg & Sons Firm No. 1408
Principal Driller and Operator I Steve Potts Date 1/15/06
Driller or Operator II _____ Date _____
Operator I _____ Date _____
Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

59N 4W 10

FORWARD WHITE COPY TO WATER RESOURCES