

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0079862

Drilling Permit No. 890894

Water right or Injection well # _____

2. OWNER: ROBERT FUNK

Name JENNY FUNK

Address 732 WATERS CREEK ROAD

City PRIEST RIVER State ID Zip 83856

3. WELL LOCATION:

Twp. 58 North ☒ or South ☐ Rge. 04 East ☐ or West ☒

Sec. 11 NE 1/4 NW 1/4 10 acres 40 acres 160 acres

Gov't Lot _____ County BONNER

Lat. 48 ° 39803 23.882 (Deg. and Decimal minutes)

Long. -116 ° 81857 49.114 (Deg. and Decimal minutes)

Address of Well Site _____

(Give at least name of road - Distance to Road or Landmark) City _____

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
BENTONITE	0	38	30 BAGS	POUR

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+2	143	.250	STEEL	☒	☐	☐	☐
5	130	150	.250	STEEL	☐	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 143

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____

Manufactured screen ☒ Y ☐ N Type TELESCOPIC

Method of Installation LOWER IN PLACE

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
149	154	15	5	5"	SS	.250

Length of Headpipe 20' Length of Tailpipe 0

Packer ☒ Y ☐ N Type FIGURE K

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
-----------------	-----------	---------	-----------------------	------------------

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 80 Static water level (ft) 74

Water temp. (°F) _____ Bottom hole temp. (°F) _____

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
150	15	60

Test method:

Pump	Bailer	Air	Flowing artesian
☐	☐	☒	☐

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
6	0	12	SAND COBBLES		X
6	12	40	LARGE GRAVELS SAND SILT		X
6	40	75	SILTY GRAVELS		X
6	75	170	SAND OCC GRAVELS ACTIVE	X	
6	170	172	GRAY CLAY		

RECEIVED

FEB 03 2020

IDWR/NORTH

Completed Depth (Measurable): 154'

Date Started: 08/13/19

Date Completed: 08/16/19

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name FOGLE PUMP & SUPPLY Co. No. 596

*Principal Driller [Signature] Date 8-18-19

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Identify

Identify from: Tax Parcels

Tax Parcels

FUNK, ROBERT E & JENNIFER L

Location: 2,291,364.408 1,914,531.633 Meters

Field	Value
ID	15688761
UPDATED	6/17/2023
PIN	RP58N04W112850A
OWNER	FUNK, ROBERT E & JENNIFER L
ADDRESS1	PO BOX 299
ADDRESS2	
CITY	COOLIN
STATE	ID
ZIPCODE	83821
P_ADDRESS	300 LOOKING GLASS LP
P_ZIPCODE	83856
SUB_NAME	
LEGAL1	11-58N-4W E2SE1/4NW
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
ACRES	5
COUNTY	Bonner
SOURCE	<null>
YEAR_BUILT	2021
ParcelCount	1
SHAPE	Polygon

Identified 1 feature