

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1 WELL TAG NO. D 0091048
Drilling Permit No 903844
Water right or injection well # _____

2 OWNER
Name GARRY & KIM BEDFORD
Address 204 BARRETT RD.
City PRESTON RIVER State ID Zip 83856

3 WELL LOCATION:
N ☒ S ☐ E ☐ W ☒
Sec 26 T 57 R 5
S 26 T 57 R 5

County BANNER
Loc 48 S 15.284 (Deg. and Decimal minutes)
Long -116 S 55.2364 (Deg. and Decimal minutes)
Address of Well Site 5841 HWY. 57
City PRESTON RIVER

Lot _____ Blk. _____ Sub Name _____

4 USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5 TYPE OF WORK:
☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6 DRILL METHOD:
☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7 SEALING PROCEDURES:
Seal Material From (ft) To (ft) Quantity (lbs or ft³) Placement method/procedure
CEMENT 0 38 1000 LBS. OVERBORE
CHP DRY POUR

8 CASING/LINER:
Casing Liner Threaded Welded
6 42 123 .750 STEEL ☒ ☐ ☐ ☒
4 20 580 5/4 PVC ☐ ☒ ☒ ☐

Has drive shoe used? ☒ Y ☐ N Shoe Depth(s) 123

9 PERFORATIONS/SCREENS:
Perforations ☐ Y ☒ N Method _____
Manufactured screen ☒ Y ☐ N Type PVC
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
600	580	.020		4	PVC	SCH 40

Length of headpipe _____ Length of Tailpipe _____
Backer ☐ Y ☒ N Type _____

10 FILTER PACK:
Filter Material From (ft) To (ft) Quantity (lbs or ft³) Placement method

11 FLOWING ARTESIAN:
Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____
Escape control device _____

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 132 Static water level (ft) 132
Water temp. (°F) COLD Bottom hole temp. (°F) COLD
Describe access port BOLT ON CAP

Well test:
Drawdown (feet) 600 Discharge or yield (gpm) 3 Test duration (minutes) 120
Test method:
Pump ☐ Bailor ☐ Air ☒ Flowing artesian ☐

Water quality test or comments: GOOD

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water
				Y N
10	0	1	TOP SOIL	
	1	38	LOAMY SAND	
8	38	46	" "	
	46	102	SILTY CLAY	
	102	123	SOFT DECOMPOSED SHALE	
6	123	132	FIRM DECOMPOSED SHALE	
	132	204	GRAY SHALE 1/2 GPM	X
	204	218	BROKEN GRAY SHALE 2 GPM	X
	218	361	GRAY SHALE	
	361	600	GRAY SHALE 1/2 GPM	X

RECEIVED

FEB 22 2022

IDWR/NORTH

208-263-5974

Mark Pitts
Robin Pitts

Serving
North Idaho
Over 20 Years



DRILLING • PUMPS • WATER TREATMENT
Complete Systems • From the Well To The House
435 Woodview Rd • Sandpoint, ID 83864

Completed Depth (Measurable) 600
Date Started 2/10/22 Date Completed 2/14/22

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
Company Name AAA SWEETWATER DRILLING No. 509
Principal Driller Mark Pitts Date 2-17-22
Driller [Signature] Date 2/17/22
Operator II _____ Date _____
Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required