

95-18547 EVIDENCE OF PRIORITY
FROM BONNER COUNTY PARCEL DATA

Field	Value
ACRES	4.9
ADDRESS1	276 PEACOCK LN
ADDRESS2	
CITY	SPIRIT LAKE
COUNTY	Bonner
ID	15701489
LEGAL1	21-54N-4W QUAIL RIDGE 3RD ADD BLK 2 LOT 6 CPWRS
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	CZERWONKA, RICHARD L & MARNA L
P_ADDRESS	276 PEACOCK LN
P_ZIPCODE	83869
ParcelCount	1
PIN	RP012030020060A
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	
UPDATED	6/17/2023
YEAR_BUILT	2021
ZIPCODE	83869-5122

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

5/10/21

1. WELL TAG NO. D 0088119

Drilling Permit No. 899533
Water right or injection well # _____

2. OWNER:

Name Rich Czerwona
Address 1028 Military Road East
City Tacoma State WA Zip 98445

3. WELL LOCATION:

Twp. 54 North ☒ or South ☐ Rge. 04 East ☐ or West ☒
Sec. 21 10 acres 1/4 SW 1/4 SE 1/4

Gov't Lot _____ County Bonner
Lat. 48 ° 00.4698N (Deg. and Decimal minutes)
Long. 116 ° 50.2602W (Deg. and Decimal minutes)
Address of Well Site NKA Peacock Lane

(Give at least name of road - Distance to Road or Landmark)
City Spirit Lake
Lot. 6 Blk. 2 Sub. Name Quail Ridge 3rd Addition

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite Chips	0	18	600 lbs	Dry Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	460	.250	Steel	☒	☐	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) Ring Bit @ 460'

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method Air Perforated
Manufactured screen ☐ Y ☒ N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
440	460	1/4x1	9	6"	Steel	250

Length of Headpipe _____ Length of Tailpipe _____
Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
N/A				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 415 Static water level (ft) 365
Water temp. (°F) Cold Bottom hole temp. (°F) Cold
Describe access port Welded Steel Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
N/A	30+ gpm	240	☐	☐	☒	☐

Test method:

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
12	0	20	Sand & Gravel		X
8	20	196	Sand & Gravel		X
8	196	415	Brown Clay		X
8	415	430	Sand	X	
8	430	460	Sand & Gravel	X	

RECEIVED

MAY 10 2021

IDWR / NORTH



Completed Depth (Measurable): 460'

Date Started: 05/03/2021

Date Completed: 05/04/2021

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Horsley Drilling, Inc. Co. No. 632

*Principal Driller C. Mark Horsley Date 05/04/2021

*Driller [Signature] Date 05/04/2021

*Operator II _____ Date _____

Operator I Josh Roberge Date 05/04/2021

* Signature of Principal Driller and rig operator are required.