

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATION

Permit No: 65-23573
Exam Date: 06/11/2024

1. Current Owner:
ALLAN MAKI 7776 PIERCE PARK BOISE ID 83714
2. Accompanied by: *In house exam*
Phone No:
Address:
Relationship to permit Holder:

3. **SOURCE:**
GROUND WATER

Method of Determination: application and permit

B. OVERLAP REVIEW

1. Other water rights with the same place of use: NO Overlap

Water Right No.	Source	Purpose of Use	Basis

Comments: NA

2. Other water rights with the same point-of-diversion: NO Overlap

Water Right No.	Source	Purpose of Use	Basis

Comments: NA

C. DIVERSION AND DELIVERY SYSTEM

1. **LOCATION OF POINT(S) OF DIVERSION:**

GROUND WATER L7 (NE¼ SW¼), Sec. 23, Twp 07N, Rge 02E, B.M. BOISE County

Method of Determination: application, permit and ArcMap

PLACE OF USE: DOMESTIC

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
07N	02E	23									X L7								

Method of Determination: application, permit and ArcMap

3.

Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.

☒

Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.

Aerial Photo Attached (required for irrigation of 10+ acres).

Photo of Diversion and System Attached

4.

Well or Diversion ID No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurements:

E. FLOW CALCULATIONS

Additional Computation Sheets Attached

Measured Method:

F. VOLUME CALCULATIONS

1. Volume Calculations for irrigation:

$$V_{IR} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$$

$$V_{DR} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 =$$

$$V = \text{Smaller of } V_{IR} \text{ and } V_{DR} =$$

2. Volume Calculations for Other Uses: 1.2 af for indoor and up to ½ acre of irrigation per Administrative Application Processing Memo #22.

G. NARRATIVE/REMARKS/COMMENTS: ArcMap and Boise County confirm permit holder as current owner. There is not a dwelling on the property, but the owners park a trailer on the lot and are irrigating the lot, so the water is being put to beneficial use. There is a septic drain field that was installed 2 years ago. There are no rights overlapping the POU or POD.

POU is located within Lot 6, Blk 2, Hansons River View Subdivision.

POD is located within Lot 7, Blk 2 Hansons River View Subdivision. The location of the POU and POD were listed backwards on the permit. Those conditions were corrected.

Remove condition 026A.

Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS

1. Recommended Amounts

<u>Beneficial Use</u>	<u>Period of Use</u>	<u>Rate of Diversion</u>	
DOMESTIC	01/01 to 12/31	0.04 CFS	1.2 AF
<u>Totals:</u>		0.04 CFS	1.2 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☒ None

I. AUTHENTICATION

Jean Hersley -

Field Examiner's Name Jean Hersley Date 6-18-24

Reviewer HT Date 6/27/24


65-23573

The screenshot displays the Boise County Parcels web application. The interface includes a top navigation bar with various links and a search bar. The main map area shows an aerial view of a property with several parcels outlined in yellow. One parcel, labeled RP031010020060, is highlighted with a blue overlay, indicating a permit. A sidebar on the left lists map layers such as Boise County Mask, P155, Subdivisions, Boise County Parcels, Wells, Water Right Places of Use, NFHL Flood Hazard Zones, Idaho Surface Management Agency, and Taxing Districts. A legend is also visible. On the right, a detailed information panel for the selected parcel (RP031010020060, MAKI ALLAN EDHART) provides the following details:

- Zoom to
- The parcel number is RP031010020060
- Owner 1: Maki Allan Edhart
- Owner 2: Maki Elaine Eberharter
- Address: , Id
- Mailing Address: 7776 PIERCE PARK
- Legal Address: T7n R2e Sec 23, Hansons River View Sub, Blk 2 Lot 6
- Acres: 0.66
- Instrument Number: 155616/
- Taxing Districts:**
- Tax Code Areas: 0220000
- City:
- Fire: HORSESHOE BEND FIRE
- Highway: BOISE COUNTY ROAD & BRIDGE
- Library: HORSESHOE BEND FREE LIBR
- School: HORSESHOE BEND ELEM #73

At the bottom right, a status bar indicates "Selected features: 1" and "Mapbox, Microsoft, Powered by Esri".

Boise county shows permit holder as current owner. No dwelling is shown on property but excavation has started.



ArcMap shows permit holder as current owner. No dwelling is shown on property but excavation has started.

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D D0053251
DRILLING PERMIT NO. _____
Water Right or Injection Well No. _____

2. OWNER:

Name James & Pauleen Grant
Address PO Box 416
City Horseshoe Bend State ID Zip 83629

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 07 North ☒ or South ☐
Rge. 2 East ☒ or West ☐
Sec. 23 1/4 NE 1/4 SW 1/4
Gov't Lot _____
County _____

Lat: 43° 35.583' Long: 116° 11.227'

Address of Well Site 27 Hanson Drive

City _____

LL 7 Blk. 2 Sub. Name Hanson's River View

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply

(Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

Seal Material	From	To	Weight	Volume	Seal Placement Method
Bentonite	0	95	1700		Dry poured

Was drive shoe used? ☒ N ☐ Shoe Depth(s) 116' (6" only)

Was drive shoe seal tested? ☒ N ☐ How? air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-116	.25	Steel	☒	☐	☒	☐
5"	+2	-718	.25	Steel	☐	☒	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☐ N Type _____

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method torch

Screen Type & Method of Installation _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
360	700	3/8" x 1/4"	1/ft	5"	Steel	☐	☒

10. FILTER PACK

Filter Material	From	To	Weight	Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

30 ft. below ground Artesian pressure _____ lb.
Depth flow encountered 715 ft. Describe access port or control devices: Well cap

12. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
30		700	1 hr

Water Temp. 58°

Bottom hole temp. _____

Water Quality test or comments: reddish tint - no sediment

Depth first Water Encounter 105

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
12"	0	12	Brown Clay		
12"	12	20	Gravel, sand & Rocks		
8"	20	103	Gravel, sand & Rocks		
8"	103	110	Brown DG	X	
8"	110	115	Blue Clay		
8"	115	116	Blue Basalt - Hard		
6"	116	305	Blue Basalt - Hard		
6"	305	315	Brown Basalt - Med Hard		
6"	315	440	Blue Basalt - Hard		
6"	440	445	Brown Basalt		
6"	445	530	Blue Basalt		
6"	530	550	Med Hard Blue Basalt		
6"	550	600	Hard Blue Basalt		
6"	600	675	Brown Basalt - Med Hard		
6"	675	710	Hard Blue Basalt		
6"	710	718	Fractured Blue Basalt	X	

RECEIVED

NOV 18 2008

WATER RESOURCES
WESTERN REGION

Completed Depth 718 (Measurable)

Date: Started 9/23/08 Completed 10/31/08

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Ailstone Well Drilling Firm No 561

Principal Driller Dan Jones Date 11/7/08

and Driller or Operator II Matthew Jones Date 11/7/08

Operator I _____ Date _____

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

Hersley, Jean

From: Elaine Eberharter-Maki <edlawsolutions@gmail.com>
Sent: Tuesday, June 18, 2024 10:50 AM
To: Hersley, Jean
Subject: Re: Water Permit 65-23573
Attachments: image001.png

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

I am parking a trailer on the property and using the water for domestic purpose.



Elaine Eberharter-Maki
EDUCATION LAW SOLUTIONS PA
Mobile: 208-870-5483
edlawsolutions@gmail.com

CONFIDENTIALITY AND SIGNATURE NOTICE: This email, and any attachments, may contain information that is privileged, confidential and/or protected from disclosure under applicable law, and nothing contained therein shall be deemed to waive or diminish the protections afforded by such laws. **Do not:** (i) deliver, distribute, copy or disclose this transmission or its contents to any third party or business entity; or (ii) produce a copy of this e-mail in connection with any litigation without the advice of any attorney; or (iii) take any action in reliance on the information it contains. If you are not an intended recipient of this transmission, please notify the sender immediately and delete the original message without making any copies. Nothing in this communication is intended to constitute an electronic signature, unless a specific statement to the contrary is included in this communication.

On Tue, Jun 18, 2024 at 10:39 AM Hersley, Jean <Jean.Hersley@idwr.idaho.gov> wrote:

Thank you for the picture. I just need to know if you are parking an RV or trailer on the property and using the water for domestic use. If so, we won't need a phone call.



Jean Hersley

Technical Records Specialist II

Idaho Dept Water Resources

(208) 287-4942

From: Elaine Eberharter-Maki <edlawsolutions@gmail.com>
Sent: Tuesday, June 18, 2024 10:31 AM
To: Hersley, Jean <Jean.Hersley@idwr.idaho.gov>
Subject: Re: Water Permit 65-23573

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

Ms. Hersley: Attached please find a picture of the lot with red metal posts identifying where the septic drain field is located. The drain field was installed at the approximate cost of \$10,00 by Dobson Excavation 2 years ago. The well is also used to irrigate the lot and border vegetation. We look forward to talking with you this week regarding our application before it expires. We can make ourselves available most any time. Allan & Elaine



Maki

Elaine Eberharter-Maki
EDUCATION LAW SOLUTIONS PA
Mobile: 208-870-5483
edlawsolutions@gmail.com

CONFIDENTIALITY AND SIGNATURE NOTICE: This email, and any attachments, may contain information that is privileged, confidential and/or protected from disclosure under applicable law, and nothing contained therein shall be deemed to waive or diminish the protections afforded by such laws. **Do not:** (i) deliver, distribute, copy or disclose this transmission or its contents to any third party or business entity; or (ii) produce a copy of this e-mail in connection with any litigation without the advice of any attorney; or (iii) take any action in reliance on the information it contains. If you are not an intended recipient of this transmission, please notify

the sender immediately and delete the original message without making any copies. Nothing in this communication is intended to constitute an electronic signature, unless a specific statement to the contrary is included in this communication.

On Thu, Jun 13, 2024 at 3:37 PM Elaine Eberharter-Maki <edlawsolutions@gmail.com> wrote:

Ms. Hersley: Would it be possible to set up a phone call with you for Monday morning, June 17, regarding our application for a water permit? We are available most any time in the morning. Thank you - Allan & Elaine Maki

Elaine Eberharter-Maki
EDUCATION LAW SOLUTIONS PA
Mobile: 208-870-5483
edlawsolutions@gmail.com

CONFIDENTIALITY AND SIGNATURE NOTICE: This email, and any attachments, may contain information that is privileged, confidential and/or protected from disclosure under applicable law, and nothing contained therein shall be deemed to waive or diminish the protections afforded by such laws. **Do not:** (i) deliver, distribute, copy or disclose this transmission or its contents to any third party or business entity; or (ii) produce a copy of this e-mail in connection with any litigation without the advice of any attorney; or (iii) take any action in reliance on the information it contains. If you are not an intended recipient of this transmission, please notify the sender immediately and delete the original message without making any copies. Nothing in this communication is intended to constitute an electronic signature, unless a specific statement to the contrary is included in this communication.

On Tue, Jun 11, 2024 at 11:09 AM Hersley, Jean <Jean.Hersley@idwr.idaho.gov> wrote:

Dear Permit Holder:

The Department of Water Resources (Department) is in the process of reviewing your permit for licensing. Water permit 65-23573 is a permit for domestic use for 1 home from groundwater (well). This permit also includes a ½ acre of irrigation.

After reviewing aerial imagery, it doesn't appear there is a dwelling on the property or that any irrigation has taken place. How is this water being put to beneficial use?

Please respond to this email within 14 days so the Department can continue reviewing this permit for licensing. Please let me know if you have any questions. Thank you.



Jean Hersley

Technical Records Specialist II

Idaho Dept Water Resources

(208) 287-4942