

## Travis L. Thompson

---

**From:** Nathan Erickson <nerickson@tfid.org>  
**Sent:** Thursday, June 1, 2023 4:49 PM  
**To:** Travis L. Thompson  
**Cc:** Robert Bohling; Jeff Malina; Erin Steel; Josh Baird  
**Subject:** Hankins Well #2 Pump Test

Hi Travis,

We were able to fire up the Hankins Well #2 yesterday and could only run it for 35 minutes until it was pumping air. The exact time of the test was 5-31-2023, from 8:15 am to 8:50 am. The well started pumping at 700 gpm, the flow quickly went down to around 400 gpm, and at the end, it was pumping 320 gpm with 29 feet of drawdown. After talking with the water distribution staff, it sounds like running a longer pump test runs the risk of drawing down the water table and drying up some of the domestic wells to the east. Apparently, this has been an issue in the past. Because of the potential injury to neighboring domestic wells, the City will not be able to conduct a longer pump test from the Hankins wells.

Let me know if you have any questions.

Thanks,

**Nathan Erickson**  
Environmental Manager  
City of Twin Falls  
(208) 735-7272  
[nerickson@tfid.org](mailto:nerickson@tfid.org)