

95-18478 EVIDENCE OF PRIORITY

Field	Value
ACRES	13
ADDRESS1	PO BOX 986
ADDRESS2	<null>
CITY	SPIRIT LAKE
COUNTY	Kootenai
ID	16844914
LEGAL1	SPIRIT LAKE EAST, LT 1
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
OWNER	GARDOM, BRANDON
P_ADDRESS	5040 W HIGHWAY 54
P_ZIPCODE	<null>
ParcelCount	1
PIN	074200000010
SHAPE	Polygon
SOURCE	<null>
STATE	ID
SUB_NAME	SPIRIT LAKE EAST
UPDATED	4/5/2024
YEAR_BUILT	2022
ZIPCODE	83869

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0088010

Drilling Permit No. 697819
Water right or injection well # _____

2. OWNER:

Name Timberland Construction Services LLC
Address 31391 North Spitfire Street
City Spirit Lake State ID Zip 83869

3. WELL LOCATION:

Twp. 53 North ☒ or South ☐ Rge. 04 East ☐ or West ☒
Sec. 9 1/4 SW 1/4 SW 1/4
Gov't Lot _____ County Kootenai
Lat. 47 ° 56.898 (Deg. and Decimal minutes)
Long. 116 ° 50.9316 (Deg. and Decimal minutes)
Address of Well Site NKA Hwy 54

(Give at least name of road + distance to road or landmark)

City Spirit Lake
Lot. 1 Blk. _____ Sub. Name Spirit Lake East

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite Chips	0	18	650 lbs	Dry Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner	Threaded	Welded
6"	+2	640	.250	Steel	☒	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) Ring Bit @ 640'

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method Air Perforated
Manufactured screen ☐ Y ☒ N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
620	640	1/4x1	9	6"	Steel	.250

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
N/A				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 570 Static water level (ft) 570
Water temp. (°F) Cold Bottom hole temp. (°F) Cold
Describe access port Welded Steel Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
N/A	30+ gpm	240	☐	☐	☒	☐

Test method:

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water
				Y N
12	0	20	Sand & Gravel	
8	20	570	Sand & Gravel	X
8	570	640	Sand & Gravel	X

RECEIVED

MAR 19 2021

DWR/NORTH



Completed Depth (Measurable) 640'

Date Started: 03/10/2021

Date Completed: 03/12/2021

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Horsley Drilling, Inc. Co. No. 632

*Principal Driller C. Mark Horsley Date 03/12/2021

*Driller [Signature] Date 03/12/2021

*Operator II _____ Date _____

Operator I Josh Roberge Date 3/12/2021

* Signature of Principal Driller and rig operator are required.