

Jordan, Blake

From: Jordan, Blake
Sent: Monday, June 23, 2025 9:24 AM
To: Thane Kindred
Cc: Kristin Moore; Chase Becker
Subject: RE: Issue of License 21-13235 for ORR Red Rock LLC

Hi Thane,

Thanks for reaching out about this. I've reviewed your feedback and agree with the 0.29 cfs. I'll be issuing an amended license to reflect this change. Please note that the license will carry a condition limiting rights 21-13269, 21-13270, 21-7360, and 21-13235 to a combined total of 0.33 cfs.

Feel free to reach out if you have any questions.

Blake Jordan | Water Resources Program Manager



900 N Skyline Dr. Ste A
Idaho Falls, ID 83402
208-497-3777

Blake

From: Thane Kindred <thane.rmea@gmail.com>
Sent: Thursday, June 19, 2025 10:17 AM
To: Jordan, Blake <Blake.Jordan@idwr.idaho.gov>
Cc: Kristin Moore <kristin.rmea@gmail.com>; Chase Becker <cbecker@alpenglowlpartnersllc.com>
Subject: Issue of License 21-13235 for ORR Red Rock LLC

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

Blake,

Kristin and I have been working with ORR Red Rock LLC on Permit number 21-13235 and we recently got an Issue of License from IDWR regarding this permit. In this proposed license IDWR recommends a rate of diversion of 0.23 CFS. This proposed rate seems to come from the field examination (attached) which states the following:

"Flow measured at Well #1 was 39 GPM, Well#2 was 110 GPM, totaled 149 GPM and calculates to 0.33 CFS. Well #1 can divert a total of 0.09 CFS, Well #2 can divert a total of 0.24 CFS. There are multiple water rights owned by Alpenglowl and used at the RV park. Water rights 21-13270 and 21-13269 are irrigation rights, diverted from both wells for a combined 0.06 CFS. Water right 21-7360 is commercial use and has diverted from Well #1, for 0.04 CFS. 21-13235 was permitted for 0.58 CFS. However, total diversion rate found for the system was 0.33 CFS. 21-13235 will be licensed for 0.23 CFS."

Though we agree that the license should not be issued for more than what has been realized on the property, we would suggest that the licensed rate should be 0.29 CFS rather than 0.23 CFS. We make this suggestion because irrigation rights

21-13270 and 21-13269 are only licensed for the summer months while the commercial rights (21-7360 and 21-13235) are licensed/permitted for the full year. At times when the irrigation rights are not being used, we feel that Red Rock LLC should be allowed to use the full water available to them. Thus, if the total capacity of the wells is 0.33 CFS and commercial water right 21-7360 diverts 0.04 CFS, water right 21-13235 should be licensed for 0.29 CFS (0.33-0.04).

--

Thanks,
Thane Kindred, GIT

(208) 524-2353 Ext. 108
482 Constitution Way Suite 303
Idaho Falls, ID 83402

