

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATION

Permit No: 15-7369
Exam Date: 07/16/2024

1. Current Owner:
DL PRICE FAMILY TRUST
4491 W 4700 S
MALAD CITY ID 83252-6630

2. Accompanied by: Clint Price
Phone No:
Address:
Relationship to permit Holder:

3. **SOURCE:**
GROUND WATER

Method of Determination: Site Visit

B. OVERLAP REVIEW

1. Other water rights with the same place of use:
The place of use lies within the boundaries of Samaria Water & Irrigation Company water rights 15-2025, 15-2024, 15-2023, 15-2075, 15-2074. No irrigation water is currently provided to the place of use from Samaria Water & Irrigation Co.

2. Other water rights with the same point-of-diversion: NO Overlap

C. DIVERSION AND DELIVERY SYSTEM

Water is delivered from the well south along a buried pressurized mainline pipe. Wheel lines connect to risers and run east-west to deliver irrigation water to the 42.5 acres.



1. **LOCATION OF POINT(S) OF DIVERSION:**

GROUND WATER NE¼ SE¼, Sec. 2, Twp 15S, Rge 35E, B.M. ONEIDA County

Method of Determination: GPS

PLACE OF USE: IRRIGATION

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
15S	35E	2													26.0	16.5			42.5

Total Acres: 42.5

Method of Determination: Field Visit, Aerial Imagery

3. Delivery System Diagram Attached (required). Indicate all major components and distances between components.

☒ Indicate weir size/pipe as applicable.

☒ Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.

☒ Aerial Photo Attached (required for irrigation of 10+ acres).

☒ Photo of Diversion and System Attached

Well or Diversion ID No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
D0011997	GE	50	DTFT1020037		



D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date
Flowmeter	Nautilus	Hidroconta				

2. Measurements: 475 GPM= **1.06 cfs****Permit limited to 0.85 cfs**

Flow meter appears properly installed on a section of straight pipe near the well. Totalizer displayed 90.43 AF on 7/16/24.

F. VOLUME CALCULATIONS

1. Volume Calculations for irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = 42.5 \text{ acres} \times 3.5 \text{ af/acre} = \mathbf{148.8 \text{ af.}}$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 = 0.85 \times 214 \times 1.9835 = 360 \text{ af.}$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 148.8 \text{ AF}$$

2. Volume Calculations for Other Uses: Stockwater: 100 cattle x 12 gpd x 365 days = 438,000 gallons = **1.3 AF****Total 150.1 af**


G. NARRATIVE/REMARKS/COMMENTS

Domestic Use: No domestic was developed under this permit.

A hose can connect to the conveyance system to provide water for livestock from the well.

Well drilling report for tag D0011997 is for a 140 ft deep well drilled in September 2000.

Well drilling report for tag D0102824 was deepened to 260 ft in May 2024. Both tags were welded to the well casing.



Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS

1. Recommended Amounts

<u>Beneficial Use</u>	<u>Period of Use</u>	<u>Rate of Diversion</u>	<u>Annual Volume</u>
IRRIGATION	04/01 to 10/31	0.85 CFS	149.0 AF
STOCKWATER	01/01 to 12/31	0.02 CFS	1.3 AF

Totals: 0.85 CFS 150.1 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☒ None

I. AUTHENTICATION

Christian Stewart - Water Resource Agent

Field Examiner's Name Christian J Stewart Date 10/06/2025

Reviewer _____ Date _____


State of Idaho
Department of Water Resources

Water Right

15-7369

DI Price Family Trust

October 06, 2025



0 0.05 0.1 0.2 Miles

- Place Of Use Boundary
- Point of Diversion
- State Outline
- Townships
- PLS Sections
- Quarter Quarters

