

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
IN-OFFICE REVIEW/BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATIONExam Date: 5/7/2026

1. Does this qualify for an in-office field exam (IDAPA 37.03.02.035.01.q)? X Y N
- a. Irrigation of 5 acres or less
- b. Storage of up to 14.6 AF for stockwater purposes only
- c. X Any use other than irrigation or storage, if the combined diversion rate is 0.24 cfs or less
- d. Other < >

Comment: N/A

2. Current Owner: Charles and Tammra Cramer

Owner of Record Correct? X Y NAddress of Record Correct? X Y NIf No Explain: N/A

3. Beneficial Use Fees have been paid: X Y N Receipt No: C126025

4. Source: Tributary:

St Joe River

Coeur D'Alene Lake

Method of Determination: GIS, Idaho Tax Parcel Data, and the Permit Holders Statement of Completion for Proof of Beneficial Use (Proof Statement).

Change in Source: Y X N**B. OVERLAP REVIEW**

1. Other water rights with the same place of use: Overlap ? Yes X No

Water Right No.	Source	Purpose of Use	Basis
N/A			

Comments: There are no other Water Rights (WR) overlapping the permitted place of use (POU).

2. Other water rights with the same point of diversion: Overlap ? Yes X No

Water Right No.	Source	Purpose of Use	Basis
N/A			

Comments: There are no other WR's overlapping the permitted point of diversion (POD).**C. DIVERSION AND DELIVERY SYSTEM**

1. Location of Point(s) of Diversion:

Source	Govt. Lot	¼	¼	Sec.	Twp.	Rge.		County
St Joe River	5	NE	SW	14	46N	01W	B.M.	Benewah

Method of Determination: GIS, Idaho Tax Parcel Data, and 2025 NAIP Aerial Imagery.Change in POD? Y X N Amendment Required? Y X N

2. Place of Use: Domestic

TWP	RGE	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
46N	01W	14									D	D		D					D
		Lot #									5	4		5					

Method of Determination: GIS, Idaho Tax Parcel Data, and 2025 NAIP Aerial Imagery.Change in POU? Y X N Amendment Required? Y X N

3. Diversion System Information

Description: N/A Delivery System Diagram Attached. (mark all major components and distances between components) X Aerial Photo indicating the location of the recommended POD and POU. X Aerial Photo Attached (required) Photo of Diversion and System Attached

3. Diversion Id No.*	Motor Make	HP	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
N/A					

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1. Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date
N/A						

2. Measurement Comments: No measurement is required for permits qualifying for an in-office examination according to the IDAPA Beneficial Use Examination Rules.

E. FLOW CALCULATIONS

 Additional Computation Sheets AttachedMeasured Method: According to Administrative Application Processing Memo #22 the standard diversion rate for the domestic use of a single-family home is 0.04 cfs. I am recommending a 0.04 cfs diversion rate.

Administrative Application Processing Memo #22 Standard = 0.04 cfs

Permit allowed = 0.04 cfs

Total Recommendation = 0.04 cfsComments: N/A

F. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = \underline{(N/A)}$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 = \underline{(N/A)}$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = \underline{(N/A)}$$

2. Volume Calculations for Other Uses: 2025 Aerial Imagery confirmed both internal and external domestic use for 1 home was developed. According to Administrative Application Processing Memo #22 the standard diversion volume for a single domestic use is 0.6 af for internal and 0.6 for external use or 1.2 af total. I am recommending a 1.2 af diversion volume.Comments: N/A

G. PURPOSE OF USE

Irrigation Y X N # Stock N/A Domestic # of Homes 1 (internal and external)Change in Purpose of Use? Y X NMethod of Determination: GIS, Idaho Tax Parcel Data, 2025 NAIP Aerial Imagery, and the permit holders Proof Statement.

H. NARRATIVE/REMARKS/COMMENTS

This permit qualifies for an in-office licensing examination. The permit authorized internal and external domestic use for one home diverting from the St. Joe River. Idaho Tax Parcel Data indicated the property was developed in 1994. 2025 NAIP Aerial Imagery confirmed both internal and external use (up to ½ an acre of yard irrigation) was developed within the development period. A condition on the permit requires the permit holder to install a fish screen meeting the fish screening and permit requirements of the Idaho Dept. of Fish and Game. The permit holder did not indicate a screening device was installed on their Proof Statement. However, according to the original application for permit this permit was a re-filing of lapsed permit 91-8046. They also indicated they had installed a screen on the pump intake. Therefore, it seems likely the permit holder still has a fish screen installed on the pump intake. The standards set in Administrative Application Processing Memo #22 were utilized to make a diversion rate a volume recommendation. All conditions of permit approval have been met, and development of beneficial use was confirmed within authorization on the permit. Therefore, I am recommending a 0.04 cfs diversion rate and 1.2 af diversion volume.

Conditions X60, X01, 187, 227, and 004 should remain on the license. Condition 029 should be removed from the license because information available in the WR file indicated the permit holder installed a fish screen meeting the fish screening and passage requirements of the Idaho Dept. of Fish and Game.

Have conditions of permit approval been met? ☒ Yes ☐ No

I. RECOMMENDATIONS

1. Recommended Amounts:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
Domestic	01/01-12/31	0.04 CFS	1.2 AF
	Totals:	0.04 CFS	1.2 AF

2. Recommended Amendments:

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☒ None

J. AUTHENTICATION

Field Examiner: Skyler Cheever – Water Resource Agent, Sr – State Office

Field Examiner's  Date 5/7/2024

Reviewer  Date 5/22/2026

Field Exam Map

Map showing the authorized point of diversion (yellow point) and place of use (orange outline).

