

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
IN-OFFICE REVIEW/BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATIONExam Date: 6/26/2026

1. Does this qualify for an in-office field exam (IDAPA 37.03.02.035.01.q)? X Y N
- a. X Irrigation of 5 acres or less
- b. Storage of up to 14.6 AF for stockwater purposes only
- c. Any use other than irrigation or storage, if the combined diversion rate is 0.24 cfs or less
- d. Other < >

Comment: N/A

2. Current Owner: Charels and Carol Compas

Owner of Record Correct? X Y NAddress of Record Correct? X Y NIf No Explain: N/A

3. Beneficial Use Fees have been paid:
- X
- Y
- N
- Receipt No: C126808

4. Source: Tributary:

Groundwater N/A

Method of Determination: GIS, Idaho Tax Parcel Data, and the Permit Holders Statement of Completion for Proof of Beneficial Use (Proof Statement).Change in Source: Y X N**B. OVERLAP REVIEW**

1. Other water rights with the same place of use: Overlap ?
- X
- Yes
-
- No

Water Right No.	Source	Purpose of Use	Basis
63-28907	Groundwater	Domestic	Decree

Comments: Water Right (WR) 63-28907 overlaps the permitted place of use (POU) but authorizes a different point of diversion (POD). However, since it is for a different beneficial use and authorizes a different POD there is no reason to limit use under both WR's when combined.

2. Other water rights with the same point of diversion: Overlap ?
-
- Yes
- X
- N

Water Right No.	Source	Purpose of Use	Basis
N/A			

Comments: There are no other WR's overlapping the permitted POD.**C. DIVERSION AND DELIVERY SYSTEM**

1. Location of Point(s) of Diversion:

Source	Govt. Lot	¼	¼	Sec.	Twp.	Rge.		County
Groundwater		NE	NE	28	06N	05W	B.M.	Canyon

Method of Determination: GIS, Idaho Tax Parcel Data, and Well Log.Change in POD? Y X N Amendment Required? Y X N

2. Place of Use: Irrigation

TWP	RGE	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
06N	05W	28	1.6																1.6
		Lot #																	
Total Acres =																			1.6

Method of Determination: GIS, Idaho Tax Parcel Data, 2026 Canyon County, and 2025 NAIP Aerial Imagery.Change in POU? Y X N Amendment Required? Y X N

3. Diversion System Information

Description: N/A Delivery System Diagram Attached. (mark all major components and distances between components) X Aerial Photo indicating the location of the recommended POD and POU. X Aerial Photo Attached (required) Photo of Diversion and System Attached

3. Diversion Id No.*	Motor Make	HP	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1. Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurement Comments: No measurement is required for permits qualifying for an in-office examination according to the IDAPA Beneficial Use Examination Rules.**E. FLOW CALCULATIONS** Additional Computation Sheets AttachedMeasured Method: According to Administrative Application Processing Memo #17 the standard diversion rate/acre for the irrigation of 5 acres or less is 0.03 cfs/acre. I am recommending a 0.05 cfs diversion rate.

(1.6 confirmed acres of irrigation) * (0.03 cfs/acre) = 0.048 or 0.05 cfs rounded.

Administrative Application Processing Memo #17 Calculation = 0.05 cfs

Permit allowed = 0.09 cfs

Total Recommendation = 0.05 cfsComments: N/A**F. VOLUME CALCULATIONS**

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = (1.6 \text{ acres}) \times (4.5 \text{ af/acre}) = 7.2 \text{ af}$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 = (0.05 \text{ cfs}) \times (260 \text{ days}) \times (1.9835 \text{ af/day}) = 25.8 \text{ af}$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 7.2 \text{ af}$$

2. Volume Calculations for Other Uses: N/A

Irrigation Diversion Volume Calculation = 7.2 af

Total Recommendation = 7.2 afComments: N/A

G. PURPOSE OF USEIrrigation X Y N # Stock N/A Domestic # of Homes N/A Change in Purpose of Use? Y X N Method of Determination: GIS, Idaho Tax Parcel Data, 2026 Canyon County/2025 NAIP Aerial Imagery, and the permit holders Proof Statement**H. NARRATIVE/REMARKS/COMMENTS**

This permit qualifies for an in-office licensing examination. The permit authorized the irrigation of 3.0 acres diverting from groundwater. 2026 Canyon County and 2025 NAIP Aerial Imagery did not indicate exactly where irrigation development occurred within the authorized POU. The permit holder provided photographs of developed irrigation with their Proof Statement. Therefore, 2026 Canyon County and 2025 NAIP Aerial Imagery and photographs provided with the permit holders Proof Statement confirmed the development of 1.6 acres of irrigation within the development period. The standards set in Administrative Application Processing Memo #17 was utilized to make a diversion rate recommendation. All conditions of permit approval have been met, and the development of beneficial use was confirmed within authorization on the permit. Therefore, I am recommending a 0.05 cfs diversion rate and 7.2 af diversion volume.

Conditions R69 should remain on the license. Condition 121 should be changed to 103 as is the standard with licensing. Condition 26A should be removed as is the standard with licensing. Condition 046 should be removed because the permit holder had a well drilled meeting the drilling permit requirements of Section §42-235, Idaho Code and applicable Well Construction Rules of the Department.

Have conditions of permit approval been met? X Yes No**I. RECOMMENDATIONS**

1. Recommended Amounts:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
Irrigation	03/01 – 11/15	0.05 CFS	7.2 AF
	<u>Totals:</u>	0.05 CFS	7.2 AF

2. Recommended Amendments:

 Change P.D. as reflected above Add P.D. as reflected above X None Change P.U. as reflected above Add P.U. as reflected above X None**J. AUTHENTICATION**Field Examiner: **Skyler Cheever – Water Resource Agent, Sr – State Office**Field Examiner's  Date 6/26/2026Reviewer  Date 6/29/2026

Field Exam Map

Map showing the authorized point of diversion (yellow point) and place of use (orange outline).



2026 Canyon County Aerial Imagery

63-34255



6/26/2026, 1 24 44 PM

Imagery 2026

- Blue Band_3
- Red Band_1
- Green Band_2
- Sections Adjusted for Assessment
- Canyon County Roads
- County
- Canyon County Roads
- Taxparcels



Maps and data are to be used for reference purposes only and Canyon County is not responsible for any inaccuracies herein contained. No responsibility is assumed for damages or other liabilities due to the availability, use or misuse of the information herein provided.

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0077166

Drilling Permit No. 63-34255 927867-883924

Water right or injection well # 63-34255

2. OWNER: Charlie Campos

Name Same

Address PO Box 1075

City Springville State UT Zip 84663

3. WELL LOCATION:

Twp. 6 North ☒ or South ☐ Rge. 5 East ☐ or West ☒

Sec. 28 1/4 NE 1/4 NE 1/4

Gov't Lot _____ County Canyon

Lat. 43 ° 49 ' 976 (Deg. and Decimal minutes)

Long. 116 ° 56 ' 120 (Deg. and Decimal minutes)

Address of Well Site 31727 83660

(Give at least name of road + distance to road or landmark) City Parma Id

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☐ Domestic ☐ Municipal ☐ Monitor ☒ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
<u>Bentonite</u>	<u>0</u>	<u>40</u>	<u>2500 lbs</u>	<u>pour in</u>

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>8 1/2</u>	<u>117</u>	<u>250</u>	<u>Steel</u>		☒	☐	☐	☒
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 117

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☐ N Method X

Manufactured screen ☐ Y ☐ N Type X

Method of installation X

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☐ N Type X

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device well cap

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 190 Static water level (ft) 148

Water temp. (°F) 63 Bottom hole temp. (°F) 63

Describe access port well cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
<u>195</u>	<u>100 GPM</u>	<u>1 hr</u>

Test method:

Pump ☒ Bailor ☐ Air ☒ Flowing artesian ☐
Both

Water quality test or comments: good clean water

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
<u>12</u>	<u>0</u>	<u>5</u>	<u>over burden</u>		
<u>12</u>	<u>5</u>	<u>25</u>	<u>Sandy Clay</u>		
<u>12</u>	<u>25</u>	<u>40</u>	<u>Brown Sand + Clay</u>		
<u>8</u>	<u>40</u>	<u>50</u>	<u>Mixed</u>		
<u>8</u>	<u>50</u>	<u>75</u>	<u>Sand + Gravel</u>		
<u>8</u>	<u>75</u>	<u>123</u>	<u>Brown Sand</u>		
<u>8</u>	<u>123</u>	<u>146</u>	<u>Gray Sand</u>		
<u>8</u>	<u>146</u>	<u>160</u>	<u>Tan Sand Course</u>		
<u>8</u>	<u>160</u>	<u>177</u>	<u>gray Sand</u>		
<u>8</u>	<u>177</u>	<u>190</u>	<u>Brown Sand</u>		
<u>8</u>	<u>190</u>	<u>210</u>	<u>Course Sand Tan</u>		
<u>8</u>	<u>210</u>	<u>230</u>	<u>Sand gravel Mixed</u>		
<u>8</u>	<u>230</u>	<u>245</u>	<u>Clay</u>		

RECEIVED

DEC 21 2017

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 230
Date Started: 10-16-2017 Date Completed: 10-20-2017

14. DRILLER'S CERTIFICATION:

I/we certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Knice Pump & Drilling Co. No. 417

*Principal Driller Mike Knice Date 11-25-2017

*Driller Mike Knice Date 11-25-2017

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.