

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
IN-OFFICE REVIEW/BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATIONExam Date: 9/9/2026

1. Does this qualify for an in-office field exam (IDAPA 37.03.02.035.01.q)? X Y N
- Irrigation of 5 acres or less
 - Storage of up to 14.6 AF for stockwater purposes only
 - X Any use other than irrigation or storage, if the combined diversion rate is 0.24 cfs or less
 - Other < >

Comment: N/A

2. Current Owner: Gary Oye and Cheryl Chipman

Owner of Record Correct? X Y NAddress of Record Correct? X Y NIf No Explain: N/A

3. Beneficial Use Fees have been paid:
- X
- Y
-
- N Receipt No: C128126

4. Source: Brushy Fork Creek Tributary: Crooked Fork Creek

Method of Determination: GIS, Idaho Tax Parcel Data, and the Permit Holders Statement of Completion for Proof of Beneficial Use (Proof Statement).

Change in Source: Y X N**B. OVERLAP REVIEW**

1. Other water rights with the same place of use: Overlap ?
-
- Yes
- X
- No

Water Right No.	Source	Purpose of Use	Basis
N/A			

Comments: There are no other Water Rights (WR) overlapping the permitted place of use (POU).

2. Other water rights with the same point of diversion: Overlap ?
-
- Yes
- X
- No

Water Right No.	Source	Purpose of Use	Basis
N/A			

Comments: There are no other WR's overlapping the permitted point of diversion (POD).**C. DIVERSION AND DELIVERY SYSTEM**

1. Location of Point(s) of Diversion:

Source	Govt. Lot	¼	¼	Sec.	Twp.	Rge.		County
Brushy Fork Creek		NW	SW	5	37N	15E	B.M.	Idaho

Method of Determination: GIS and Idaho Tax Parcel Data.Change in POD? Y X N Amendment Required? Y X N

2. Place of Use: Domestic

TWP	RGE	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
37N	15E	5										D							
		Lot #																	

Method of Determination: GIS, Idaho Tax Parcel Data, and 2025 NAIP/ESRI Aerial Imagery.Change in POU? Y X N Amendment Required? Y X N

3. Diversion System Information

Description: N/A☐ Delivery System Diagram Attached. (mark all major components and distances between components)☒ Aerial Photo indicating the location of the recommended POD and POU (required).☒ Additional Aerial Photography.☐ Photo of Diversion and System Attached

3. Diversion Id No.*	Motor Make	HP	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
N/A					

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1. Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date
N/A						

2. Measurement Comments: No measurement is required for permits qualifying for an in-office examination according to the IDAPA Beneficial Use Examination Rules.

E. FLOW CALCULATIONS

☐ Additional Computation Sheets Attached

Measured Method: 2025 NAIP/ESRI Aerial Imagery and photographs provided with the permit holders Proof Statement confirmed the development of internal and external domestic use. According to Administrative Application Processing Memo #22 the standard diversion rate for a single domestic use is 0.04 cfs. I am recommending a 0.04 cfs diversion rate.

Administrative Application Processing Memo #22 Standard = 0.04 cfs

Permit Authorization = 0.04 cfs

Total Recommendation = 0.04 cfsComments: N/A

F. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = \underline{N/A}$$

I.R.

$$V = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 = \underline{N/A}$$

D.R.

$$V = \text{Smaller of } V_{\text{I.R.}} \text{ and } V_{\text{D.R.}} = \underline{N/A}$$

2. Volume Calculations for Other Uses: According to Administrative Application Processing Memo #22 the standard diversion volume for a single domestic use is 0.6 af for internal and 0.6 for external use or 1.2 af total. I am recommending a 1.2 af diversion volume.

Comments: N/A

G. PURPOSE OF USE

Irrigation ☐ Y ☒ N # Stock N/A Domestic # of Homes 1 (Internal and External)Change in Purpose of Use? ☐ Y ☒ NMethod of Determination: GIS, Idaho Tax Parcel Data, 2025 NAIP/ESRI Aerial Imagery, and the permit holders Proof Statement.

H. NARRATIVE/REMARKS/COMMENTS

This permit qualifies for an in-office licensing examination. The permit authorized internal and external domestic use diverting from Bushy Fork Creek. 2025 NAIP/ESRI Aerial Imagery and photographs provided with the permit holders Proof Statement confirmed the development of internal and external domestic use within the development period. Two conditions on the permit require the permit holder to install a fish screen with a perforation size of 3/32 in or smaller and an approach velocity of 0.5 fps at the diversion intake. The permit holder confirmed on their Proof Statement and provided pictures a fish screen was installed on the diversion intake meeting conditional requirements.

The standards set in Administrative Application Processing Memo #22 were utilized to make a diversion rate and volume recommendation. All conditions of permit approval have been met, and development of beneficial use was confirmed within authorization on the permit. Therefore, I am recommending a 0.04 cfs diversion rate and 1.2 af diversion volume.

All conditions of permit approval should remain on the license unchanged.

Have conditions of permit approval been met? ☒ Yes ☐ No

I. RECOMMENDATIONS

1. Recommended Amounts:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
Domestic	01/01 – 12/31	0.04 CFS	1.2 AF
	<u>Totals:</u>	0.04 CFS	1.2 AF

2. Recommended Amendments:

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☒ None

J. AUTHENTICATION

Field Examiner: **Skyler Cheever – Water Resource Agent, Sr – State Office**

Field Examiner's  Date 9/9/2026

Reviewer  Date 9/10/26

Field Exam Map

Map showing the authorized point of diversion (yellow point) and place of use (orange outline).



2025 ESRI Aerial Imagery

