

STATE OF ID. HO  
DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

USE TYPEWRITER OR  
BALLPOINT PEN



State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

**1. WELL OWNER**

Name Joe H. Evans

Address Rt. 2, Box 266, Sandpoint, ID 83864

Owner's Permit No. 96-81-N-105

**7. WATER LEVEL**

Static water level 20 feet below land surface.

Flowing?  Yes  No G.P.M. flow \_\_\_\_\_

Artesian closed-in pressure \_\_\_\_\_ p.s.i.

Controlled by:  Valve  Cap  Plug

Temperature \_\_\_\_\_ °F. Quality \_\_\_\_\_

**2. NATURE OF WORK**

New well  Deepened  Replacement

Abandoned (describe method of abandoning) \_\_\_\_\_

**8. WELL TEST DATA**

Pump  Bailer  Air  Other \_\_\_\_\_

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>15 GPM</u>		
<u>Estimated Airlift</u>		

**3. PROPOSED USE**

Domestic  Irrigation  Test  Municipal

Industrial  Stock  Waste Disposal or Injection

Other \_\_\_\_\_ (specify type)

**9. LITHOLOGIC LOG**

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
6	0	3	Overburden, Soil		<input checked="" type="checkbox"/>
6	3	20	Broken Rock, Gravel, Boulders		<input checked="" type="checkbox"/>
6	20	60	Sand & Gravel	<input checked="" type="checkbox"/>	

**4. METHOD DRILLED**

Rotary  Air  Hydraulic  Reverse rotary

Cable  Dug  Other \_\_\_\_\_

**5. WELL CONSTRUCTION**

Casing schedule:  Steel  Concrete  Other \_\_\_\_\_

Thickness	Diameter	From	To
<u>.250</u> inches	<u>6</u> inches	<u>+ 1</u> feet	<u>57</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used?  Yes  No

Was a packer or seal used?  Yes  No

Perforated?  Yes  No

How perforated?  Factory  Knife  Torch

Size of perforation \_\_\_\_\_ inches by \_\_\_\_\_ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed?  Yes  No

Manufacturer's name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_

Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Gravel packed?  Yes  No  Size of gravel \_\_\_\_\_

Placed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface seal depth 20' Material used in seal:  Cement grout

Pudding clay  Well cuttings

Sealing procedure used:  Slurry pit  Temp. surface casing

Overbore to seal depth

Method of joining casing:  Threaded  Welded  Solvent Weld

Cemented between strata

Describe access port \_\_\_\_\_

**RECEIVED**

**JUL 22 1981**

Department of Water Resources  
Northern District Office

**004171**

**RECEIVED**

6" Drive Shoe Installed  
No PVC Liner Installed

**JUL 27 1981**

Department of Water Resources

**6. LOCATION OF WELL**

Match map location must agree with written location.

Subdivision Name \_\_\_\_\_

Lot No. \_\_\_\_\_ Block No. \_\_\_\_\_

County Bonner

SE 1/4 SE 1/4 Sec. 26, T. 56 N/S, R. 2W E/W.

**10.** Work started 7/15/81 finished 7/15/81

*cdl dl*

**11. DRILLERS CERTIFICATION**

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Ponderosa Drilling & Development, Inc. Firm No. 228

Address E. 6010 Broadway Date 7/17/81

Signed by (Firm Official) [Signature]

and (Operator) [Signature]

MAY 1981