

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

N/C

1. WELL OWNER
 Name Ted Diehl
 Address 8366 Sunnyside Rd. Sdpt., ID.
 Owner's Permit No. 96-90-N-100

7. WATER LEVEL
 Static water level -30 feet below land surface.
 Flowing? Yes No G.P.M. flow _____
 Artesian closed-in pressure _____ p.s.i.
 Controlled by: Valve Cap Plug
 Temperature 46 °F. Quality GOOD
Describe artesian or temperature zones below.

2. NATURE OF WORK
 New well Deepened Replacement
 Well diameter increase
 Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

8. WELL TEST DATA
 Pump Bailer Air Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>4 GPM</u>	<u>260</u>	<u>1</u>

3. PROPOSED USE
 Domestic Irrigation Test Municipal
 Industrial Stock Waste Disposal or Injection
 Other _____ (specify type)

9. LITHOLOGIC LOG

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
<u>6"</u>	<u>+1</u>	<u>5</u>	<u>Topsell, Boulders</u>		<input checked="" type="checkbox"/>
	<u>5</u>	<u>15</u>	<u>Boulders, Gravel, Clay</u>		<input checked="" type="checkbox"/>
	<u>15</u>	<u>260</u>	<u>Shale Rock</u>	<input checked="" type="checkbox"/>	

4" PVC Liner and Screen installed from -6' to -260'

101414

4. METHOD DRILLED
 Rotary Air Hydraulic Reverse rotary
 Cable Dug Other _____


5. WELL CONSTRUCTION
 Casing schedule: Steel Concrete Other _____


Thickness	Diameter	From	To
<u>.250</u> inches	_____ inches	<u>1</u> feet	<u>29</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? Yes No
 Was a packer or seal used? Yes No
 Perforated? Yes No
 How perforated? Factory Knife Torch Gun
 Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? Yes No
 Manufacturer's name COOK
 Type PVC Model No. _____
 Diameter 6" Slot size 20 Set from -254 feet to -259 feet
 Diameter _____ Slot size _____ Set from _____ feet to _____ feet
 Gravel packed? Yes No Size of gravel _____
 Placed from _____ feet to _____ feet
 Surface seal depth 20' Material used in seal: Cement grout
 Bentonite Pudding clay _____
 Sealing procedure used: Slurry pit Temp. surface casing
 Overbore to seal depth
 Method of joining casing: Threaded Welded Solvent Weld
 Cemented between strata
 Describe access port Well seal



6. LOCATION OF WELL
 Sketch map location must agree with written location

 Subdivision Name _____
JUN 21 1991
 Lot No. _____ Block No. _____
 County Bonner
SW 1/4 SW 1/4 Sec. 14, T. 57 N S R. 1 E W

10. Work started 7-26-90 finished 8-8-90

11. DRILLERS CERTIFICATION DL
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
 Firm Name Bob Pitts & Sons Firm No. 235
 Address Sandpoint, ID Date 8-9-90
 Signed by (Firm Official) Dale Pitts
 and _____
 (Operator) [Signature]